

ANALYTICAL REPORT

Eurofins Eaton Monrovia
750 Royal Oaks Drive
Suite 100
Monrovia, CA 91016
Tel: (626)386-1100

Laboratory Job ID: 380-15847-1
Client Project/Site: RED-HILL
Sampling Event: RUSH Weekly Red Hill

For:
City & County of Honolulu
630 South Beretania Street
Public Service Bldg. Room 308
Honolulu, Hawaii 96843

Attn: Mr. Erwin Kawata



Authorized for release by:
10/21/2022 1:45:06 PM
Kathleen Robb, Client Program Manager
(949)261-1022
Kathleen.Robb@et.eurofinsus.com

Designee for
Rachelle Arada, Manager of Project Management
(626)386-1106
Rachelle.Arada@et.eurofinsus.com

LINKS

Review your project
results through



Have a Question?



Visit us at:

www.eurofinsus.com/Env

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below. (DW,Water matrices)



Kathleen Robb
Client Program Manager
10/21/2022 1:45:06 PM





Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	5
Detection Summary	6
Client Sample Results	7
Action Limit Summary	10
Surrogate Summary	11
QC Sample Results	14
QC Association Summary	29
Lab Chronicle	31
Certification Summary	32
Method Summary	34
Sample Summary	35
Subcontract Data	36
Chain of Custody	85
Receipt Checklists	96

Definitions/Glossary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-15847-1

Qualifiers

GC/MS Semi VOA

Qualifier	Qualifier Description
*+	LCS and/or LCSD is outside acceptance limits, high biased.
^3+	Reporting Limit Check Standard is outside acceptance limits, high biased
F1	MS and/or MSD recovery exceeds control limits.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

GC/MS Semi VOA TICs

Qualifier	Qualifier Description
J	Indicates an Estimated Value for TICs
N	Presumptive evidence of material.
T	Result is a tentatively identified compound (TIC) and an estimated value.

Subcontract

Qualifier	Qualifier Description
U	This analyte was not detected.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-15847-1

Job ID: 380-15847-1

Laboratory: Eurofins Eaton Monrovia

Narrative

Job Narrative 380-15847-1

Comments

No additional comments.

Receipt

The samples were received on 8/10/2022 10:20 AM. Unless otherwise noted below, the samples arrived in good condition, and where required, properly preserved and on ice. The temperatures of the 6 coolers at receipt time were 1.1° C, 3.2° C, 3.3° C, 3.5° C, 4.2° C and 4.7° C.

GC/MS Semi VOA

Method 525.2: The continuing calibration verification (CCV) associated with batch 380-14896 recovered above the upper control limit for Di(2-ethylhexyl)adipate. The samples associated with this CCV were non-detects for the affected analytes; therefore, the data have been reported. The associated samples are impacted: MOANALUA WELLS (380-15847-1), (380-15819-N-1-A) and (380-16346-B-1-A).

No additional analytical or quality issues were noted, other than those described above or in the Definitions/Glossary page.

Subcontract non-Sister

See attached subcontract report.

Organic Prep

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

Subcontract Work

Methods 8015 Diesel LL (EAL) and Motor Oil, 8015 Gas (Purgeable) LL (EAL): These methods were subcontracted to EMAX Laboratories Inc. The subcontract laboratory certifications are different from that of the facility issuing the final report.

Method 625 PAH Physis LL (EAL) + TICs: This method was subcontracted to Physis Environmental Laboratories. The subcontract laboratory certification is different from that of the facility issuing the final report.

Detection Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-15847-1

Client Sample ID: MOANALUA WELLS

Lab Sample ID: 380-15847-1

No Detections.

Client Sample ID: TB:MOANALUA WELLS

Lab Sample ID: 380-15847-2

No Detections.

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Monrovia

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-15847-1

Client Sample ID: MOANALUA WELLS

Lab Sample ID: 380-15847-1

Date Collected: 08/08/22 10:57

Matrix: Drinking Water

Date Received: 08/10/22 10:20

Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
2,4'-DDD	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
2,4'-DDE	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
2,4'-DDT	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
2,4-Dinitrotoluene	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
2,6-Dinitrotoluene	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
4,4'-DDD	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
4,4'-DDE	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
4,4'-DDT	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
Acenaphthene	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
Acenaphthylene	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
Acetochlor	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
Alachlor	ND		0.050	ug/L		08/17/22 11:27	08/25/22 17:55	1
alpha-BHC	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
alpha-Chlordane	ND		0.050	ug/L		08/17/22 11:27	08/25/22 17:55	1
Anthracene	ND		0.020	ug/L		08/17/22 11:27	08/25/22 17:55	1
Atrazine	ND		0.050	ug/L		08/17/22 11:27	08/25/22 17:55	1
Benz(a)anthracene	ND		0.050	ug/L		08/17/22 11:27	08/25/22 17:55	1
Benzo[a]pyrene	ND		0.020	ug/L		08/17/22 11:27	08/25/22 17:55	1
Benzo[b]fluoranthene	ND		0.020	ug/L		08/17/22 11:27	08/25/22 17:55	1
Benzo[g,h,i]perylene	ND		0.050	ug/L		08/17/22 11:27	08/25/22 17:55	1
Benzo[k]fluoranthene	ND		0.020	ug/L		08/17/22 11:27	08/25/22 17:55	1
beta-BHC	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
Bromacil	ND	*+	0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
Butachlor	ND	*+	0.050	ug/L		08/17/22 11:27	08/25/22 17:55	1
Butylbenzylphthalate	ND	^3+	0.50	ug/L		08/17/22 11:27	08/25/22 17:55	1
Caffeine	ND		0.050	ug/L		08/17/22 11:27	08/25/22 17:55	1
Chlorobenzilate	ND	*+	0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
Chloroneb	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
Chlorothalonil (Draconil, Bravo)	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
Chlorpyrifos	ND		0.050	ug/L		08/17/22 11:27	08/25/22 17:55	1
Chrysene	ND		0.020	ug/L		08/17/22 11:27	08/25/22 17:55	1
delta-BHC	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
Di(2-ethylhexyl)adipate	ND		0.60	ug/L		08/17/22 11:27	08/25/22 17:55	1
Bis(2-ethylhexyl) phthalate	ND		0.60	ug/L		08/17/22 11:27	08/25/22 17:55	1
Diazinon (Qualitative)	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
Dibenz(a,h)anthracene	ND		0.050	ug/L		08/17/22 11:27	08/25/22 17:55	1
Diclorvos (DDVP)	ND		0.050	ug/L		08/17/22 11:27	08/25/22 17:55	1
Dieldrin	ND		0.20	ug/L		08/17/22 11:27	08/25/22 17:55	1
Diethylphthalate	ND		0.50	ug/L		08/17/22 11:27	08/25/22 17:55	1
Dimethoate	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
Dimethylphthalate	ND		0.50	ug/L		08/17/22 11:27	08/25/22 17:55	1
Di-n-butyl phthalate	ND		1.0	ug/L		08/17/22 11:27	08/25/22 17:55	1
Di-n-octyl phthalate	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
Endosulfan I (Alpha)	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
Endosulfan II (Beta)	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
Endosulfan sulfate	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
Endrin	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
Endrin aldehyde	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
EPTC	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1

Eurofins Eaton Monrovia

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-15847-1

Client Sample ID: MOANALUA WELLS

Lab Sample ID: 380-15847-1

Date Collected: 08/08/22 10:57

Matrix: Drinking Water

Date Received: 08/10/22 10:20

Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Fluoranthene	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
Fluorene	ND		0.050	ug/L		08/17/22 11:27	08/25/22 17:55	1
gamma-Chlordane	ND		0.050	ug/L		08/17/22 11:27	08/25/22 17:55	1
Heptachlor	ND		0.040	ug/L		08/17/22 11:27	08/25/22 17:55	1
Heptachlor epoxide (isomer B)	ND		0.050	ug/L		08/17/22 11:27	08/25/22 17:55	1
Hexachlorobenzene	ND		0.050	ug/L		08/17/22 11:27	08/25/22 17:55	1
Hexachlorocyclopentadiene	ND		0.050	ug/L		08/17/22 11:27	08/25/22 17:55	1
Indeno[1,2,3-cd]pyrene	ND		0.050	ug/L		08/17/22 11:27	08/25/22 17:55	1
Isophorone	ND		0.50	ug/L		08/17/22 11:27	08/25/22 17:55	1
Lindane	ND		0.040	ug/L		08/17/22 11:27	08/25/22 17:55	1
Malathion	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
Methoxychlor	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
Metolachlor	ND		0.050	ug/L		08/17/22 11:27	08/25/22 17:55	1
Metribuzin	ND		0.050	ug/L		08/17/22 11:27	08/25/22 17:55	1
Molinate	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
Naphthalene	ND		0.30	ug/L		08/17/22 11:27	08/25/22 17:55	1
Parathion	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
Pendimethalin (Penoxaline)	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
Total Permethrin (mixed isomers)	ND		0.20	ug/L		08/17/22 11:27	08/25/22 17:55	1
Phenanthrene	ND		0.040	ug/L		08/17/22 11:27	08/25/22 17:55	1
Propachlor	ND		0.050	ug/L		08/17/22 11:27	08/25/22 17:55	1
Pyrene	ND		0.050	ug/L		08/17/22 11:27	08/25/22 17:55	1
Simazine	ND		0.050	ug/L		08/17/22 11:27	08/25/22 17:55	1
Terbacil	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
Terbutylazine	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1
Thiobencarb	ND		0.20	ug/L		08/17/22 11:27	08/25/22 17:55	1
trans-Nonachlor	ND		0.050	ug/L		08/17/22 11:27	08/25/22 17:55	1
Trifluralin	ND		0.10	ug/L		08/17/22 11:27	08/25/22 17:55	1

Tentatively Identified Compound	Est. Result	Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Decane	1.5	T J N	ug/L		2.39	124-18-5	08/17/22 11:27	08/25/22 17:55	1
Tetradecanoic acid	0.68	T J N	ug/L		5.80	544-63-8	08/17/22 11:27	08/25/22 17:55	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2-Nitro-m-xylene	89		70 - 130	08/17/22 11:27	08/25/22 17:55	1
Triphenylphosphate	111		70 - 130	08/17/22 11:27	08/25/22 17:55	1
Perylene-d12	97		70 - 130	08/17/22 11:27	08/25/22 17:55	1

Method: 625 PAH Physis LL (EAL) + TICs - EPA 625 Base/Neutral and Acid Organics i

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/21/22 09:48	1
1-Methylphenanthrene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/21/22 09:48	1
2,3,5-Trimethylnaphthalene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/21/22 09:48	1
2,6-Dimethylnaphthalene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/21/22 09:48	1
2-Methylnaphthalene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/21/22 09:48	1
Acenaphthene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/21/22 09:48	1
Acenaphthylene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/21/22 09:48	1
Anthracene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/21/22 09:48	1
Benz[a]anthracene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/21/22 09:48	1
Benzo[a]pyrene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/21/22 09:48	1

Eurofins Eaton Monrovia

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-15847-1

Client Sample ID: MOANALUA WELLS

Lab Sample ID: 380-15847-1

Date Collected: 08/08/22 10:57

Matrix: Drinking Water

Date Received: 08/10/22 10:20

Method: 625 PAH Physis LL (EAL) + TICs - EPA 625 Base/Neutral and Acid Organics i (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzo[b]fluoranthene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/21/22 09:48	1
Benzo[e]pyrene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/21/22 09:48	1
Benzo[g,h,i]perylene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/21/22 09:48	1
Benzo[k]fluoranthene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/21/22 09:48	1
Biphenyl	ND		0.005	0.001	µg/L		08/15/22 00:00	08/21/22 09:48	1
Chrysene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/21/22 09:48	1
Dibenz[a,h]anthracene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/21/22 09:48	1
Dibenzo[a,i]pyrene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/21/22 09:48	1
Dibenzothiophene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/21/22 09:48	1
Disalicylidenepropanediamine	ND		0.1	0.05	µg/L		08/15/22 00:00	08/21/22 09:48	1
Fluoranthene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/21/22 09:48	1
Fluorene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/21/22 09:48	1
Indeno[1,2,3-cd]pyrene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/21/22 09:48	1
Naphthalene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/21/22 09:48	1
Perylene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/21/22 09:48	1
Phenanthrene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/21/22 09:48	1
Pyrene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/21/22 09:48	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
(d10-Acenaphthene)	82		45 - 118	08/15/22 00:00	08/21/22 09:48	1
(d10-Phenanthrene)	89		56 - 123	08/15/22 00:00	08/21/22 09:48	1
(d12-Chrysene)	86		36 - 142	08/15/22 00:00	08/21/22 09:48	1
(d12-Perylene)	76		36 - 161	08/15/22 00:00	08/21/22 09:48	1
(d8-Naphthalene)	79		20 - 112	08/15/22 00:00	08/21/22 09:48	1

Method: 8015 Diesel LL (EAL) and Motor Oil - 8015 - TPH DRO/ORO

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
DIESEL	ND	U	0.024		mg/L			08/15/22 18:07	1
MOTOR OIL	ND	U	0.048		mg/L			08/15/22 18:07	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
BROMOBENZENE	73		60 - 130		08/15/22 18:07	1
HEXACOSANE	92		60 - 130		08/15/22 18:07	1

Method: 8015 Gas (Purgeable) LL (EAL) - SW846 8015B Gasoline Range Organics

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
GASOLINE	ND	U	0.02		mg/L			08/12/22 14:24	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
BROMOFLUOROBENZENE	90		60 - 140		08/12/22 14:24	1

Client Sample ID: TB:MOANALUA WELLS

Lab Sample ID: 380-15847-2

Date Collected: 08/08/22 10:57

Matrix: Water

Date Received: 08/10/22 10:20

Method: 8015 Gas (Purgeable) LL (EAL) - SW846 8015B Gasoline Range Organics

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
GASOLINE	ND	U	0.02		mg/L			08/12/22 16:13	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
BROMOFLUOROBENZENE	90		60 - 140		08/12/22 16:13	1

Eurofins Eaton Monrovia

Action Limit Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-15847-1

Client Sample ID: MOANALUA WELLS

Lab Sample ID: 380-15847-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Alachlor	ND		ug/L	2	0.050	525.2	Total/NA
Atrazine	ND		ug/L	3	0.050	525.2	Total/NA
Benzo[a]pyrene	ND		ug/L	0.2	0.020	525.2	Total/NA
Di(2-ethylhexyl)adipate	ND		ug/L	400	0.60	525.2	Total/NA
Bis(2-ethylhexyl) phthalate	ND		ug/L	6	0.60	525.2	Total/NA
Endrin	ND		ug/L	2	0.10	525.2	Total/NA
Heptachlor	ND		ug/L	0.4	0.040	525.2	Total/NA
Heptachlor epoxide (isomer B)	ND		ug/L	0.2	0.050	525.2	Total/NA
Hexachlorobenzene	ND		ug/L	1	0.050	525.2	Total/NA
Hexachlorocyclopentadiene	ND		ug/L	50	0.050	525.2	Total/NA
Lindane	ND		ug/L	0.2	0.040	525.2	Total/NA
Methoxychlor	ND		ug/L	40	0.10	525.2	Total/NA
Simazine	ND		ug/L	4	0.050	525.2	Total/NA

Surrogate Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-15847-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		2NMX (70-130)	TPP (70-130)	PRY (70-130)
380-15847-1	MOANALUA WELLS	89	111	97

Surrogate Legend
 2NMX = 2-Nitro-m-xylene
 TPP = Triphenylphosphate
 PRY = Perylene-d12

Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		2NMX (70-130)	TPP (70-130)	PRY (70-130)
380-15819-O-1-A DU	Duplicate	90	116	93
380-16346-A-1-A MS	Matrix Spike	92	112	94
LCS 380-13642/3-A	Lab Control Sample	93	112	96
LCS 380-13642/4-A	Lab Control Sample Dup	92	109	96
MB 380-13642/1-A	Method Blank	91	113	94
MRL 380-13642/2-A	Lab Control Sample	92	108	92

Surrogate Legend
 2NMX = 2-Nitro-m-xylene
 TPP = Triphenylphosphate
 PRY = Perylene-d12

Method: 625 PAH Physis LL (EAL) + TICs - EPA 625 Base/Neutral and Acid Organics i

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)				
		Acenaphtl (45-118)	Phenanth (56-123)	CRY (36-142)	NPT (20-112)	PRY (36-161)
380-15847-1	MOANALUA WELLS	82	89	86	79	76

Surrogate Legend
 (d10-Acenaphthene) = (d10-Acenaphthene)
 (d10-Phenanthrene) = (d10-Phenanthrene)
 CRY = (d12-Chrysene)
 NPT = (d8-Naphthalene)
 PRY = (d12-Perylene)

Method: 625 PAH Physis LL (EAL) + TICs - EPA 625 Base/Neutral and Acid Organics i

Matrix: water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)				
		Acenaphtl (65-113)	Phenanth (80-111)	CRY (60-139)	NPT (44-119)	PRY (36-161)
99170-B1	Method Blank	92	93	92	88	88
99170-BS1	Lab Control Sample	87	91	84	81	86
99170-BS2	Lab Control Sample Dup	92	98	88	90	95

Surrogate Legend
 (d10-Acenaphthene) = (d10-Acenaphthene)
 (d10-Phenanthrene) = (d10-Phenanthrene)

Eurofins Eaton Monrovia

Surrogate Summary

Client: City & County of Honolulu

Job ID: 380-15847-1

Project/Site: RED-HILL

CRY = (d12-Chrysene)

NPT = (d8-Naphthalene)

PRY = (d12-Perylene)

Method: 8015 Diesel LL (EAL) and Motor Oil - 8015 - TPH DRO/ORO

Matrix: Drinking Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	BB (60-130)	XACOSAI (60-130)
380-15847-1	MOANALUA WELLS	73	92

Surrogate Legend

BB = BROMOBENZENE

HEXACOSANE = HEXACOSANE

Method: 8015 Diesel LL (EAL) and Motor Oil - 8015 - TPH DRO/ORO

Matrix: WATER

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	BB	XACOSAI
22DSH022WB	Method Blank		

Surrogate Legend

BB = BROMOBENZENE

HEXACOSANE = HEXACOSANE

Method: 8015 Diesel LL (EAL) and Motor Oil - 8015 - TPH DRO/ORO

Matrix: WATER

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	BB (60-130)	XACOSAI (60-130)
22DSH022WL	Lab Control Sample	82	100

Surrogate Legend

BB = BROMOBENZENE

HEXACOSANE = HEXACOSANE

Method: 8015 Gas (Purgeable) LL (EAL) - SW846 8015B Gasoline Range Organics

Matrix: Drinking Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	BFB (60-140)
380-15847-1	MOANALUA WELLS	90

Surrogate Legend

BFB = BROMOFLUOROBENZENE

Method: 8015 Gas (Purgeable) LL (EAL) - SW846 8015B Gasoline Range Organics

Matrix: WATER

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	BFB
22VG39H05B	Method Blank	

Surrogate Legend

BFB = BROMOFLUOROBENZENE

Eurofins Eaton Monrovia

Surrogate Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-15847-1

Method: 8015 Gas (Purgeable) LL (EAL) - SW846 8015B Gasoline Range Organics

Matrix: WATER

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	BFB (70-130)
22VG39H05C	LCD	109
22VG39H05L	Lab Control Sample	109

Surrogate Legend

BFB = BROMOFLUOROBENZENE

Method: 8015 Gas (Purgeable) LL (EAL) - SW846 8015B Gasoline Range Organics

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	BFB (60-140)
380-15847-2	TB:MOANALUA WELLS	90

Surrogate Legend

BFB = BROMOFLUOROBENZENE

Method: 8015 Gas (Purgeable) LL (EAL) - SW846 8015B Gasoline Range Organics

Matrix: WATER

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	BFB (60-140)
22H144-01M	Matrix Spike	113
22H144-01S	Matrix Spike Duplicate	113

Surrogate Legend

BFB = BROMOFLUOROBENZENE

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-15847-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Lab Sample ID: MB 380-13642/1-A
Matrix: Water
Analysis Batch: 14896

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 13642

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
2,4'-DDD	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
2,4'-DDE	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
2,4'-DDT	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
2,4-Dinitrotoluene	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
2,6-Dinitrotoluene	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
4,4'-DDD	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
4,4'-DDE	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
4,4'-DDT	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
Acenaphthene	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
Acenaphthylene	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
Acetochlor	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
Alachlor	ND		0.050	ug/L		08/17/22 11:27	08/25/22 12:26	1
alpha-BHC	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
alpha-Chlordane	ND		0.050	ug/L		08/17/22 11:27	08/25/22 12:26	1
Anthracene	ND		0.020	ug/L		08/17/22 11:27	08/25/22 12:26	1
Atrazine	ND		0.050	ug/L		08/17/22 11:27	08/25/22 12:26	1
Benz(a)anthracene	ND		0.050	ug/L		08/17/22 11:27	08/25/22 12:26	1
Benzo[a]pyrene	ND		0.020	ug/L		08/17/22 11:27	08/25/22 12:26	1
Benzo[b]fluoranthene	ND		0.020	ug/L		08/17/22 11:27	08/25/22 12:26	1
Benzo[g,h,i]perylene	ND		0.050	ug/L		08/17/22 11:27	08/25/22 12:26	1
Benzo[k]fluoranthene	ND		0.020	ug/L		08/17/22 11:27	08/25/22 12:26	1
beta-BHC	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
Bromacil	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
Butachlor	ND		0.050	ug/L		08/17/22 11:27	08/25/22 12:26	1
Butylbenzylphthalate	ND		0.50	ug/L		08/17/22 11:27	08/25/22 12:26	1
Caffeine	ND		0.050	ug/L		08/17/22 11:27	08/25/22 12:26	1
Chlorobenzilate	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
Chloroneb	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
Chlorothalonil (Draconil, Bravo)	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
Chlorpyrifos	ND		0.050	ug/L		08/17/22 11:27	08/25/22 12:26	1
Chrysene	ND		0.020	ug/L		08/17/22 11:27	08/25/22 12:26	1
delta-BHC	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
Di(2-ethylhexyl)adipate	ND		0.60	ug/L		08/17/22 11:27	08/25/22 12:26	1
Bis(2-ethylhexyl) phthalate	ND		0.60	ug/L		08/17/22 11:27	08/25/22 12:26	1
Diazinon (Qualitative)	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
Dibenz(a,h)anthracene	ND		0.050	ug/L		08/17/22 11:27	08/25/22 12:26	1
Diclorvos (DDVP)	ND		0.050	ug/L		08/17/22 11:27	08/25/22 12:26	1
Dieldrin	ND		0.20	ug/L		08/17/22 11:27	08/25/22 12:26	1
Diethylphthalate	ND		0.50	ug/L		08/17/22 11:27	08/25/22 12:26	1
Dimethoate	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
Dimethylphthalate	ND		0.50	ug/L		08/17/22 11:27	08/25/22 12:26	1
Di-n-butyl phthalate	ND		1.0	ug/L		08/17/22 11:27	08/25/22 12:26	1
Di-n-octyl phthalate	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
Endosulfan I (Alpha)	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
Endosulfan II (Beta)	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
Endosulfan sulfate	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
Endrin	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
Endrin aldehyde	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1

Eurofins Eaton Monrovia

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-15847-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 380-13642/1-A
Matrix: Water
Analysis Batch: 14896

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 13642

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
EPTC	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
Fluoranthene	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
Fluorene	ND		0.050	ug/L		08/17/22 11:27	08/25/22 12:26	1
gamma-Chlordane	ND		0.050	ug/L		08/17/22 11:27	08/25/22 12:26	1
Heptachlor	ND		0.040	ug/L		08/17/22 11:27	08/25/22 12:26	1
Heptachlor epoxide (isomer B)	ND		0.050	ug/L		08/17/22 11:27	08/25/22 12:26	1
Hexachlorobenzene	ND		0.050	ug/L		08/17/22 11:27	08/25/22 12:26	1
Hexachlorocyclopentadiene	ND		0.050	ug/L		08/17/22 11:27	08/25/22 12:26	1
Indeno[1,2,3-cd]pyrene	ND		0.050	ug/L		08/17/22 11:27	08/25/22 12:26	1
Isophorone	ND		0.50	ug/L		08/17/22 11:27	08/25/22 12:26	1
Lindane	ND		0.040	ug/L		08/17/22 11:27	08/25/22 12:26	1
Malathion	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
Methoxychlor	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
Metolachlor	ND		0.050	ug/L		08/17/22 11:27	08/25/22 12:26	1
Metribuzin	ND		0.050	ug/L		08/17/22 11:27	08/25/22 12:26	1
Molinate	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
Naphthalene	ND		0.30	ug/L		08/17/22 11:27	08/25/22 12:26	1
Parathion	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
Pendimethalin (Penoxaline)	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
Total Permethrin (mixed isomers)	ND		0.20	ug/L		08/17/22 11:27	08/25/22 12:26	1
Phenanthrene	ND		0.040	ug/L		08/17/22 11:27	08/25/22 12:26	1
Propachlor	ND		0.050	ug/L		08/17/22 11:27	08/25/22 12:26	1
Pyrene	ND		0.050	ug/L		08/17/22 11:27	08/25/22 12:26	1
Simazine	ND		0.050	ug/L		08/17/22 11:27	08/25/22 12:26	1
Terbacil	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
Terbutylazine	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1
Thiobencarb	ND		0.20	ug/L		08/17/22 11:27	08/25/22 12:26	1
trans-Nonachlor	ND		0.050	ug/L		08/17/22 11:27	08/25/22 12:26	1
Trifluralin	ND		0.10	ug/L		08/17/22 11:27	08/25/22 12:26	1

<i>Tentatively Identified Compound</i>	MB Est. Result	MB Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
<i>Tentatively Identified Compound</i>	None		ug/L				08/17/22 11:27	08/25/22 12:26	1

<i>Surrogate</i>	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
<i>2-Nitro-m-xylene</i>	91		70 - 130	08/17/22 11:27	08/25/22 12:26	1
<i>Triphenylphosphate</i>	113		70 - 130	08/17/22 11:27	08/25/22 12:26	1
<i>Perylene-d12</i>	94		70 - 130	08/17/22 11:27	08/25/22 12:26	1

Lab Sample ID: LCS 380-13642/3-A
Matrix: Water
Analysis Batch: 14896

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 13642

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
2,4'-DDD	1.98	2.19		ug/L		110	70 - 130
2,4'-DDE	1.98	2.14		ug/L		108	70 - 130
2,4'-DDT	1.98	2.50		ug/L		126	70 - 130
2,4-Dinitrotoluene	1.98	2.37		ug/L		120	70 - 130
2,6-Dinitrotoluene	1.98	2.29		ug/L		115	70 - 130

Eurofins Eaton Monrovia

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-15847-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 380-13642/3-A

Matrix: Water

Analysis Batch: 14896

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 13642

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
4,4'-DDD	1.98	2.32		ug/L		117	70 - 130
4,4'-DDE	1.98	2.11		ug/L		106	70 - 130
4,4'-DDT	1.98	2.27		ug/L		115	70 - 130
Acenaphthene	1.98	1.98		ug/L		100	70 - 130
Acenaphthylene	1.98	1.98		ug/L		100	70 - 130
Acetochlor	1.98	2.40		ug/L		121	70 - 130
Alachlor	1.98	2.23		ug/L		112	70 - 130
alpha-BHC	1.98	2.11		ug/L		106	70 - 130
alpha-Chlordane	1.98	2.12		ug/L		107	70 - 130
Anthracene	1.98	2.11		ug/L		106	70 - 130
Atrazine	1.98	2.31		ug/L		117	70 - 130
Benz(a)anthracene	1.98	2.27		ug/L		114	70 - 130
Benzo[a]pyrene	1.98	2.18		ug/L		110	70 - 130
Benzo[b]fluoranthene	1.98	2.32		ug/L		117	70 - 130
Benzo[g,h,i]perylene	1.98	2.18		ug/L		110	70 - 130
Benzo[k]fluoranthene	1.98	2.24		ug/L		113	70 - 130
beta-BHC	1.98	2.16		ug/L		109	70 - 130
Bromacil	1.98	2.79	*+	ug/L		141	70 - 130
Butachlor	1.98	2.59	*+	ug/L		131	70 - 130
Butylbenzylphthalate	1.98	2.47		ug/L		125	70 - 130
Caffeine	1.98	1.70		ug/L		86	45 - 137
Chlorobenzilate	1.98	2.76	*+	ug/L		139	70 - 130
Chloroneb	1.98	2.11		ug/L		106	70 - 130
Chlorothalonil (Draconil, Bravo)	1.98	2.34		ug/L		118	70 - 130
Chlorpyrifos	1.98	2.32		ug/L		117	70 - 130
Chrysene	1.98	2.15		ug/L		109	70 - 130
delta-BHC	1.98	2.20		ug/L		111	70 - 130
Di(2-ethylhexyl)adipate	1.98	2.52		ug/L		127	70 - 130
Bis(2-ethylhexyl) phthalate	1.98	2.07		ug/L		105	70 - 130
Diazinon (Qualitative)	1.98	1.91		ug/L		96	15 - 132
Dibenz(a,h)anthracene	1.98	2.21		ug/L		111	70 - 130
Diclorvos (DDVP)	1.98	2.19		ug/L		111	70 - 130
Dieldrin	1.98	2.15		ug/L		108	70 - 130
Diethylphthalate	1.98	2.17		ug/L		109	70 - 130
Dimethoate	1.98	1.70		ug/L		86	35 - 100
Dimethylphthalate	1.98	2.20		ug/L		111	70 - 130
Di-n-butyl phthalate	3.97	4.22		ug/L		106	70 - 130
Di-n-octyl phthalate	1.98	1.74		ug/L		88	70 - 130
Endosulfan I (Alpha)	1.98	2.18		ug/L		110	70 - 130
Endosulfan II (Beta)	1.98	2.20		ug/L		111	70 - 130
Endosulfan sulfate	1.98	2.44		ug/L		123	70 - 130
Endrin	1.98	2.38		ug/L		120	70 - 130
Endrin aldehyde	1.98	2.09		ug/L		106	70 - 130
EPTC	1.98	2.17		ug/L		110	70 - 130
Fluoranthene	1.98	2.24		ug/L		113	70 - 130
Fluorene	1.98	2.15		ug/L		108	70 - 130
gamma-Chlordane	1.98	2.13		ug/L		107	70 - 130
Heptachlor	1.98	2.23		ug/L		112	70 - 130
Heptachlor epoxide (isomer B)	1.98	2.20		ug/L		111	70 - 130

Eurofins Eaton Monrovia

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-15847-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 380-13642/3-A
Matrix: Water
Analysis Batch: 14896

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 13642

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Hexachlorobenzene	1.98	1.97		ug/L		99	70 - 130
Hexachlorocyclopentadiene	1.98	2.14		ug/L		108	70 - 130
Indeno[1,2,3-cd]pyrene	1.98	2.19		ug/L		110	70 - 130
Isophorone	1.98	1.89		ug/L		95	70 - 130
Lindane	1.98	2.18		ug/L		110	70 - 130
Malathion	1.98	2.58		ug/L		130	70 - 130
Methoxychlor	1.98	2.50		ug/L		126	70 - 130
Metolachlor	1.98	2.38		ug/L		120	70 - 130
Metribuzin	1.98	2.39		ug/L		120	70 - 130
Molinate	1.98	2.14		ug/L		108	70 - 130
Naphthalene	1.98	1.76		ug/L		88	70 - 130
Parathion	1.98	2.33		ug/L		117	70 - 130
Pendimethalin (Penoxaline)	1.98	2.38		ug/L		120	70 - 130
Phenanthrene	1.98	2.07		ug/L		105	70 - 130
Propachlor	1.98	2.25		ug/L		113	70 - 130
Pyrene	1.98	2.26		ug/L		114	70 - 130
Simazine	1.98	2.32		ug/L		117	70 - 130
Terbacil	1.98	2.39		ug/L		121	70 - 130
Terbutylazine	1.98	2.29		ug/L		115	70 - 130
Thiobencarb	1.98	2.06		ug/L		104	70 - 130
trans-Nonachlor	1.98	2.19		ug/L		111	70 - 130
Trifluralin	1.98	2.38		ug/L		120	70 - 130

Surrogate	LCS %Recovery	LCS Qualifier	Limits
2-Nitro-m-xylene	93		70 - 130
Triphenylphosphate	112		70 - 130
Perylene-d12	96		70 - 130

Lab Sample ID: LCSD 380-13642/4-A
Matrix: Water
Analysis Batch: 14896

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: 13642

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
2,4'-DDD	1.99	2.18		ug/L		110	70 - 130	0	20
2,4'-DDE	1.99	2.13		ug/L		107	70 - 130	0	20
2,4'-DDT	1.99	2.45		ug/L		123	70 - 130	2	20
2,4-Dinitrotoluene	1.99	2.32		ug/L		116	70 - 130	2	20
2,6-Dinitrotoluene	1.99	2.27		ug/L		114	70 - 130	1	20
4,4'-DDD	1.99	2.27		ug/L		114	70 - 130	2	20
4,4'-DDE	1.99	2.14		ug/L		107	70 - 130	1	20
4,4'-DDT	1.99	2.24		ug/L		112	70 - 130	2	20
Acenaphthene	1.99	2.00		ug/L		100	70 - 130	1	20
Acenaphthylene	1.99	2.03		ug/L		102	70 - 130	2	20
Acetochlor	1.99	2.36		ug/L		119	70 - 130	2	20
Alachlor	1.99	2.24		ug/L		112	70 - 130	0	20
alpha-BHC	1.99	2.09		ug/L		105	70 - 130	1	20
alpha-Chlordane	1.99	2.13		ug/L		107	70 - 130	0	20
Anthracene	1.99	2.13		ug/L		107	70 - 130	1	20

Eurofins Eaton Monrovia

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-15847-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCSD 380-13642/4-A
Matrix: Water
Analysis Batch: 14896

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: 13642

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD
									Limit
Atrazine	1.99	2.23		ug/L		112	70 - 130	4	20
Benz(a)anthracene	1.99	2.22		ug/L		112	70 - 130	2	20
Benzo[a]pyrene	1.99	2.15		ug/L		108	70 - 130	1	20
Benzo[b]fluoranthene	1.99	2.24		ug/L		113	70 - 130	3	20
Benzo[g,h,i]perylene	1.99	2.15		ug/L		108	70 - 130	1	20
Benzo[k]fluoranthene	1.99	2.25		ug/L		113	70 - 130	1	20
beta-BHC	1.99	2.12		ug/L		106	70 - 130	2	20
Bromacil	1.99	2.70	*+	ug/L		136	70 - 130	3	20
Butachlor	1.99	2.50		ug/L		126	70 - 130	3	20
Butylbenzylphthalate	1.99	2.43		ug/L		122	70 - 130	2	20
Caffeine	1.99	1.74		ug/L		87	45 - 137	2	20
Chlorobenzilate	1.99	2.64	*+	ug/L		132	70 - 130	4	20
Chloroneb	1.99	2.08		ug/L		105	70 - 130	1	20
Chlorothalonil (Draconil, Bravo)	1.99	2.29		ug/L		115	70 - 130	2	20
Chlorpyrifos	1.99	2.31		ug/L		116	70 - 130	0	20
Chrysene	1.99	2.19		ug/L		110	70 - 130	2	20
delta-BHC	1.99	2.10		ug/L		105	70 - 130	4	20
Di(2-ethylhexyl)adipate	1.99	2.39		ug/L		120	70 - 130	5	20
Bis(2-ethylhexyl) phthalate	1.99	1.98		ug/L		99	70 - 130	5	20
Diazinon (Qualitative)	1.99	1.85		ug/L		93	15 - 132	3	20
Dibenz(a,h)anthracene	1.99	2.20		ug/L		110	70 - 130	0	20
Diclorvos (DDVP)	1.99	2.13		ug/L		107	70 - 130	3	20
Dieldrin	1.99	2.19		ug/L		110	70 - 130	2	20
Diethylphthalate	1.99	2.09		ug/L		105	70 - 130	4	20
Dimethoate	1.99	1.73		ug/L		87	35 - 100	1	20
Dimethylphthalate	1.99	2.16		ug/L		109	70 - 130	2	20
Di-n-butyl phthalate	3.99	4.22		ug/L		106	70 - 130	0	20
Di-n-octyl phthalate	1.99	1.69		ug/L		85	70 - 130	3	20
Endosulfan I (Alpha)	1.99	2.15		ug/L		108	70 - 130	2	20
Endosulfan II (Beta)	1.99	2.22		ug/L		111	70 - 130	1	20
Endosulfan sulfate	1.99	2.43		ug/L		122	70 - 130	1	20
Endrin	1.99	2.49		ug/L		125	70 - 130	5	20
Endrin aldehyde	1.99	2.13		ug/L		107	70 - 130	2	20
EPTC	1.99	2.12		ug/L		106	70 - 130	3	20
Fluoranthene	1.99	2.22		ug/L		111	70 - 130	1	20
Fluorene	1.99	2.12		ug/L		106	70 - 130	1	20
gamma-Chlordane	1.99	2.09		ug/L		105	70 - 130	2	20
Heptachlor	1.99	2.25		ug/L		113	70 - 130	1	20
Heptachlor epoxide (isomer B)	1.99	2.20		ug/L		110	70 - 130	0	20
Hexachlorobenzene	1.99	1.97		ug/L		99	70 - 130	0	20
Hexachlorocyclopentadiene	1.99	2.19		ug/L		110	70 - 130	2	20
Indeno[1,2,3-cd]pyrene	1.99	2.17		ug/L		109	70 - 130	1	20
Isophorone	1.99	1.86		ug/L		93	70 - 130	1	20
Lindane	1.99	2.11		ug/L		106	70 - 130	3	20
Malathion	1.99	2.53		ug/L		127	70 - 130	2	20
Methoxychlor	1.99	2.42		ug/L		121	70 - 130	3	20
Metolachlor	1.99	2.33		ug/L		117	70 - 130	2	20
Metribuzin	1.99	2.39		ug/L		120	70 - 130	0	20
Molinate	1.99	2.09		ug/L		105	70 - 130	2	20

Eurofins Eaton Monrovia

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-15847-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCSD 380-13642/4-A
Matrix: Water
Analysis Batch: 14896

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: 13642

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Naphthalene	1.99	1.80		ug/L		90	70 - 130	2	20
Parathion	1.99	2.28		ug/L		115	70 - 130	2	20
Pendimethalin (Penoxaline)	1.99	2.37		ug/L		119	70 - 130	0	20
Phenanthrene	1.99	2.07		ug/L		104	70 - 130	0	20
Propachlor	1.99	2.17		ug/L		109	70 - 130	3	20
Pyrene	1.99	2.23		ug/L		112	70 - 130	1	20
Simazine	1.99	2.24		ug/L		112	70 - 130	4	20
Terbacil	1.99	2.44		ug/L		123	70 - 130	2	20
Terbutylazine	1.99	2.20		ug/L		110	70 - 130	4	20
Thiobencarb	1.99	2.04		ug/L		102	70 - 130	1	20
trans-Nonachlor	1.99	2.18		ug/L		110	70 - 130	0	20
Trifluralin	1.99	2.33		ug/L		117	70 - 130	2	20

Surrogate	LCSD %Recovery	LCSD Qualifier	LCSD Limits
2-Nitro-m-xylene	92		70 - 130
Triphenylphosphate	109		70 - 130
Perylene-d12	96		70 - 130

Lab Sample ID: MRL 380-13642/2-A
Matrix: Water
Analysis Batch: 14896

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 13642

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
2,4'-DDD	0.0999	0.141		ug/L		141	50 - 150
2,4'-DDE	0.0999	0.110		ug/L		110	50 - 150
2,4'-DDT	0.0999	0.0995	J	ug/L		100	50 - 150
2,4-Dinitrotoluene	0.0999	0.135		ug/L		135	50 - 150
2,6-Dinitrotoluene	0.0999	0.0968	J	ug/L		97	50 - 150
4,4'-DDD	0.0999	0.107		ug/L		108	50 - 150
4,4'-DDE	0.0999	0.104		ug/L		104	50 - 150
4,4'-DDT	0.0999	0.136		ug/L		136	50 - 150
Acenaphthene	0.0999	0.0979	J	ug/L		98	50 - 150
Acenaphthylene	0.0999	0.0742	J	ug/L		74	50 - 150
Acetochlor	0.0500	0.0550	J	ug/L		110	50 - 150
Alachlor	0.0500	0.0625		ug/L		125	50 - 150
alpha-BHC	0.0999	0.102		ug/L		102	50 - 150
alpha-Chlordane	0.0500	0.0557		ug/L		112	50 - 150
Anthracene	0.0200	0.0199	J	ug/L		99	50 - 150
Atrazine	0.0500	0.0664		ug/L		133	50 - 150
Benz(a)anthracene	0.0500	0.0539		ug/L		108	50 - 150
Benzo[a]pyrene	0.0200	0.0204		ug/L		102	50 - 150
Benzo[b]fluoranthene	0.0200	0.0221		ug/L		111	50 - 150
Benzo[g,h,i]perylene	0.0500	0.0491	J	ug/L		98	50 - 150
Benzo[k]fluoranthene	0.0200	0.0217		ug/L		109	50 - 150
beta-BHC	0.0999	0.103		ug/L		103	50 - 150
Bromacil	0.0999	0.118		ug/L		118	50 - 150
Butachlor	0.0500	0.0621		ug/L		124	50 - 150
Butylbenzylphthalate	0.150	0.327	J ^3+	ug/L		218	50 - 150

Eurofins Eaton Monrovia

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-15847-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MRL 380-13642/2-A
Matrix: Water
Analysis Batch: 14896

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 13642

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Caffeine	0.0500	0.0286	J	ug/L		57	50 - 150
Chlorobenzilate	0.0999	0.127		ug/L		128	50 - 150
Chloroneb	0.0999	0.101		ug/L		101	50 - 150
Chlorothalonil (Draconil, Bravo)	0.0999	0.0986	J	ug/L		99	50 - 150
Chlorpyrifos	0.0500	0.0490	J	ug/L		98	50 - 150
Chrysene	0.0200	0.0226		ug/L		113	50 - 150
delta-BHC	0.0999	0.120		ug/L		120	50 - 150
Di(2-ethylhexyl)adipate	0.300	0.377	J	ug/L		126	50 - 150
Bis(2-ethylhexyl) phthalate	0.599	0.734		ug/L		122	50 - 150
Diazinon (Qualitative)	0.0999	0.0822	J	ug/L		82	15 - 132
Dibenz(a,h)anthracene	0.0500	0.0531		ug/L		106	50 - 150
Diclorvos (DDVP)	0.0500	0.0455	J	ug/L		91	50 - 150
Dieldrin	0.0999	0.113	J	ug/L		113	50 - 150
Diethylphthalate	0.150	0.170	J	ug/L		114	50 - 150
Dimethoate	0.0999	0.0546	J	ug/L		55	35 - 100
Dimethylphthalate	0.300	0.311	J	ug/L		104	50 - 150
Di-n-butyl phthalate	0.300	0.347	J	ug/L		116	49 - 243
Di-n-octyl phthalate	0.0999	0.121		ug/L		121	50 - 150
Endosulfan I (Alpha)	0.0999	0.103		ug/L		103	50 - 150
Endosulfan II (Beta)	0.0999	0.115		ug/L		115	50 - 150
Endosulfan sulfate	0.0999	0.104		ug/L		104	50 - 150
Endrin	0.0999	0.136		ug/L		136	50 - 150
Endrin aldehyde	0.0999	0.0916	J	ug/L		92	50 - 150
EPTC	0.0999	0.0978	J	ug/L		98	50 - 150
Fluoranthene	0.0500	0.0517	J	ug/L		103	50 - 150
Fluorene	0.0500	0.0522		ug/L		104	50 - 150
gamma-Chlordane	0.0500	0.0510		ug/L		102	50 - 150
Heptachlor	0.0400	0.0531		ug/L		133	50 - 150
Heptachlor epoxide (isomer B)	0.0500	0.0524		ug/L		105	50 - 150
Hexachlorobenzene	0.0500	0.0622		ug/L		125	50 - 150
Hexachlorocyclopentadiene	0.0500	0.0480	J	ug/L		96	50 - 150
Indeno[1,2,3-cd]pyrene	0.0500	0.0448	J	ug/L		90	50 - 150
Isophorone	0.0999	0.0849	J	ug/L		85	50 - 150
Lindane	0.0500	0.0469		ug/L		94	50 - 150
Malathion	0.0999	0.106		ug/L		106	50 - 150
Methoxychlor	0.0999	0.146		ug/L		146	50 - 150
Metolachlor	0.0500	0.0624		ug/L		125	50 - 150
Metribuzin	0.0500	0.0414	J	ug/L		83	50 - 150
Molinate	0.0999	0.103		ug/L		103	50 - 150
Naphthalene	0.0999	0.0901	J	ug/L		90	50 - 150
Parathion	0.0999	0.144		ug/L		144	50 - 150
Pendimethalin (Penoxaline)	0.0999	0.133		ug/L		133	50 - 150
Phenanthrene	0.0200	0.0231	J	ug/L		116	50 - 150
Propachlor	0.0500	0.0533		ug/L		107	50 - 150
Pyrene	0.0500	0.0540		ug/L		108	50 - 150
Simazine	0.0500	0.0483	J	ug/L		97	50 - 150
Terbacil	0.0999	0.118		ug/L		118	50 - 150
Terbutylazine	0.0999	0.0985	J	ug/L		99	50 - 150
Thiobencarb	0.0999	0.113	J	ug/L		113	50 - 150

Eurofins Eaton Monrovia

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-15847-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MRL 380-13642/2-A
Matrix: Water
Analysis Batch: 14896

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 13642

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
trans-Nonachlor	0.0500	0.0529		ug/L		106	50 - 150
Trifluralin	0.0999	0.0984	J	ug/L		98	50 - 150

Surrogate	MRL %Recovery	MRL Qualifier	Limits
2-Nitro-m-xylene	92		70 - 130
Triphenylphosphate	108		70 - 130
Perylene-d12	92		70 - 130

Lab Sample ID: 380-16346-A-1-A MS
Matrix: Water
Analysis Batch: 14896

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 13642

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
2,4'-DDD	ND		1.99	2.21		ug/L		111	70 - 130
2,4'-DDE	ND		1.99	2.13		ug/L		107	70 - 130
2,4'-DDT	ND		1.99	2.49		ug/L		125	70 - 130
2,4-Dinitrotoluene	ND		1.99	2.43		ug/L		122	70 - 130
2,6-Dinitrotoluene	ND		1.99	2.37		ug/L		119	70 - 130
4,4'-DDD	ND		1.99	2.28		ug/L		115	70 - 130
4,4'-DDE	ND		1.99	2.13		ug/L		107	70 - 130
4,4'-DDT	ND		1.99	2.28		ug/L		114	70 - 130
Acenaphthene	ND		1.99	1.97		ug/L		99	70 - 130
Acenaphthylene	ND		1.99	2.05		ug/L		103	70 - 130
Acetochlor	ND		1.99	2.38		ug/L		120	70 - 130
Alachlor	ND		1.99	2.24		ug/L		112	70 - 130
alpha-BHC	ND		1.99	2.10		ug/L		106	70 - 130
alpha-Chlordane	ND		1.99	2.16		ug/L		108	70 - 130
Anthracene	ND	F1	1.99	1.03	F1	ug/L		51	70 - 130
Atrazine	ND		1.99	2.28		ug/L		114	70 - 130
Benz(a)anthracene	ND		1.99	1.95		ug/L		98	70 - 130
Benzo[a]pyrene	ND		1.99	1.54		ug/L		78	70 - 130
Benzo[b]fluoranthene	ND		1.99	2.27		ug/L		114	70 - 130
Benzo[g,h,i]perylene	ND		1.99	2.18		ug/L		110	70 - 130
Benzo[k]fluoranthene	ND		1.99	2.28		ug/L		115	70 - 130
beta-BHC	ND		1.99	2.17		ug/L		109	70 - 130
Bromacil	ND	*+ F1	1.99	2.73	F1	ug/L		137	70 - 130
Butachlor	ND	*+	1.99	2.50		ug/L		126	70 - 130
Butylbenzylphthalate	ND	^3+	1.99	2.54		ug/L		128	70 - 130
Caffeine	ND		1.99	1.88		ug/L		94	46 - 144
Chlorobenzilate	ND	*+ F1	1.99	2.68	F1	ug/L		135	70 - 130
Chloroneb	ND		1.99	2.12		ug/L		106	70 - 130
Chlorothalonil (Draconil, Bravo)	ND		1.99	2.34		ug/L		118	70 - 130
Chlorpyrifos	ND		1.99	2.32		ug/L		117	70 - 130
Chrysene	ND		1.99	2.16		ug/L		109	70 - 130
delta-BHC	ND		1.99	2.14		ug/L		107	70 - 130
Di(2-ethylhexyl)adipate	ND		1.99	2.48		ug/L		124	70 - 130
Bis(2-ethylhexyl) phthalate	ND		1.99	2.11		ug/L		106	70 - 130
Diazinon (Qualitative)	ND		1.99	1.89		ug/L		95	15 - 132

Eurofins Eaton Monrovia

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-15847-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-16346-A-1-A MS
Matrix: Water
Analysis Batch: 14896

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 13642

Analyte	Sample	Sample	Spike	MS	MS	Unit	D	%Rec	%Rec Limits
	Result	Qualifier	Added	Result	Qualifier				
Dibenz(a,h)anthracene	ND		1.99	2.30		ug/L		115	70 - 130
Diclorvos (DDVP)	ND		1.99	2.14		ug/L		108	70 - 130
Dieldrin	ND		1.99	2.16		ug/L		108	70 - 130
Diethylphthalate	ND		1.99	2.15		ug/L		108	70 - 130
Dimethoate	ND		1.99	1.88		ug/L		94	34 - 111
Dimethylphthalate	ND		1.99	2.19		ug/L		110	70 - 130
Di-n-butyl phthalate	ND		3.98	4.21		ug/L		106	70 - 130
Di-n-octyl phthalate	ND		1.99	1.98		ug/L		100	70 - 130
Endosulfan I (Alpha)	ND		1.99	2.19		ug/L		110	70 - 130
Endosulfan II (Beta)	ND		1.99	2.18		ug/L		109	70 - 130
Endosulfan sulfate	ND		1.99	2.46		ug/L		123	70 - 130
Endrin	ND		1.99	2.55		ug/L		128	70 - 130
Endrin aldehyde	ND		1.99	2.09		ug/L		105	70 - 130
EPTC	ND		1.99	2.12		ug/L		107	70 - 130
Fluoranthene	ND		1.99	2.19		ug/L		110	70 - 130
Fluorene	ND		1.99	2.14		ug/L		107	70 - 130
gamma-Chlordane	ND		1.99	2.11		ug/L		106	70 - 130
Heptachlor	ND		1.99	2.20		ug/L		111	70 - 130
Heptachlor epoxide (isomer B)	ND		1.99	2.16		ug/L		109	70 - 130
Hexachlorobenzene	ND		1.99	1.96		ug/L		98	70 - 130
Hexachlorocyclopentadiene	ND		1.99	2.15		ug/L		108	70 - 130
Indeno[1,2,3-cd]pyrene	ND		1.99	2.25		ug/L		113	70 - 130
Isophorone	ND		1.99	1.92		ug/L		96	70 - 130
Lindane	ND		1.99	2.16		ug/L		108	70 - 130
Malathion	ND		1.99	2.57		ug/L		129	70 - 130
Methoxychlor	ND		1.99	2.47		ug/L		124	70 - 130
Metolachlor	ND		1.99	2.38		ug/L		119	70 - 130
Metribuzin	ND		1.99	2.14		ug/L		107	70 - 130
Molinate	ND		1.99	2.12		ug/L		107	70 - 130
Naphthalene	ND		1.99	1.79		ug/L		90	70 - 130
Parathion	ND		1.99	2.31		ug/L		116	70 - 130
Pendimethalin (Penoxaline)	ND		1.99	2.38		ug/L		120	70 - 130
Phenanthrene	ND		1.99	2.06		ug/L		104	70 - 130
Propachlor	ND		1.99	2.21		ug/L		111	70 - 130
Pyrene	ND		1.99	2.19		ug/L		110	70 - 130
Simazine	ND		1.99	2.29		ug/L		115	70 - 130
Terbacil	ND		1.99	2.43		ug/L		122	70 - 130
Terbutylazine	ND		1.99	2.23		ug/L		112	70 - 130
Thiobencarb	ND		1.99	2.02		ug/L		101	70 - 130
trans-Nonachlor	ND		1.99	2.19		ug/L		110	70 - 130
Trifluralin	ND		1.99	2.35		ug/L		118	70 - 130
		MS	MS						
Surrogate		%Recovery	Qualifier	Limits					
2-Nitro-m-xylene		92		70 - 130					
Triphenylphosphate		112		70 - 130					
Perylene-d12		94		70 - 130					

QC Sample Results

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-15847-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-15819-O-1-A DU
Matrix: Water
Analysis Batch: 14896

Client Sample ID: Duplicate
Prep Type: Total/NA
Prep Batch: 13642

Analyte	Sample	Sample	DU	DU	Unit	D	RPD	Limit
	Result	Qualifier	Result	Qualifier				
2,4'-DDD	ND		ND		ug/L		NC	20
2,4'-DDE	ND		ND		ug/L		NC	20
2,4'-DDT	ND		ND		ug/L		NC	20
2,4-Dinitrotoluene	ND		ND		ug/L		NC	20
2,6-Dinitrotoluene	ND		ND		ug/L		NC	20
4,4'-DDD	ND		ND		ug/L		NC	20
4,4'-DDE	ND		ND		ug/L		NC	20
4,4'-DDT	ND		ND		ug/L		NC	20
Acenaphthene	ND		ND		ug/L		NC	20
Acenaphthylene	ND		ND		ug/L		NC	20
Acetochlor	ND		ND		ug/L		NC	20
Alachlor	ND		ND		ug/L		NC	20
alpha-BHC	ND		ND		ug/L		NC	20
alpha-Chlordane	ND		ND		ug/L		NC	20
Anthracene	ND		ND		ug/L		NC	20
Atrazine	ND		ND		ug/L		NC	20
Benz(a)anthracene	ND		ND		ug/L		NC	20
Benzo[a]pyrene	ND		ND		ug/L		NC	20
Benzo[b]fluoranthene	ND		ND		ug/L		NC	20
Benzo[g,h,i]perylene	ND		ND		ug/L		NC	20
Benzo[k]fluoranthene	ND		ND		ug/L		NC	20
beta-BHC	ND		ND		ug/L		NC	20
Bromacil	ND	*+	ND	*+	ug/L		NC	20
Butachlor	ND	*+	ND	*+	ug/L		NC	20
Butylbenzylphthalate	ND	^3+	ND		ug/L		NC	20
Caffeine	ND		ND		ug/L		NC	20
Chlorobenzilate	ND	*+	ND	*+	ug/L		NC	20
Chloroneb	ND		ND		ug/L		NC	20
Chlorothalonil (Draconil, Bravo)	ND		ND		ug/L		NC	20
Chlorpyrifos	ND		ND		ug/L		NC	20
Chrysene	ND		ND		ug/L		NC	20
delta-BHC	ND		ND		ug/L		NC	20
Di(2-ethylhexyl)adipate	ND		ND		ug/L		NC	20
Bis(2-ethylhexyl) phthalate	ND		ND		ug/L		NC	20
Diazinon (Qualitative)	ND		ND		ug/L		NC	20
Dibenz(a,h)anthracene	ND		ND		ug/L		NC	20
Diclorvos (DDVP)	ND		ND		ug/L		NC	20
Dieldrin	ND		ND		ug/L		NC	20
Diethylphthalate	ND		ND		ug/L		NC	20
Dimethoate	ND		ND		ug/L		NC	20
Dimethylphthalate	ND		ND		ug/L		NC	20
Di-n-butyl phthalate	ND		ND		ug/L		NC	20
Di-n-octyl phthalate	ND		ND		ug/L		NC	20
Endosulfan I (Alpha)	ND		ND		ug/L		NC	20
Endosulfan II (Beta)	ND		ND		ug/L		NC	20
Endosulfan sulfate	ND		ND		ug/L		NC	20
Endrin	ND		ND		ug/L		NC	20
Endrin aldehyde	ND		ND		ug/L		NC	20

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-15847-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-15819-O-1-A DU
Matrix: Water
Analysis Batch: 14896

Client Sample ID: Duplicate
Prep Type: Total/NA
Prep Batch: 13642

Analyte	Sample Result	Sample Qualifier	DU Result	DU Qualifier	Unit	D	RPD	Limit
EPTC	ND		ND		ug/L		NC	20
Fluoranthene	ND		ND		ug/L		NC	20
Fluorene	ND		ND		ug/L		NC	20
gamma-Chlordane	ND		ND		ug/L		NC	20
Heptachlor	ND		ND		ug/L		NC	20
Heptachlor epoxide (isomer B)	ND		ND		ug/L		NC	20
Hexachlorobenzene	ND		ND		ug/L		NC	20
Hexachlorocyclopentadiene	ND		ND		ug/L		NC	20
Indeno[1,2,3-cd]pyrene	ND		ND		ug/L		NC	20
Isophorone	ND		ND		ug/L		NC	20
Lindane	ND		ND		ug/L		NC	20
Malathion	ND		ND		ug/L		NC	20
Methoxychlor	ND		ND		ug/L		NC	20
Metolachlor	ND		ND		ug/L		NC	20
Metribuzin	ND		ND		ug/L		NC	20
Molinate	ND		ND		ug/L		NC	20
Naphthalene	ND		ND		ug/L		NC	20
Parathion	ND		ND		ug/L		NC	20
Pendimethalin (Penoxaline)	ND		ND		ug/L		NC	20
Total Permethrin (mixed isomers)	ND		ND		ug/L		NC	20
Phenanthrene	ND		ND		ug/L		NC	20
Propachlor	ND		ND		ug/L		NC	20
Pyrene	ND		ND		ug/L		NC	20
Simazine	ND		ND		ug/L		NC	20
Terbacil	ND		ND		ug/L		NC	20
Terbutylazine	ND		ND		ug/L		NC	20
Thiobencarb	ND		ND		ug/L		NC	20
trans-Nonachlor	ND		ND		ug/L		NC	20
Trifluralin	ND		ND		ug/L		NC	20

Surrogate	%Recovery	DU Qualifier	DU Limits
2-Nitro-m-xylene	90		70 - 130
Triphenylphosphate	116		70 - 130
Perylene-d12	93		70 - 130

Method: 625 PAH Physis LL (EAL) + TICs - EPA 625 Base/Neutral and Acid Organics i

Lab Sample ID: 99170-B1
Matrix: water
Analysis Batch: O-38084

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: O-38084_P

Analyte	Blank Result	Blank Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/20/22 16:04	1
1-Methylphenanthrene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/20/22 16:04	1
2,3,5-Trimethylnaphthalene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/20/22 16:04	1
2,6-Dimethylnaphthalene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/20/22 16:04	1
2-Methylnaphthalene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/20/22 16:04	1
Acenaphthene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/20/22 16:04	1
Acenaphthylene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/20/22 16:04	1

Eurofins Eaton Monrovia

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-15847-1

Method: 625 PAH Physis LL (EAL) + TICs - EPA 625 Base/Neutral and Acid Organics i (Continued)

Lab Sample ID: 99170-B1
Matrix: water
Analysis Batch: O-38084

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: O-38084_P

Analyte	Blank Result	Blank Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Anthracene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/20/22 16:04	1
Benz[a]anthracene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/20/22 16:04	1
Benzo[a]pyrene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/20/22 16:04	1
Benzo[b]fluoranthene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/20/22 16:04	1
Benzo[e]pyrene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/20/22 16:04	1
Benzo[g,h,i]perylene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/20/22 16:04	1
Benzo[k]fluoranthene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/20/22 16:04	1
Biphenyl	ND		0.005	0.001	µg/L		08/15/22 00:00	08/20/22 16:04	1
Chrysene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/20/22 16:04	1
Dibenz[a,h]anthracene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/20/22 16:04	1
Dibenzo[a,l]pyrene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/20/22 16:04	1
Dibenzothiophene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/20/22 16:04	1
Disalicylidenepronediamine	ND		0.1	0.05	µg/L		08/15/22 00:00	08/20/22 16:04	1
Fluoranthene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/20/22 16:04	1
Fluorene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/20/22 16:04	1
Indeno[1,2,3-cd]pyrene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/20/22 16:04	1
Naphthalene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/20/22 16:04	1
Perylene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/20/22 16:04	1
Phenanthrene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/20/22 16:04	1
Pyrene	ND		0.005	0.001	µg/L		08/15/22 00:00	08/20/22 16:04	1

Surrogate	Blank %Recovery	Blank Qualifier	Limits	Prepared	Analyzed	Dil Fac
(d10-Acenaphthene)	92		65 - 113	08/15/22 00:00	08/20/22 16:04	1
(d10-Phenanthrene)	93		80 - 111	08/15/22 00:00	08/20/22 16:04	1
(d12-Chrysene)	92		60 - 139	08/15/22 00:00	08/20/22 16:04	1
(d12-Perylene)	88		36 - 161	08/15/22 00:00	08/20/22 16:04	1
(d8-Naphthalene)	88		44 - 119	08/15/22 00:00	08/20/22 16:04	1

Lab Sample ID: 99170-BS1
Matrix: water
Analysis Batch: O-38084

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: O-38084_P

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
1-Methylnaphthalene	0.5	0.414		µg/L		83	49 - 117
1-Methylphenanthrene	0.5	0.434		µg/L		87	66 - 127
2,3,5-Trimethylnaphthalene	0.5	0.427		µg/L		85	57 - 120
2,6-Dimethylnaphthalene	0.5	0.413		µg/L		83	54 - 117
2-Methylnaphthalene	0.5	0.41		µg/L		82	47 - 130
Acenaphthene	0.5	0.425		µg/L		85	53 - 131
Acenaphthylene	0.5	0.418		µg/L		84	43 - 140
Anthracene	0.5	0.449		µg/L		90	58 - 135
Benz[a]anthracene	0.5	0.365		µg/L		73	55 - 145
Benzo[a]pyrene	0.5	0.401		µg/L		80	51 - 143
Benzo[b]fluoranthene	0.5	0.446		µg/L		89	46 - 165
Benzo[e]pyrene	0.5	0.427		µg/L		85	42 - 152
Benzo[g,h,i]perylene	0.5	0.444		µg/L		89	63 - 133
Benzo[k]fluoranthene	0.5	0.426		µg/L		85	56 - 145
Biphenyl	0.5	0.422		µg/L		84	56 - 119

Eurofins Eaton Monrovia

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-15847-1

Method: 625 PAH Physis LL (EAL) + TICs - EPA 625 Base/Neutral and Acid Organics i (Continued)

Lab Sample ID: 99170-BS1
Matrix: water
Analysis Batch: O-38084

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: O-38084_P

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits	
Chrysene	0.5	0.384		µg/L		77	56 - 141	
Dibenz[a,h]anthracene	0.5	0.407		µg/L		81	55 - 150	
Dibenzo[a,l]pyrene	0.5	0.499		µg/L		100	50 - 150	
Dibenzothiophene	0.5	0.436		µg/L		87	75 - 113	
Disalicylidenepropanediamine	25	18.1		µg/L		72	50 - 150	
Fluoranthene	0.5	0.442		µg/L		88	60 - 146	
Fluorene	0.5	0.432		µg/L		86	58 - 131	
Indeno[1,2,3-cd]pyrene	0.5	0.415		µg/L		83	50 - 151	
Naphthalene	0.5	0.402		µg/L		80	41 - 126	
Perylene	0.5	0.4		µg/L		80	48 - 141	
Phenanthrene	0.5	0.45		µg/L		90	67 - 127	
Pyrene	0.5	0.425		µg/L		85	54 - 156	

Surrogate	LCS LCS		Limits
	%Recovery	Qualifier	
(d10-Acenaphthene)	87		65 - 113
(d10-Phenanthrene)	91		80 - 111
(d12-Chrysene)	84		60 - 139
(d12-Perylene)	86		36 - 161
(d8-Naphthalene)	81		44 - 119

Lab Sample ID: 99170-BS2
Matrix: water
Analysis Batch: O-38084

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: O-38084_P

Analyte	Spike Added	LCS DUP Result	LCS DUP Qualifier	Unit	D	%Rec	%Rec Limits		RPD	
									RPD	Limit
1-Methylnaphthalene	0.5	0.442		µg/L		88	49 - 117	6	30	
1-Methylphenanthrene	0.5	0.443		µg/L		89	66 - 127	2	30	
2,3,5-Trimethylnaphthalene	0.5	0.45		µg/L		90	57 - 120	6	30	
2,6-Dimethylnaphthalene	0.5	0.44		µg/L		88	54 - 117	6	30	
2-Methylnaphthalene	0.5	0.439		µg/L		88	47 - 130	7	30	
Acenaphthene	0.5	0.449		µg/L		90	53 - 131	6	30	
Acenaphthylene	0.5	0.449		µg/L		90	43 - 140	7	30	
Anthracene	0.5	0.427		µg/L		85	58 - 135	6	30	
Benz[a]anthracene	0.5	0.387		µg/L		77	55 - 145	5	30	
Benzo[a]pyrene	0.5	0.447		µg/L		89	51 - 143	11	30	
Benzo[b]fluoranthene	0.5	0.472		µg/L		94	46 - 165	5	30	
Benzo[e]pyrene	0.5	0.453		µg/L		91	42 - 152	7	30	
Benzo[g,h,i]perylene	0.5	0.465		µg/L		93	63 - 133	4	30	
Benzo[k]fluoranthene	0.5	0.468		µg/L		94	56 - 145	10	30	
Biphenyl	0.5	0.455		µg/L		91	56 - 119	8	30	
Chrysene	0.5	0.4		µg/L		80	56 - 141	4	30	
Dibenz[a,h]anthracene	0.5	0.439		µg/L		88	55 - 150	8	30	
Dibenzo[a,l]pyrene	0.5	0.512		µg/L		102	50 - 150	2	30	
Dibenzothiophene	0.5	0.461		µg/L		92	75 - 113	6	30	
Disalicylidenepropanediamine	25	23.3		µg/L		93	50 - 150	25	30	
Fluoranthene	0.5	0.459		µg/L		92	60 - 146	4	30	
Fluorene	0.5	0.449		µg/L		90	58 - 131	5	30	
Indeno[1,2,3-cd]pyrene	0.5	0.442		µg/L		88	50 - 151	6	30	

Eurofins Eaton Monrovia

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-15847-1

Method: 625 PAH Physis LL (EAL) + TICs - EPA 625 Base/Neutral and Acid Organics i (Continued)

Lab Sample ID: 99170-BS2
Matrix: water
Analysis Batch: O-38084

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: O-38084_P

Analyte	Spike Added	LCS DUP Result	LCS DUP Qualifier	Unit	D	%Rec	%Rec		RPD	Limit
							Limits	RPD		
Naphthalene	0.5	0.437		µg/L		87	41 - 126	8		30
Perylene	0.5	0.428		µg/L		86	48 - 141	7		30
Phenanthrene	0.5	0.47		µg/L		94	67 - 127	4		30
Pyrene	0.5	0.443		µg/L		89	54 - 156	5		30

Surrogate	LCS DUP %Recovery	LCS DUP Qualifier	Limits	Prepared	Analyzed	Dil Fac
(d10-Phenanthrene)	98		80 - 111			
(d12-Chrysene)	88		60 - 139			
(d12-Perylene)	95		36 - 161			
(d8-Naphthalene)	90		44 - 119			

Method: 8015 Diesel LL (EAL) and Motor Oil - 8015 - TPH DRO/ORO

Lab Sample ID: 22DSH022WB
Matrix: WATER
Analysis Batch: 22DSH022W

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
MOTOR OIL	ND	U	0.05		mg/L		08/15/22 14:24	1	

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
HEXACOSANE			60 - 130		08/15/22 14:24	1

Lab Sample ID: 22DSH022WL
Matrix: WATER
Analysis Batch: 22DSH022W

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec		Limit
							Limits	RPD	
DIESEL	2.5	2.58		mg/L		103	50 - 130		

Surrogate	LCS %Recovery	LCS Qualifier	Limits	Prepared	Analyzed	Dil Fac
HEXACOSANE	100		60 - 130			

Method: 8015 Gas (Purgeable) LL (EAL) - SW846 8015B Gasoline Range Organics

Lab Sample ID: 22VG39H05B
Matrix: WATER
Analysis Batch: 22VG39H05

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac

Eurofins Eaton Monrovia

QC Sample Results

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-15847-1

Method: 8015 Gas (Purgeable) LL (EAL) - SW846 8015B Gasoline Range Organics

Lab Sample ID: 22VG39H05L
Matrix: WATER
Analysis Batch: 22VG39H05

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
GASOLINE	0.5	0.421		mg/L		84	60 - 130
Surrogate							
	%Recovery	LCS Qualifier	LCS Limits				
BROMOFLUOROBENZENE	109		70 - 130				

Lab Sample ID: 22H144-01M
Matrix: WATER
Analysis Batch: 22VG39H05

Client Sample ID: Matrix Spike
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
GASOLINE	ND		0.5	0.445		mg/L		89	50 - 130
Surrogate									
	%Recovery	MS Qualifier	MS Limits						
BROMOFLUOROBENZENE	113		60 - 140						

Lab Sample ID: 22H144-01S
Matrix: WATER
Analysis Batch: 22VG39H05

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
GASOLINE	ND		0.5	0.438		mg/L		88	50 - 130	2	30
Surrogate											
	%Recovery	MSD Qualifier	MSD Limits								
BROMOFLUOROBENZENE	113		60 - 140								

QC Association Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-15847-1

GC/MS Semi VOA

Prep Batch: 13642

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-15847-1	MOANALUA WELLS	Total/NA	Drinking Water	525.2	
MB 380-13642/1-A	Method Blank	Total/NA	Water	525.2	
LCS 380-13642/3-A	Lab Control Sample	Total/NA	Water	525.2	
LCSD 380-13642/4-A	Lab Control Sample Dup	Total/NA	Water	525.2	
MRL 380-13642/2-A	Lab Control Sample	Total/NA	Water	525.2	
380-16346-A-1-A MS	Matrix Spike	Total/NA	Water	525.2	
380-15819-O-1-A DU	Duplicate	Total/NA	Water	525.2	

Analysis Batch: 14896

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-15847-1	MOANALUA WELLS	Total/NA	Drinking Water	525.2	13642
MB 380-13642/1-A	Method Blank	Total/NA	Water	525.2	13642
LCS 380-13642/3-A	Lab Control Sample	Total/NA	Water	525.2	13642
LCSD 380-13642/4-A	Lab Control Sample Dup	Total/NA	Water	525.2	13642
MRL 380-13642/2-A	Lab Control Sample	Total/NA	Water	525.2	13642
380-16346-A-1-A MS	Matrix Spike	Total/NA	Water	525.2	13642
380-15819-O-1-A DU	Duplicate	Total/NA	Water	525.2	13642

Subcontract

Analysis Batch: O-38084

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-15847-1	MOANALUA WELLS	Total/NA	Drinking Water	625 PAH Physis LL (EAL) + TICs	O-38084_P
99170-B1	Method Blank	Total/NA	water	625 PAH Physis LL (EAL) + TICs	O-38084_P
99170-BS1	Lab Control Sample	Total/NA	water	625 PAH Physis LL (EAL) + TICs	O-38084_P
99170-BS2	Lab Control Sample Dup	Total/NA	water	625 PAH Physis LL (EAL) + TICs	O-38084_P

Analysis Batch: 22DSH022W

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-15847-1	MOANALUA WELLS	Total/NA	Drinking Water	8015 Diesel LL (EAL) and Motor Oil	
22DSH022WB	Method Blank	Total/NA	WATER	8015 Diesel LL (EAL) and Motor Oil	
22DSH022WL	Lab Control Sample	Total/NA	WATER	8015 Diesel LL (EAL) and Motor Oil	

Analysis Batch: 22VG39H05

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-15847-1	MOANALUA WELLS	Total/NA	Drinking Water	8015 Gas (Purgeable) LL (EAL)	
380-15847-2	TB:MOANALUA WELLS	Total/NA	Water	8015 Gas (Purgeable) LL (EAL)	
22VG39H05B	Method Blank	Total/NA	WATER	8015 Gas (Purgeable) LL (EAL)	

Eurofins Eaton Monrovia

QC Association Summary

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-15847-1

Subcontract (Continued)

Analysis Batch: 22VG39H05 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
22VG39H05L	Lab Control Sample	Total/NA	WATER	8015 Gas (Purgeable) LL (EAL)	
22H144-01M	Matrix Spike	Total/NA	WATER	8015 Gas (Purgeable) LL (EAL)	
22H144-01S	Matrix Spike Duplicate	Total/NA	WATER	8015 Gas (Purgeable) LL (EAL)	

Prep Batch: O-38084_P

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-15847-1	MOANALUA WELLS	Total/NA	Drinking Water	EPA_625	
99170-B1	Method Blank	Total/NA	water	EPA_625	
99170-BS1	Lab Control Sample	Total/NA	water	EPA_625	
99170-BS2	Lab Control Sample Dup	Total/NA	water	EPA_625	



Lab Chronicle

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-15847-1

Client Sample ID: MOANALUA WELLS

Lab Sample ID: 380-15847-1

Date Collected: 08/08/22 10:57

Matrix: Drinking Water

Date Received: 08/10/22 10:20

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	525.2			13642	N8NE	EA MON	08/17/22 11:27
Total/NA	Analysis	525.2		1	14896	UJC9	EA MON	08/25/22 17:55
Total/NA	Prep	EPA_625		1	O-38084_P			08/15/22 00:00
Total/NA	Analysis	625 PAH Physis LL (EAL) + TICs		1	O-38084	YC		08/21/22 09:48
Total/NA	Analysis	8015 Diesel LL (EAL) and Motor Oil		1	22DSH022W	SDees		08/15/22 18:07
Total/NA	Analysis	8015 Gas (Purgeable) LL (EAL)		1	22VG39H05	SCerva		08/12/22 14:24

Client Sample ID: TB:MOANALUA WELLS

Lab Sample ID: 380-15847-2

Date Collected: 08/08/22 10:57

Matrix: Water

Date Received: 08/10/22 10:20

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	8015 Gas (Purgeable) LL (EAL)		1	22VG39H05	SCerva		08/12/22 16:13

Laboratory References:

= Physis Environmental Laboratories, 1904 Wright Circle, Anaheim, CA 92806

EA MON = Eurofins Eaton Monrovia, 750 Royal Oaks Drive, Suite 100, Monrovia, CA 91016, TEL (626)386-1100

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-15847-1

Laboratory: Eurofins Eaton Monrovia

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-23

The following analytes are included in this report, but the laboratory is not certified by the governing authority. This list may include analytes for which the agency does not offer certification.

Analysis Method	Prep Method	Matrix	Analyte
525.2	525.2	Drinking Water	2,4'-DDD
525.2	525.2	Drinking Water	2,4'-DDE
525.2	525.2	Drinking Water	2,4'-DDT
525.2	525.2	Drinking Water	2,4-Dinitrotoluene
525.2	525.2	Drinking Water	2,6-Dinitrotoluene
525.2	525.2	Drinking Water	4,4'-DDD
525.2	525.2	Drinking Water	4,4'-DDE
525.2	525.2	Drinking Water	4,4'-DDT
525.2	525.2	Drinking Water	Acenaphthene
525.2	525.2	Drinking Water	Acenaphthylene
525.2	525.2	Drinking Water	Acetochlor
525.2	525.2	Drinking Water	alpha-BHC
525.2	525.2	Drinking Water	alpha-Chlordane
525.2	525.2	Drinking Water	Anthracene
525.2	525.2	Drinking Water	Benz(a)anthracene
525.2	525.2	Drinking Water	Benzo[b]fluoranthene
525.2	525.2	Drinking Water	Benzo[g,h,i]perylene
525.2	525.2	Drinking Water	Benzo[k]fluoranthene
525.2	525.2	Drinking Water	beta-BHC
525.2	525.2	Drinking Water	Bromacil
525.2	525.2	Drinking Water	Butylbenzylphthalate
525.2	525.2	Drinking Water	Caffeine
525.2	525.2	Drinking Water	Chlorobenzilate
525.2	525.2	Drinking Water	Chloroneb
525.2	525.2	Drinking Water	Chlorothalonil (Draconil, Bravo)
525.2	525.2	Drinking Water	Chlorpyrifos
525.2	525.2	Drinking Water	Chrysene
525.2	525.2	Drinking Water	delta-BHC
525.2	525.2	Drinking Water	Diazinon (Qualitative)
525.2	525.2	Drinking Water	Dibenz(a,h)anthracene
525.2	525.2	Drinking Water	Diclorvos (DDVP)
525.2	525.2	Drinking Water	Diethylphthalate
525.2	525.2	Drinking Water	Dimethoate
525.2	525.2	Drinking Water	Dimethylphthalate
525.2	525.2	Drinking Water	Di-n-butyl phthalate
525.2	525.2	Drinking Water	Di-n-octyl phthalate
525.2	525.2	Drinking Water	Endosulfan I (Alpha)
525.2	525.2	Drinking Water	Endosulfan II (Beta)
525.2	525.2	Drinking Water	Endosulfan sulfate
525.2	525.2	Drinking Water	Endrin aldehyde
525.2	525.2	Drinking Water	EPTC
525.2	525.2	Drinking Water	Fluoranthene
525.2	525.2	Drinking Water	Fluorene
525.2	525.2	Drinking Water	gamma-Chlordane
525.2	525.2	Drinking Water	Indeno[1,2,3-cd]pyrene

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-15847-1

Laboratory: Eurofins Eaton Monrovia (Continued)

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
-----------	---------	-----------------------	-----------------

The following analytes are included in this report, but the laboratory is not certified by the governing authority. This list may include analytes for which the agency does not offer certification.

Analysis Method	Prep Method	Matrix	Analyte
525.2	525.2	Drinking Water	Isophorone
525.2	525.2	Drinking Water	Malathion
525.2	525.2	Drinking Water	Molinate
525.2	525.2	Drinking Water	Naphthalene
525.2	525.2	Drinking Water	Parathion
525.2	525.2	Drinking Water	Pendimethalin (Penoxaline)
525.2	525.2	Drinking Water	Phenanthrene
525.2	525.2	Drinking Water	Pyrene
525.2	525.2	Drinking Water	Terbacil
525.2	525.2	Drinking Water	Terbutylazine
525.2	525.2	Drinking Water	Thiobencarb
525.2	525.2	Drinking Water	Total Permethrin (mixed isomers)
525.2	525.2	Drinking Water	trans-Nonachlor
525.2	525.2	Drinking Water	Trifluralin

Method Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-15847-1

Method	Method Description	Protocol	Laboratory
525.2	Semivolatile Organic Compounds (GC/MS)	EPA	EA MON
625	EPA 625 Base/Neutral and Acid Organics i	EPA	
8015	8015 - TPH DRO/ORO	EPA	
8015B	SW846 8015B Gasoline Range Organics	SW846	
525.2	Extraction of Semivolatile Compounds	EPA	EA MON

Protocol References:

EPA = US Environmental Protection Agency

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

Laboratory References:

= Physis Environmental Laboratories, 1904 Wright Circle, Anaheim, CA 92806

EA MON = Eurofins Eaton Monrovia, 750 Royal Oaks Drive, Suite 100, Monrovia, CA 91016, TEL (626)386-1100



Sample Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-15847-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
380-15847-1	MOANALUA WELLS	Drinking Water	08/08/22 10:57	08/10/22 10:20
380-15847-2	TB:MOANALUA WELLS	Water	08/08/22 10:57	08/10/22 10:20

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17



3051 Fujita Street
Torrance, CA 90505
Tel: (310)-618-8889

Date: 08-31-2022
EMAX Batch No.: 22H144

Attn: Jackie Contreras

Eurofins Eaton Analytical
750 Royal Oaks Dr., Suite 100
Monrovia, CA 91016-3629

Subject: Laboratory Report
Project: 380-15847

Enclosed is the Laboratory report for samples received on 08/11/22.
The data reported relate only to samples listed below :

Sample ID	Control #	Col Date	Matrix	Analysis
380-15847-1	H144-01	08/08/22	WATER	TPH GASOLINE TPH DIESEL & MOTOR OIL
380-15847-2	H144-02	08/08/22	WATER	TPH GASOLINE
380-15847-1MS	H144-01M	08/08/22	WATER	TPH GASOLINE
380-15847-1MSD	H144-01S	08/08/22	WATER	TPH GASOLINE

The results are summarized on the following pages.

Please feel free to call if you have any questions concerning these results.

Sincerely yours,

Caspak J. Pang
Laboratory Director

This report is confidential and intended solely for the use of the individual or entity to whom it is addressed. This report shall not be reproduced except in full or without the written approval of EMAX.

EMAX certifies that results included in this report meets all TNI & DOD requirements unless noted in the Case Narrative.

NELAP Accredited Certificate Number CA002912022-22
ANAB Accredited DoD ELAP and ISO/IEC 17025 Certificate Number L2278 Testing
California ELAP Accredited Certificate Number 2672

Chain of Custody Record

Monrovia, CA (Suite 100)
 750 Royal Oaks Drive Suite 100
 Monrovia, CA 91016
 Phone: 626-386-1100



3861144



Client Information (Sub Contract Lab)

Client Contact: **EMAX Laboratories Inc**
 Shipping/Receiving

Sampler: Frank, Debbie L
 Phone: Debbie.Frank@eurofins.com
 E-Mail: Debbie.Frank@eurofins.com
 Accreditation Required (See note): State - Hawaii

Carrier/Tracking No(s):
 State of Origin: Hawaii

COC No: 380-17099-1
 Page: Page 1 of 1
 Job #: 380-15847-1

Address: 3051 Fujita Street,
 City: Torrance
 State, Zip: CA, 90505
 Phone:

Due Date Requested: 8/24/2022
 TAT Requested (days):

Analysis Requested

Project Name: RED-HILL
 Project #: 38001111
 SSO#:
 Site: Honolulu BWS Sites

Field Filtered Sample (Yes or No)
 Perform MS/MSD (Yes or No)
 SUB (8015 Gas (Purgeable) LL (EAL)/ 8015 Gas (Purgeable) LL (EAL)
 SUB (8015 Diesel LL (EAL) and Motor Oil)/ 8015 Diesel LL (EAL) and Motor Oil

- Preservation Codes:
- A - HCL
 - B - NaOH
 - C - Zn Acetate
 - D - Nitric Acid
 - E - NaHSO4
 - F - MeOH
 - G - Amchlor
 - H - Ascorbic Acid
 - I - Ice
 - J - DI Water
 - K - EDTA
 - L - EDA
 - Other:
 - M - Hexane
 - N - None
 - O - AsNaO2
 - P - Na2O4S
 - Q - Na2S2O3
 - R - Na2S2O3
 - S - H2SO4
 - T - TSP Dodecahydrate
 - U - Acetone
 - V - MCAA
 - W - pH 4.5
 - Y - Trizma
 - Z - other (specify)

Sample Identification - Client ID (Lab ID)

1 MOANALUA WELLS (331-223-T-P202) (380-15847-1)
 2 TB:MOANALUA WELLS (331-223-T-P202) (380-15847-2)

Sample ID	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	MATRIX (W=water, Sealed, O=water/oil, BT=Testkit, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	SUB (8015 Gas (Purgeable) LL (EAL)/ 8015 Gas (Purgeable) LL (EAL))	SUB (8015 Diesel LL (EAL) and Motor Oil)/ 8015 Diesel LL (EAL) and Motor Oil	Total Number of containers	Special Instructions/Note:
1	8/8/22	10:57	Hawaiian	Water	X	X			6	See Attached Instructions
2	8/8/22	10:57	Hawaiian	Water	X	X			2	See Attached Instructions

Note: Since laboratory accreditations are subject to change, Eurofins Eaton Analytical, LLC places the ownership of method, analyte & accreditation compliance upon out sub-contract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/test/matrix being analyzed, the samples must be shipped back to the Eurofins Eaton Analytical, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Eaton Analytical, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Eaton Analytical, LLC.

Possible Hazard Identification

Deliverable Requested: I, II, III, IV, Other (specify) Primary Deliverable Rank: 2

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
 Return To Client Disposal By Lab Archive For _____ Months

Empty Kit Relinquished by:

Date: _____ Time: _____ Method of Shipment: _____

Relinquished by:

Date/Time: 8/11/22 18:02 Company: SEA Received by: Noel TAN Date/Time: 8/11/22 18:02 Company: _____

Relinquished by:

Date/Time: _____ Date/Time: _____ Company: _____

Custody Seals Intact: _____ Custody Seal No.: _____

REPORT ID: 22H144 Cooler Temperature(s) °C and Other Remarks: 2.0° Page 2 of 24



REFERENCE: EMAX-SM02 Rev. 12
SAMPLE RECEIPT FORM 1

Type of Delivery <input type="checkbox"/> Fedex <input type="checkbox"/> UPS <input type="checkbox"/> GSO <input type="checkbox"/> Others <input checked="" type="checkbox"/> EMAX Courier <input checked="" type="checkbox"/> Client Delivery	Airbill / Tracking Number	ECN <u>22H144</u> Recipient <u>Noel Tah</u> Date <u>08/11/22</u> Time <u>10:02</u>
--	---------------------------	--

COC INSPECTION


<input checked="" type="checkbox"/> Client Name	<input checked="" type="checkbox"/> Client PM/FC	<input type="checkbox"/> Sampler Name	<input checked="" type="checkbox"/> Sampling Date/Time	<input checked="" type="checkbox"/> Sample ID	<input checked="" type="checkbox"/> Matrix
<input checked="" type="checkbox"/> Address	<input type="checkbox"/> Tel # / Fax #	<input type="checkbox"/> Courier Signature	<input checked="" type="checkbox"/> Analysis Required	<input type="checkbox"/> Preservative (if any)	<input checked="" type="checkbox"/> TAT
Safety Issues (if any) Note:	<input type="checkbox"/> High concentrations expected	<input type="checkbox"/> From Superfund Site	<input type="checkbox"/> Rad screening required		

PACKAGING INSPECTION

Container	<input checked="" type="checkbox"/> Cooler	<input type="checkbox"/> Box	<input type="checkbox"/> Other
Condition	<input type="checkbox"/> Custody Seal	<input type="checkbox"/> Intact	<input type="checkbox"/> Damaged
Packaging	<input checked="" type="checkbox"/> Bubble Pack	<input type="checkbox"/> Styrofoam	<input type="checkbox"/> Popcorn
Temperatures (Cool, ≤6 °C but not frozen)	<input type="checkbox"/> Cooler 1 _____ °C	<input checked="" type="checkbox"/> Cooler 2 <u>2.0</u> °C	<input type="checkbox"/> Cooler 3 _____ °C
	<input type="checkbox"/> Cooler 6 _____ °C	<input type="checkbox"/> Cooler 7 _____ °C	<input type="checkbox"/> Cooler 8 _____ °C
Thermometer:	A - S/N _____	B - S/N <u>210760237</u>	C - S/N _____
			<input checked="" type="checkbox"/> D - S/N <u>210760272</u>

Comments: Temperature is out of range. PM was informed IMMEDIATELY.
 Note:

DISCREPANCIES

LabSampleID	LabSampleContainerID	Code	ClientSample Label ID / Information	Corrective Action
<u>2</u>	<u>7,0</u>	<u>D7</u>	<u>two dates on label - 8/3/22 & 8/8/22</u>	<u>R1</u>
				

pH holding time requirement for water samples is 15 mins. Water samples for pH analysis are received beyond 15 minutes from sampling time.

NOTES/OBSERVATIONS:

SAMPLE MATRIX IS DRINKING WATER? YES NO

LEGEND:

Code Description-Sample Management	Code Description-Sample Management	Code Description-Sample Management
D1 Analysis is not indicated in _____	D13 Out of Holding Time	R1 Proceed as indicated in <input checked="" type="checkbox"/> COC <input type="checkbox"/> Label
D2 Analysis mismatch COC vs label	D14 Bubble is >6mm	R2 Refer to attached instruction
D3 Sample ID mismatch COC vs label	D15 No trip blank in cooler	R3 Cancel the analysis
D4 Sample ID is not indicated in _____	D16 Preservation not indicated in _____	R4 Use vial with smallest bubble first
D5 Container -[improper] [leaking] [broken]	D17 Preservation mismatch COC vs label	R5 Log-in with latest sampling date and time+1 min
D6 Date/Time is not indicated in _____	D18 Insufficient chemical preservative	R6 Adjust pH as necessary
D7 Date/Time mismatch COC vs label	D19 Insufficient Sample	R7 Filter and preserved as necessary
D8 Sample listed in COC is not received	D20 No filtration info for dissolved analysis	R8 _____
D9 Sample received is not listed in COC	D21 No sample for moisture determination	R9 _____
D10 No initial/date on corrections in COC/label	D22 _____	R10 _____
D11 Container count mismatch COC vs received	D23 _____	R11 _____
D12 Container size mismatch COC vs received	D24 _____	R12 _____

REVIEWS:

Sample Labeling	Date	SRF	Date	PM	Date
<u>Jacelyne Solis</u>	<u>08/12/22</u>	<u>[Signature]</u>	<u>8/12/22</u>	<u>[Signature]</u>	<u>8/16/22</u>



AREA FAST
COURIER SERVICE

1146 N. Central Ave., #444 • Glendale, CA 91202
Phone: 818/ 497-4474

INVOICE 19314
CALL NO _____
REF. NO _____
DATE 08-11-22

CHARGE TO EUROFIN
FROM: Eaton Analy TO: E. MAX WORKS
MONTROVIA 3035 FUJITA
TORRANCE

PACKAGES	DESCRIPTION	CHARGES
		REGULAR
		RUSH
		ASAP
		MISC CHARGES
		WAITING TIME
		WEIGHT
		TOTAL CHARGE

DRIVER: NOEL TAN PICK UP TIME: 8/11/22 18:02 DELIVERY TIME: 8:02
Received By: _____

REPORTING CONVENTIONS

DATA QUALIFIERS:

Lab Qualifier	AFCEE Qualifier	Description
J	F	Indicates that the analyte is positively identified and the result is less than RL but greater than MDL.
N		Indicates presumptive evidence of a compound.
B	B	Indicates that the analyte is found in the associated method blank as well as in the sample at above QC level.
E	J	Indicates that the result is above the maximum calibration range or estimated value.
*	*	Out of QC limit.

Note: The above qualifiers are used to flag the results unless the project requires a different set of qualification criteria.

ACRONYMS AND ABBREVIATIONS:

CRDL	Contract Required Detection Limit
RL	Reporting Limit
MRL	Method Reporting Limit
PQL	Practical Quantitation Limit
MDL	Method Detection Limit
DO	Diluted out

DATES

The date and time information for leaching and preparation reflect the beginning date and time of the procedure unless the method, protocol, or project specifically requires otherwise.

LABORATORY REPORT FOR

EUROFINS EATON ANALYTICAL

380-15847

METHOD 5030B/8015B
TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

SDG#: 22H144



CASE NARRATIVE

Client : EUROFINS EATON ANALYTICAL

Project: 380-15847

SDG : 22H144

METHOD 5030B/8015B
TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

A total of two(2) water samples were received on 08/11/22 to be analyzed for Total Petroleum Hydrocarbons by Purge and Trap in accordance with Method 5030B/8015B and project specific requirements.

Holding Time

Samples were analyzed within the prescribed holding time.

Calibration

Multi-calibration points were generated to establish initial calibration (ICAL). ICAL was verified using a secondary source (ICV). Continuing calibration (CCV) verifications were carried out on a frequency specified by the project. All calibration requirements were within acceptance criteria. Refer to calibration summary forms of ICAL, ICV and CCV for details. MRL was analyzed as required by the project. Refer to MRL summary form for details.

Method Blank

Method blank was prepared and analyzed at the frequency required by the project. For this SDG, one(1) method blank was analyzed. VG39H05B - result was compliant to project requirement. Refer to sample result summary form for details.

Lab Control Sample

Lab control sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) set of LCS/LCD was analyzed. VG39H05L/VG39H05C were within LCS limits. Refer to LCS summary form for details.

Matrix QC Sample

Matrix spike sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) set of MS/MSD was analyzed. Gasoline was within MS QC limits in H144-01M/H144-01S. Refer to Matrix QC summary form for details.

Surrogate

Surrogate was added on QC and field samples. All surrogate recoveries were within QC limits. Refer to sample result summary forms for details.

Sample Analysis

Samples were analyzed according to prescribed analytical procedures. Results were evaluated in accordance to project requirements. For this SDG, all quality control requirements were met.

LAB CHRONICLE
TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

```

=====
Client      : EUROFINS EATON ANALYTICAL
Project    : 380-15847
=====
SDG NO.    : 22H144
Instrument ID : GCT039
=====

```

Client Sample ID	Laboratory Sample ID	Dilution Factor	% Moist	Analysis DateTime	Extraction DateTime	Sample Data FN	Calibration Data FN	Prep. Batch	Notes
									WATER
MBLK1W	VG39H05B	1	NA	08/12/2212:35	08/12/2212:35	EH12005A	EH12004A	22VG39H05	Method Blank
LCS1W	VG39H05L	1	NA	08/12/2213:11	08/12/2213:11	EH12006A	EH12004A	22VG39H05	Lab Control Sample (LCS)
LCD1W	VG39H05C	1	NA	08/12/2213:47	08/12/2213:47	EH12007A	EH12004A	22VG39H05	LCS Duplicate
380-15847-1	H144-01	1	NA	08/12/2214:24	08/12/2214:24	EH12008A	EH12004A	22VG39H05	Field Sample
380-15847-1MS	H144-01M	1	NA	08/12/2215:01	08/12/2215:01	EH12009A	EH12004A	22VG39H05	Matrix Spike Sample (MS)
380-15847-1MSD	H144-01S	1	NA	08/12/2215:37	08/12/2215:37	EH12010A	EH12004A	22VG39H05	MS Duplicate (MSD)
380-15847-2	H144-02	1	NA	08/12/2216:13	08/12/2216:13	EH12011A	EH12004A	22VG39H05	Field Sample

FN - Filename
% Moist - Percent Moisture



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

SAMPLE RESULTS

METHOD 5030B/8015B
TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

```

=====
Client      : EUROFINS EATON ANALYTICAL   Date Collected: 08/08/22 10:57
Project     : 380-15847                   Date Received: 08/11/22
Batch No.   : 22H144                       Date Extracted: 08/12/22 14:24
Sample ID   : 380-15847-1                 Date Analyzed: 08/12/22 14:24
Lab Samp ID: H144-01                       Dilution Factor: 1
Lab File ID: EH12008A                       Matrix: WATER
Ext Btch ID: 22VG39H05                       % Moisture: NA
Calib. Ref.: EH12004A                       Instrument ID: 39
=====

```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)
GASOLINE	ND	0.020	0.010

SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromofluorobenzene	0.0360	0.0400	90	60-140

Notes:
Parameter H-C Range
Gasoline C6-C10
Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.
Sample Amount : 5ml Final Volume : 5ml
Prepared by : SCerva Analyzed by : SCerva

METHOD 5030B/8015B
TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

```

=====
Client      : EUROFINS EATON ANALYTICAL   Date Collected: 08/08/22 10:57
Project     : 380-15847                   Date Received: 08/11/22
Batch No.   : 22H144                      Date Extracted: 08/12/22 16:13
Sample ID   : 380-15847-2                 Date Analyzed: 08/12/22 16:13
Lab Samp ID: H144-02                      Dilution Factor: 1
Lab File ID: EH12011A                     Matrix: WATER
Ext Btch ID: 22VG39H05                    % Moisture: NA
Calib. Ref.: EH12004A                     Instrument ID: 39
=====

```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)
GASOLINE	ND	0.020	0.010

SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromofluorobenzene	0.0361	0.0400	90	60-140

Notes:
Parameter H-C Range
Gasoline C6-C10
Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.
Sample Amount : 5ml Final Volume : 5ml
Prepared by : SCerva Analyzed by : SCerva



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

QC SUMMARIES

METHOD 5030B/8015B
TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

```

=====
Client      : EUROFINS EATON ANALYTICAL   Date Collected: 08/12/22 12:35
Project     : 380-15847                   Date Received: 08/12/22
Batch No.   : 22H144                       Date Extracted: 08/12/22 12:35
Sample ID   : MBLK1W                       Date Analyzed: 08/12/22 12:35
Lab Samp ID: VG39H05B                     Dilution Factor: 1
Lab File ID: EH12005A                     Matrix: WATER
Ext Btch ID: 22VG39H05                   % Moisture: NA
Calib. Ref.: EH12004A                   Instrument ID: 39
=====

```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)
GASOLINE	ND	0.020	0.010

SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromofluorobenzene	0.0336	0.0400	84	60-140

Notes:
Parameter H-C Range
Gasoline C6-C10
Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.
Sample Amount : 5ml Final Volume : 5ml
Prepared by : SCerva Analyzed by : SCerva

EMAX QUALITY CONTROL DATA
LAB CONTROL SAMPLE ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
PROJECT : 380-15847
BATCH NO. : 22H144
METHOD : 5030B/8015B

```

=====
MATRIX      : WATER                               % MOISTURE:NA
DILUTION FACTOR: 1                               1
SAMPLE ID   : MBLK1W                             LCS1W
LAB SAMPLE ID : VG39H05B                         VG39H05L
LAB FILE ID  : EH12005A                         EH12006A
DATE PREPARED : 08/12/22 12:35                  08/12/22 13:11
DATE ANALYZED : 08/12/22 12:35                  08/12/22 13:47
PREP BATCH   : 22VG39H05                         22VG39H05
CALIBRATION REF: EH12004A                       EH12004A
    
```

ACCESSION:

PARAMETERS	MBResult (mg/L)	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	SpikeAmt (mg/L)	LCDResult (mg/L)	LCDRec (%)	RPD (%)	QCLimit (%)	MaxRPD (%)
Gasoline	ND	0.500	0.421	84	0.500	0.422	84	0	60-130	30

SURROGATE PARAMETER	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	SpikeAmt (mg/L)	LCDResult (mg/L)	LCDRec (%)	QCLimit (%)
Bromofluorobenzene	0.0400	0.0435	109	0.0400	0.0434	109	70-130

MB: Method Blank sample LCS: Lab Control Sample LCD: Lab Control Sample Duplicate

EMAX QUALITY CONTROL DATA
MS/MSD ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
PROJECT : 380-15847
BATCH NO. : 22H144
METHOD : 5030B/8015B

MATRIX	: WATER		% MOISTURE:NA
DILUTION FACTOR:	1	1	1
SAMPLE ID	: 380-15847-1	380-15847-1MS	380-15847-1MSD
LAB SAMPLE ID	: H144-01	H144-01M	H144-01S
LAB FILE ID	: EH12008A	EH12009A	EH12010A
DATE PREPARED	: 08/12/22 14:24	08/12/22 15:01	08/12/22 15:37
DATE ANALYZED	: 08/12/22 14:24	08/12/22 15:01	08/12/22 15:37
PREP BATCH	: 22VG39H05	22VG39H05	22VG39H05
CALIBRATION REF:	EH12004A	EH12004A	EH12004A

ACCESSION:

PARAMETERS	PSResult (mg/L)	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	RPD (%)	QCLimit (%)	MaxRPD (%)
Gasoline	ND	0.500	0.445	89	0.500	0.438	88	2	50-130	30

SURROGATE PARAMETER	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	QCLimit (%)
Bromofluorobenzene	0.0400	0.0450	113	0.0400	0.0451	113	60-140

PS: Parent Sample MS: Matrix Spike MSD: Matrix Spike Duplicate

LABORATORY REPORT FOR

EUROFINS EATON ANALYTICAL

380-15847

METHOD 3520C/8015B
TOTAL PETROLEUM HYDROCARBONS BY EXTRACTION

SDG#: 22H144



CASE NARRATIVE

Client : EUROFINS EATON ANALYTICAL

Project: 380-15847

SDG : 22H144

METHOD 3520C/8015B
TOTAL PETROLEUM HYDROCARBONS BY EXTRACTION

One(1) water sample was received on 08/11/22 to be analyzed for Total Petroleum Hydrocarbons by Extraction in accordance with Method 3520C/8015B and project specific requirements.

Holding Time

The sample was analyzed within the prescribed holding time.

Calibration

Multi-calibration points were generated to establish initial calibration (ICAL). ICAL was verified using a secondary source (ICV). Continuing calibration (CCV) verifications were carried out on a frequency specified by the project. All calibration requirements were within acceptance criteria. Refer to calibration summary forms of ICAL, ICV and CCV for details. MRL was analyzed as required by the project. Refer to MRL summary form for details.

Method Blank

Method blank was prepared and analyzed at the frequency required by the project. For this SDG, one(1) method blank was analyzed. DSH022WB - result was compliant to project requirement. Refer to sample result summary form for details.

Lab Control Sample

Lab control sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) LCS was analyzed. Percent recovery for Diesel was within LCS QC limits in DSH022WL. Refer to LCS summary form for details.

Matrix QC Sample

Matrix spike sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) set of MS/MSD was analyzed. Diesel was within MS QC limits in 22H130-01M/22H130-01S. Refer to Matrix QC summary form for details.

Surrogate

Surrogates were added on QC and field samples. All surrogate recoveries were within QC limits. Refer to sample result summary forms for details.

Sample Analysis

The sample was analyzed according to prescribed analytical procedures. Results were evaluated in accordance to project requirements. For this SDG, all quality control requirements were met.

LAB CHRONICLE
TOTAL PETROLEUM HYDROCARBONS BY EXTRACTION

Client : EUROFINS EATON ANALYTICAL
 Project : 380-15847
 SDG NO. : 22H144
 Instrument ID : D5

Client Sample ID	Laboratory Sample ID	Dilution Factor	% Moist	Analysis DateTime	Extraction DateTime	Sample Data FN	Calibration Prep. Data FN	Notes
								WATER
MBLK1W	DSH022WB	1	NA	08/15/2214:24	08/12/2217:00	LH15009A	LH15003A	22DSH022W Method Blank
LCS1W	DSH022WL	1	NA	08/15/2214:42	08/12/2217:00	LH15010A	LH15003A	22DSH022W Lab Control Sample (LCS)
380-15847-1	H144-01	1	NA	08/15/2218:07	08/12/2217:00	LH15021A	LH15003A	22DSH022W Field Sample

FN - Filename
 % Moist - Percent Moisture



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

SAMPLE RESULTS

METHOD 3520C/8015B
TOTAL PETROLEUM HYDROCARBONS BY EXTRACTION

```

=====
Client      : EUROFINS EATON ANALYTICAL   Date Collected: 08/08/22 10:57
Project     : 380-15847                   Date Received: 08/11/22
Batch No.   : 22H144                       Date Extracted: 08/12/22 17:00
Sample ID   : 380-15847-1                 Date Analyzed: 08/15/22 18:07
Lab Samp ID: 22H144-01                     Dilution Factor: 1
Lab File ID: LH15021A                       Matrix: WATER
Ext Btch ID: 22DSH022W                       % Moisture: NA
Calib. Ref.: LH15003A                       Instrument ID: D5
=====

```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)
Diesel	ND	0.024	0.012
Motor Oil	ND	0.048	0.024

SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromobenzene	0.350	0.480	73	60-130
Hexacosane	0.111	0.120	92	60-130

Notes:

Parameter H-C Range
Diesel C10-C24
Motor Oil C24-C36

Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.

Sample Amount : 1040ml Final Volume : 5ml
Prepared by : JMuert Analyzed by : SDeeso

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

QC SUMMARIES

METHOD 3520C/8015B
TOTAL PETROLEUM HYDROCARBONS BY EXTRACTION

```

=====
Client      : EUROFINS EATON ANALYTICAL   Date Collected: 08/12/22 17:00
Project     : 380-15847                   Date Received: 08/12/22
Batch No.   : 22H144                       Date Extracted: 08/12/22 17:00
Sample ID   : MBLK1W                       Date Analyzed: 08/15/22 14:24
Lab Samp ID: DSH022WB                       Dilution Factor: 1
Lab File ID: LH15009A                       Matrix: WATER
Ext Btch ID: 22DSH022W                       % Moisture: NA
Calib. Ref.: LH15003A                       Instrument ID: D5
=====

```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)	
Diesel	ND	0.025	0.012	
Motor Oil	ND	0.050	0.025	
SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromobenzene	0.388	0.500	78	60-130
Hexacosane	0.111	0.125	89	60-130

Notes:

Parameter H-C Range
Diesel C10-C24
Motor Oil C24-C36

Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.

Sample Amount : 1000ml Final Volume : 5ml
Prepared by : JMuert Analyzed by : SDeeso

EMAX QUALITY CONTROL DATA
LAB CONTROL SAMPLE ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
PROJECT : 380-15847
BATCH NO. : 22H144
METHOD : 3520C/8015B

=====

MATRIX	: WATER	% MOISTURE:NA
DILUTION FACTOR:	1	1
SAMPLE ID	: MBLK1W	LCS1W
LAB SAMPLE ID	: DSH022WB	DSH022WL
LAB FILE ID	: LH15009A	LH15010A
DATE PREPARED	: 08/12/22 17:00	08/12/22 17:00
DATE ANALYZED	: 08/15/22 14:24	08/15/22 14:42
PREP BATCH	: 22DSH022W	22DSH022W
CALIBRATION REF:	LH15003A	LH15003A

ACCESSION:

PARAMETERS	MBResult (mg/L)	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	QCLimit (%)
Diesel	ND	2.50	2.58	103	50-130

SURROGATE PARAMETERS	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	QCLimit (%)
Bromobenzene	0.500	0.409	82	60-130
Hexacosane	0.125	0.125	100	60-130

MB: Method Blank sample LCS: Lab Control Sample

EMAX QUALITY CONTROL DATA
MS/MSD ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
PROJECT : 380-15733
BATCH NO. : 22H130
METHOD : 3520C/8015B

MATRIX : WATER		% MOISTURE:NA
DILUTION FACTOR: 1	1	1
SAMPLE ID : 380-15733-1	380-15733-1MS	380-15733-1MSD
LAB SAMPLE ID : 22H130-01	22H130-01M	22H130-01S
LAB FILE ID : LH15013A	LH15014A	LH15015A
DATE PREPARED : 08/12/22 17:00	08/12/22 17:00	08/12/22 17:00
DATE ANALYZED : 08/15/22 15:38	08/15/22 15:57	08/15/22 16:16
PREP BATCH : 22DSH022W	22DSH022W	22DSH022W
CALIBRATION REF: LH15003A	LH15003A	LH15003A

ACCESSION:

PARAMETERS	PSResult (mg/L)	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	RPD (%)	QCLimit (%)	MaxRPD (%)
Diesel	ND	2.97	3.56	120	2.78	3.08	111	14	50-130	30

SURROGATE PARAMETERS	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	QCLimit (%)
Bromobenzene	0.595	0.449	75	0.555	0.384	69	60-130
Hexacosane	0.149	0.139	93	0.139	0.123	89	60-130

PS: Parent Sample MS: Matrix Spike MSD: Matrix Spike Duplicate

August 22, 2022

Debbie Frank
Eurofins Eaton Analytical
750 Royal Oaks Drive
Suite 100
Monrovia, CA 91016-

Project Name: RED-HILL Project # 38001111 Job # 380-15847-1
Physis Project ID: 1407003-271

Dear Debbie,

Enclosed are the analytical results for the sample submitted to PHYSIS Environmental Laboratories, Inc. (PHYSIS) on 8/11/2022. A total of 1 sample was received for analysis in accordance with the attached chain of custody (COC). Per the COC, the sample was analyzed for:

Organics
Polynuclear Aromatic Hydrocarbons by EPA 625.1
Disalicylidenepropanediamine by EPA 625.1
Dibenzo [a,l] Pyrene w/ PAHs by EPA 625.1

Analytical results in this report apply only to samples submitted to PHYSIS in accordance with the COC and are intended to be considered in their entirety.

Please feel free to contact me at any time with any questions. PHYSIS appreciates the opportunity to provide you with our analytical and support services.

Regards,



Misty Mercier
714 602-5320
Extension 202
mistymercier@physislabs.com

PROJECT SAMPLE LIST

Eurofins Eaton Analytical

PHYSIS Project ID: 1407003-271

RED-HILL Project # 38001111 Job # 380-15847-1

Total Samples: 1

PHYSIS ID	Sample ID	Description	Date	Time	Matrix	Sample Type
99171	MOANALUA WELLS	331-223-TP202 (380-15847-1)	8/8/2022	10:57	Samplewater	Not Specified

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

ABBREVIATIONS and ACRONYMS

QM	Quality Manual
QA	Quality Assurance
QC	Quality Control
MDL	method detection limit
RL	reporting limit
R1	project sample
R2	project sample replicate
MS1	matrix spike
MS2	matrix spike replicate
B1	procedural blank
B2	procedural blank replicate
BS1	blank spike
BS2	blank spike replicate
LCS1	laboratory control spike
LCS2	laboratory control spike replicate
LCM1	laboratory control material
LCM2	laboratory control material replicate
CRM1	certified reference material
CRM2	certified reference material replicate
RPD	relative percent difference
LMW	low molecular weight
HMW	high molecular weight

QUALITY ASSURANCE SUMMARY

LABORATORY BATCH: Physis' QM defines a laboratory batch as a group of 20 or fewer project samples of similar matrix, processed together under the same conditions and with the same reagents. QC samples are associated with each batch and were used to assess the validity of the sample analyses.

PROCEDURAL BLANK: Laboratory contamination introduced during method use is assessed through the preparation and analysis of procedural blanks is provided at a minimum frequency of one per batch.

ACCURACY: Accuracy of analytical measurements is the degree of closeness based on percent recovery calculations between measured values and the actual or true value and includes a combination of reproducibility error and systematic bias due to sampling and analytical operations. Accuracy of the project data was indicated by analysis of MS, BS, LCS, LCM, CRM, and/or surrogate spikes on a minimum frequency of one per batch. Physis' QM requires that 95% of the target compounds greater than 10 times the MDL be within the specified acceptance limits.

PRECISION: Precision is the agreement among a set of replicate measurements without assumption of knowledge of the true value and is based on RPD calculations between repeated values. Precision of the project data was determined by analysis of replicate MS₁/MS₂, BS₁/BS₂, LCS₁/LCS₂, LCM₁/LCM₂, CRM₁/CRM₂, surrogate spikes and/or replicate project sample analysis (R₁/R₂) on a minimum frequency of one per batch. Physis' QM requires that for 95% of the compounds greater than 10 times the MDL, the percent RPD should be within the specified acceptance range.

BLANK SPIKES: BS is the introduction of a known concentration of analyte into the procedural blank. BS demonstrates performance of the preparation and analytical methods on a clean matrix void of potential matrix related interferences. The BS is performed in laboratory deionized water, making these recoveries a better indicator of the efficiency of the laboratory method per se.

MATRIX SPIKES: MS is the introduction of a known concentration of analyte into a sample. MS samples demonstrate the effect a particular project sample matrix has on the accuracy of a measurement. Individually, MS samples also indicate the bias of analytical measurements due to chemical interferences inherent in the in the specific project sample spiked. Intrinsic target analyte concentration in the specific project sample can also significantly impact MS recovery.

CERTIFIED REFERENCE MATERIALS: CRMs are materials of various matrices for which analytical information has been determined and certified by a recognized authority. These are used to provide a quantitative assessment of the accuracy of an analytical method. CRMs provide evidence that the laboratory preparation and analysis produces results that are comparable to those obtained by an independent organization.

LABORATORY CONTROL MATERIAL: LCM is provided because a suitable natural seawater CRM is not available and can be used to indicate accuracy of the method. Physis' internal LCM is seawater collected at ~800 meters in the Southern California San Pedro Basin and can be used as a reference for background concentrations in clean, natural seawater for comparison to project samples.

LABORATORY CONTROL SPIKES: LCS is the introduction of a known concentration of analyte into Physis' LCM. LCS samples were employed to assess the effect the seawater matrix has on the accuracy of a measurement. LCS also indicate the bias of this method due to chemical interferences inherent in the in the seawater matrix. Intrinsic LCM concentration can also significantly impact LCS recovery.

SURROGATES: A surrogate is a pure analyte unlikely to be found in any project sample, behaves similarly to

the target analyte and most often used with organic analytical procedures. Surrogates are added in known concentration to all samples and are measured to indicate overall efficiency of the method including processing and analyses.

HOLDING TIME: Method recommended holding times are the length of time a project sample can be stored under specific conditions after collection and prior to analysis without significantly affecting the analyte's concentration. Holding times can be extended if preservation techniques are employed to reduce biodegradation, volatilization, oxidation, sorption, precipitation, and other physical and chemical processes.

SAMPLE STORAGE/RETENTION: In order to maintain chemical integrity prior to analysis, all samples submitted to Physis are refrigerated (liquids) or frozen (solids) upon receipt unless otherwise recommended by applicable methods. Solid samples are retained for 1 year from collection while liquid samples are retained until method recommended holding times elapse.

TOTAL/DISSOLVED FRACTION: In some instances, the results for the dissolved fraction may be higher than the total fraction for a particular analyte (e.g. trace metals). This is typically caused by the analytical variation for each result and indicates that the target analyte is primarily in the dissolved phase, within the sample.

PHYSIS QUALIFIER CODES

CODE	DEFINITION
#	see Case Narrative
ND	analyte not detected at or above the MDL
B	analyte was detected in the procedural blank greater than 10 times the MDL
E	analyte concentration exceeds the upper limit of the linear calibration range, reported value is estimated
H	sample received and/or analyzed past the recommended holding time
J	analyte was detected at a concentration below the RL and above the MDL, reported value is estimated
N	insufficient sample, analysis could not be performed
M	analyte was outside the specified accuracy and/or precision acceptance limits due to matrix interference. The associated B/BS were within limits, therefore the sample data was reported without further clarification
SH	analyte concentration in the project sample exceeded the spike concentration, therefore accuracy and/or precision acceptance limits do not apply
SL	analyte results were lower than 10 times the MDL, therefore accuracy and/or precision acceptance limits do not apply
NH	project sample was heterogeneous and sample homogeneity could not be readily achieved using routine laboratory practices, therefore accuracy and/or precision acceptance limits do not apply
Q	analyte was outside the specified QAPP acceptance limits for precision and/or accuracy but within Physis derived acceptance limits, therefore the sample data was reported without further clarification
R	Physis' QM allows for 5% of the target compounds greater than 10 times the MDL to be outside the specified acceptance limits for precision and/or accuracy. This is often due to random error and does not indicate any significant problems with the analysis of these project samples

CASE NARRATIVE

QUALIFIER NOTES

In addition to the use of analyte specific Physis Qualifier Codes where applicable, the following were also noted.

ND

MDL is listed due to report format restrictions; it is not used in reporting. Analytical results reported are ND at the RL.

BIANALYTICALS

REPORT

TERRA AURA
ENVIRONMENTAL LABORATORIES, INC.

Innovative Solutions for Nature

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

Base/Neutral Extractable Compounds

ANALYTE	Method	Units	RESULT	DF	MDL	RL	Fraction	QA CODE	Batch ID	Date Processed	Date Analyzed
Sample ID: 99171-R1	MOANALUA WELLS 331-223-TP202	Matrix: Samplewater					Sampled: 08-Aug-22 10:57			Received: 11-Aug-22	
Disalicylidenepropanediamine	EPA 625.1	µg/L	ND	1	0.05	0.1	Total		O-38084	15-Aug-22	21-Aug-22



Polynuclear Aromatic Hydrocarbons

ANALYTE	Method	Units	RESULT	DF	MDL	RL	Fraction	QA CODE	Batch ID	Date Processed	Date Analyzed
Sample ID: 99171-R1	MOANALUA WELLS 331-223-TP202 Matrix: Samplewater						Sampled: 08-Aug-22 10:57		Received:	11-Aug-22	
(d10-Acenaphthene)	EPA 625.1	% Recovery	82	1			Total		O-38084	15-Aug-22	21-Aug-22
(d10-Phenanthrene)	EPA 625.1	% Recovery	89	1			Total		O-38084	15-Aug-22	21-Aug-22
(d12-Chrysene)	EPA 625.1	% Recovery	86	1			Total		O-38084	15-Aug-22	21-Aug-22
(d12-Perylene)	EPA 625.1	% Recovery	76	1			Total		O-38084	15-Aug-22	21-Aug-22
(d8-Naphthalene)	EPA 625.1	% Recovery	79	1			Total		O-38084	15-Aug-22	21-Aug-22
1-Methylnaphthalene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total		O-38084	15-Aug-22	21-Aug-22
1-Methylphenanthrene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total		O-38084	15-Aug-22	21-Aug-22
2,3,5-Trimethylnaphthalene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total		O-38084	15-Aug-22	21-Aug-22
2,6-Dimethylnaphthalene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total		O-38084	15-Aug-22	21-Aug-22
2-Methylnaphthalene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total		O-38084	15-Aug-22	21-Aug-22
Acenaphthene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total		O-38084	15-Aug-22	21-Aug-22
Acenaphthylene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total		O-38084	15-Aug-22	21-Aug-22
Anthracene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total		O-38084	15-Aug-22	21-Aug-22
Benz[a]anthracene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total		O-38084	15-Aug-22	21-Aug-22
Benzo[a]pyrene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total		O-38084	15-Aug-22	21-Aug-22
Benzo[b]fluoranthene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total		O-38084	15-Aug-22	21-Aug-22
Benzo[e]pyrene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total		O-38084	15-Aug-22	21-Aug-22
Benzo[g,h,i]perylene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total		O-38084	15-Aug-22	21-Aug-22
Benzo[k]fluoranthene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total		O-38084	15-Aug-22	21-Aug-22
Biphenyl	EPA 625.1	µg/L	ND	1	0.001	0.005	Total		O-38084	15-Aug-22	21-Aug-22
Chrysene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total		O-38084	15-Aug-22	21-Aug-22
Dibenz[a,h]anthracene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total		O-38084	15-Aug-22	21-Aug-22
Dibenzo[a,l]pyrene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total		O-38084	15-Aug-22	21-Aug-22
Dibenzothiophene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total		O-38084	15-Aug-22	21-Aug-22

Polynuclear Aromatic Hydrocarbons

ANALYTE	Method	Units	RESULT	DF	MDL	RL	Fraction	QA CODE	Batch ID	Date Processed	Date Analyzed
Fluoranthene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total		O-38084	15-Aug-22	21-Aug-22
Fluorene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total		O-38084	15-Aug-22	21-Aug-22
Indeno[1,2,3-cd]pyrene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total		O-38084	15-Aug-22	21-Aug-22
Naphthalene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total		O-38084	15-Aug-22	21-Aug-22
Perylene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total		O-38084	15-Aug-22	21-Aug-22
Phenanthrene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total		O-38084	15-Aug-22	21-Aug-22
Pyrene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total		O-38084	15-Aug-22	21-Aug-22



QUALITY CONTROL REPORT

TERRA CONSULTING AURA ENVIRONMENTAL LABORATORIES, INC.

Innovative Solutions for Nature

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

Base/Neutral Extractable Compounds

QUALITY CONTROL REPORT

ANALYTE	FRACTION	RESULT	DF	MDL	RL	UNITS	SPIKE	SOURCE	ACCURACY		PRECISION		QA CODEc
							LEVEL	RESULT	%	LIMITS	%	LIMITS	
Sample ID: 99170-B1		QAQC Procedural Blank			Matrix: BlankMatrix			Sampled:		Received:			
		Method: EPA 625.1			Batch ID: O-38084			Prepared: 15-Aug-22		Analyzed: 20-Aug-22			
Disalicylideneopropanediamine	Total	ND	1	0.05	0.1	µg/L							
Sample ID: 99170-BS1		QAQC Procedural Blank			Matrix: BlankMatrix			Sampled:		Received:			
		Method: EPA 625.1			Batch ID: O-38084			Prepared: 15-Aug-22		Analyzed: 20-Aug-22			
Disalicylideneopropanediamine	Total	18.1	1	0.05	0.1	µg/L	25	0	72	50 - 150%	PASS		
Sample ID: 99170-BS2		QAQC Procedural Blank			Matrix: BlankMatrix			Sampled:		Received:			
		Method: EPA 625.1			Batch ID: O-38084			Prepared: 15-Aug-22		Analyzed: 20-Aug-22			
Disalicylideneopropanediamine	Total	23.3	1	0.05	0.1	µg/L	25	0	93	50 - 150%	PASS	25	30 PASS

Polynuclear Aromatic Hydrocarbons

QUALITY CONTROL REPORT

ANALYTE	FRACTION	RESULT	DF	MDL	RL	UNITS	SPIKE	SOURCE	ACCURACY	PRECISION	QA CODEc
							LEVEL	RESULT	%	LIMITS	%
Sample ID: 99170-B1		QAQC Procedural Blank			Matrix: BlankMatrix		Sampled:		Received:		
		Method: EPA 625.1			Batch ID: O-38084		Prepared: 15-Aug-22		Analyzed: 20-Aug-22		
(d10-Acenaphthene)	Total	92	1			% Recovery	100	92	65 - 113%	PASS	
(d10-Phenanthrene)	Total	93	1			% Recovery	100	93	80 - 111%	PASS	
(d12-Chrysene)	Total	92	1			% Recovery	100	92	60 - 139%	PASS	
(d12-Perylene)	Total	88	1			% Recovery	100	88	36 - 161%	PASS	
(d8-Naphthalene)	Total	88	1			% Recovery	100	88	44 - 119%	PASS	
1-Methylnaphthalene	Total	ND	1	0.001	0.005	µg/L					
1-Methylphenanthrene	Total	ND	1	0.001	0.005	µg/L					
2,3,5-Trimethylnaphthalene	Total	ND	1	0.001	0.005	µg/L					
2,6-Dimethylnaphthalene	Total	ND	1	0.001	0.005	µg/L					
2-Methylnaphthalene	Total	ND	1	0.001	0.005	µg/L					
Acenaphthene	Total	ND	1	0.001	0.005	µg/L					
Acenaphthylene	Total	ND	1	0.001	0.005	µg/L					
Anthracene	Total	ND	1	0.001	0.005	µg/L					
Benz[a]anthracene	Total	ND	1	0.001	0.005	µg/L					
Benzo[a]pyrene	Total	ND	1	0.001	0.005	µg/L					
Benzo[b]fluoranthene	Total	ND	1	0.001	0.005	µg/L					
Benzo[e]pyrene	Total	ND	1	0.001	0.005	µg/L					
Benzo[g,h,i]perylene	Total	ND	1	0.001	0.005	µg/L					
Benzo[k]fluoranthene	Total	ND	1	0.001	0.005	µg/L					
Biphenyl	Total	ND	1	0.001	0.005	µg/L					
Chrysene	Total	ND	1	0.001	0.005	µg/L					
Dibenz[a,h]anthracene	Total	ND	1	0.001	0.005	µg/L					
Dibenzo[a,l]pyrene	Total	ND	1	0.001	0.005	µg/L					
Dibenzothiophene	Total	ND	1	0.001	0.005	µg/L					

Polynuclear Aromatic Hydrocarbons

QUALITY CONTROL REPORT

ANALYTE	FRACTION	RESULT	DF	MDL	RL	UNITS	SPIKE	SOURCE	ACCURACY		PRECISION		QA CODEc
							LEVEL	RESULT	%	LIMITS	%	LIMITS	
Fluoranthene	Total	ND	1	0.001	0.005	µg/L							
Fluorene	Total	ND	1	0.001	0.005	µg/L							
Indeno[1,2,3-cd]pyrene	Total	ND	1	0.001	0.005	µg/L							
Naphthalene	Total	ND	1	0.001	0.005	µg/L							
Perylene	Total	ND	1	0.001	0.005	µg/L							
Phenanthrene	Total	ND	1	0.001	0.005	µg/L							
Pyrene	Total	ND	1	0.001	0.005	µg/L							



Polynuclear Aromatic Hydrocarbons

QUALITY CONTROL REPORT

ANALYTE	FRACTION	RESULT	DF	MDL	RL	UNITS	SPIKE	SOURCE	ACCURACY		PRECISION	QA CODEc
							LEVEL	RESULT	%	LIMITS	%	LIMITS
Sample ID: 99170-BS1		QAQC Procedural Blank			Matrix: BlankMatrix			Sampled:		Received:		
Method: EPA 625.1		Batch ID: O-38084			Prepared: 15-Aug-22		Analyzed: 20-Aug-22					
(d10-Acenaphthene)	Total	87	1			% Recovery	100	0	87	65 - 113%	PASS	
(d10-Phenanthrene)	Total	91	1			% Recovery	100	0	91	80 - 111%	PASS	
(d12-Chrysene)	Total	84	1			% Recovery	100	0	84	60 - 139%	PASS	
(d12-Perylene)	Total	86	1			% Recovery	100	0	86	36 - 161%	PASS	
(d8-Naphthalene)	Total	81	1			% Recovery	100	0	81	44 - 119%	PASS	
1-Methylnaphthalene	Total	0.414	1	0.001	0.005	µg/L	0.5	0	83	49 - 117%	PASS	
1-Methylphenanthrene	Total	0.434	1	0.001	0.005	µg/L	0.5	0	87	66 - 127%	PASS	
2,3,5-Trimethylnaphthalene	Total	0.427	1	0.001	0.005	µg/L	0.5	0	85	57 - 120%	PASS	
2,6-Dimethylnaphthalene	Total	0.413	1	0.001	0.005	µg/L	0.5	0	83	54 - 117%	PASS	
2-Methylnaphthalene	Total	0.41	1	0.001	0.005	µg/L	0.5	0	82	47 - 130%	PASS	
Acenaphthene	Total	0.425	1	0.001	0.005	µg/L	0.5	0	85	53 - 131%	PASS	
Acenaphthylene	Total	0.418	1	0.001	0.005	µg/L	0.5	0	84	43 - 140%	PASS	
Anthracene	Total	0.449	1	0.001	0.005	µg/L	0.5	0	90	58 - 135%	PASS	
Benz[a]anthracene	Total	0.365	1	0.001	0.005	µg/L	0.5	0	73	55 - 145%	PASS	
Benzo[a]pyrene	Total	0.401	1	0.001	0.005	µg/L	0.5	0	80	51 - 143%	PASS	
Benzo[b]fluoranthene	Total	0.446	1	0.001	0.005	µg/L	0.5	0	89	46 - 165%	PASS	
Benzo[e]pyrene	Total	0.427	1	0.001	0.005	µg/L	0.5	0	85	42 - 152%	PASS	
Benzo[g,h,i]perylene	Total	0.444	1	0.001	0.005	µg/L	0.5	0	89	63 - 133%	PASS	
Benzo[k]fluoranthene	Total	0.426	1	0.001	0.005	µg/L	0.5	0	85	56 - 145%	PASS	
Biphenyl	Total	0.422	1	0.001	0.005	µg/L	0.5	0	84	56 - 119%	PASS	
Chrysene	Total	0.384	1	0.001	0.005	µg/L	0.5	0	77	56 - 141%	PASS	
Dibenz[a,h]anthracene	Total	0.407	1	0.001	0.005	µg/L	0.5	0	81	55 - 150%	PASS	
Dibenzo[a,l]pyrene	Total	0.499	1	0.001	0.005	µg/L	0.5	0	100	50 - 150%	PASS	
Dibenzothiophene	Total	0.436	1	0.001	0.005	µg/L	0.5	0	87	75 - 113%	PASS	

Polynuclear Aromatic Hydrocarbons

QUALITY CONTROL REPORT

ANALYTE	FRACTION	RESULT	DF	MDL	RL	UNITS	SPIKE	SOURCE	ACCURACY		PRECISION		QA CODEc
							LEVEL	RESULT	%	LIMITS	%	LIMITS	
Fluoranthene	Total	0.442	1	0.001	0.005	µg/L	0.5	0	88	60 - 146%	PASS		
Fluorene	Total	0.432	1	0.001	0.005	µg/L	0.5	0	86	58 - 131%	PASS		
Indeno[1,2,3-cd]pyrene	Total	0.415	1	0.001	0.005	µg/L	0.5	0	83	50 - 151%	PASS		
Naphthalene	Total	0.402	1	0.001	0.005	µg/L	0.5	0	80	41 - 126%	PASS		
Perylene	Total	0.4	1	0.001	0.005	µg/L	0.5	0	80	48 - 141%	PASS		
Phenanthrene	Total	0.45	1	0.001	0.005	µg/L	0.5	0	90	67 - 127%	PASS		
Pyrene	Total	0.425	1	0.001	0.005	µg/L	0.5	0	85	54 - 156%	PASS		



Polynuclear Aromatic Hydrocarbons

QUALITY CONTROL REPORT

ANALYTE	FRACTION	RESULT	DF	MDL	RL	UNITS	SPIKE	SOURCE	ACCURACY		PRECISION		QA CODEc	
							LEVEL	RESULT	%	LIMITS	%	LIMITS		
Sample ID: 99170-BS2		QAQC Procedural Blank			Matrix: BlankMatrix			Sampled:			Received:			
		Method: EPA 625.1			Batch ID: O-38084			Prepared: 15-Aug-22			Analyzed: 20-Aug-22			
(d10-Acenaphthene)	Total	92	1			% Recovery	100	0	92	65 - 113%	PASS	6	30	PASS
(d10-Phenanthrene)	Total	98	1			% Recovery	100	0	98	80 - 111%	PASS	7	30	PASS
(d12-Chrysene)	Total	88	1			% Recovery	100	0	88	60 - 139%	PASS	5	30	PASS
(d12-Perylene)	Total	95	1			% Recovery	100	0	95	36 - 161%	PASS	10	30	PASS
(d8-Naphthalene)	Total	90	1			% Recovery	100	0	90	44 - 119%	PASS	11	30	PASS
1-Methylnaphthalene	Total	0.442	1	0.001	0.005	µg/L	0.5	0	88	49 - 117%	PASS	6	30	PASS
1-Methylphenanthrene	Total	0.443	1	0.001	0.005	µg/L	0.5	0	89	66 - 127%	PASS	2	30	PASS
2,3,5-Trimethylnaphthalene	Total	0.45	1	0.001	0.005	µg/L	0.5	0	90	57 - 120%	PASS	6	30	PASS
2,6-Dimethylnaphthalene	Total	0.44	1	0.001	0.005	µg/L	0.5	0	88	54 - 117%	PASS	6	30	PASS
2-Methylnaphthalene	Total	0.439	1	0.001	0.005	µg/L	0.5	0	88	47 - 130%	PASS	7	30	PASS
Acenaphthene	Total	0.449	1	0.001	0.005	µg/L	0.5	0	90	53 - 131%	PASS	6	30	PASS
Acenaphthylene	Total	0.449	1	0.001	0.005	µg/L	0.5	0	90	43 - 140%	PASS	7	30	PASS
Anthracene	Total	0.427	1	0.001	0.005	µg/L	0.5	0	85	58 - 135%	PASS	6	30	PASS
Benz[a]anthracene	Total	0.387	1	0.001	0.005	µg/L	0.5	0	77	55 - 145%	PASS	5	30	PASS
Benzo[a]pyrene	Total	0.447	1	0.001	0.005	µg/L	0.5	0	89	51 - 143%	PASS	11	30	PASS
Benzo[b]fluoranthene	Total	0.472	1	0.001	0.005	µg/L	0.5	0	94	46 - 165%	PASS	5	30	PASS
Benzo[e]pyrene	Total	0.453	1	0.001	0.005	µg/L	0.5	0	91	42 - 152%	PASS	7	30	PASS
Benzo[g,h,i]perylene	Total	0.465	1	0.001	0.005	µg/L	0.5	0	93	63 - 133%	PASS	4	30	PASS
Benzo[k]fluoranthene	Total	0.468	1	0.001	0.005	µg/L	0.5	0	94	56 - 145%	PASS	10	30	PASS
Biphenyl	Total	0.455	1	0.001	0.005	µg/L	0.5	0	91	56 - 119%	PASS	8	30	PASS
Chrysene	Total	0.4	1	0.001	0.005	µg/L	0.5	0	80	56 - 141%	PASS	4	30	PASS
Dibenz[a,h]anthracene	Total	0.439	1	0.001	0.005	µg/L	0.5	0	88	55 - 150%	PASS	8	30	PASS
Dibenzo[a,l]pyrene	Total	0.512	1	0.001	0.005	µg/L	0.5	0	102	50 - 150%	PASS	2	30	PASS
Dibenzothioophene	Total	0.461	1	0.001	0.005	µg/L	0.5	0	92	75 - 113%	PASS	6	30	PASS

Polynuclear Aromatic Hydrocarbons

QUALITY CONTROL REPORT

ANALYTE	FRACTION	RESULT	DF	MDL	RL	UNITS	SPIKE	SOURCE	ACCURACY		PRECISION		QA CODEc	
							LEVEL	RESULT	%	LIMITS	%	LIMITS		
Fluoranthene	Total	0.459	1	0.001	0.005	µg/L	0.5	0	92	60 - 146%	PASS	4	30	PASS
Fluorene	Total	0.449	1	0.001	0.005	µg/L	0.5	0	90	58 - 131%	PASS	5	30	PASS
Indeno[1,2,3-cd]pyrene	Total	0.442	1	0.001	0.005	µg/L	0.5	0	88	50 - 151%	PASS	6	30	PASS
Naphthalene	Total	0.437	1	0.001	0.005	µg/L	0.5	0	87	41 - 126%	PASS	8	30	PASS
Perylene	Total	0.428	1	0.001	0.005	µg/L	0.5	0	86	48 - 141%	PASS	7	30	PASS
Phenanthrene	Total	0.47	1	0.001	0.005	µg/L	0.5	0	94	67 - 127%	PASS	4	30	PASS
Pyrene	Total	0.443	1	0.001	0.005	µg/L	0.5	0	89	54 - 156%	PASS	5	30	PASS

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

PHYSIS

TENTATIVELY

IDENTIFIED COMPOUNDS

ENVIRONMENTAL LABORATORIES, INC.

Innovative Solutions for Nature

Sample ID: 99171

RT	Area Pct	Concentration (ng/L)	Library/ID	Cas Number	Match Qual
31.6302	4.9138	1111	Anthracene-D10-	1719-06-8	96
42.1415	1.3243	299	Terephthalic acid, isobutyl butyl ester	1000323-56-2	96
14.3859	0.6984	158	Cyclohexane, 1,2,4,5-tetraethyl-, (1.alpha.,2.alpha.,4.alpha.,5.alpha.)-	61142-24-3	82
14.3858	0.6774	153	3-Hexene, 3-ethyl-2,5-dimethyl-	62338-08-3	82
63.5230	0.4405	100	1,4-Benzenedicarboxylic acid, bis(2-ethylhexyl) ester	6422-86-2	96

Concentration estimated using the response for Anthracene-d10

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

Sample ID: Lab Blank Batch O-38084

RT	Area Pct	Concentration (ng/L)	Library/ID	Cas Number	Match Qual
31.6482	4.7930	1111	Anthracene-D10-	1719-06-8	95
42.1583	1.5901	369	Terephthalic acid, isobutyl butyl ester	1000323-56-2	95
14.3915	0.6801	158	3-Hexene, 3-ethyl-2,5-dimethyl-	62338-08-3	83
63.5413	0.4564	106	1,4-Benzenedicarboxylic acid, bis(2-ethylhexyl) ester	6422-86-2	95

Concentration estimated using the response for Anthracene-d10

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

PERFORMANCE CHAIN OF CUSTODY

TERRA ENVIRONMENTAL LABORATORIES, INC. AURA

Innovative Solutions for Nature

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

Project Iteration ID: 1407003-271
 Client Name: Eurofins Eaton Analytical
 Project Name: RED-HILL Project # 38001111
 Job # 380-15847-1
 COC Page Number: 2 of 2
 Bottle Label Color: NA

Sample Receipt Summary

Receiving Info

1. Initials Received By: RGH
2. Date Received: 8/11
3. Time Received: 1702
4. Client Name: Eurofins
5. Courier Information: (Please circle)
 - Client
 - UPS
 - Area Fast
 - DRS
 - FedEx
 - GSO/GLS
 - Ontrac
 - PAMS
 - PHYSIS Driver:
 - i. Start Time: _____
 - ii. End Time: _____
 - iii. Total Mileage: _____
 - iv. Number of Pickups: _____
6. Container Information: (Please put the # of containers or circle none)
 - Cooler
 - Styrofoam Cooler
 - Boxes
 - None
 - Carboy(s)
 - Carboy Trash Can(s)
 - Carboy Cap(s)
 - Other _____
7. What type of ice was used: (Please circle any that apply)
 - Wet Ice
 - Blue Ice
 - Dry Ice
 - Water
 - None
8. Randomly Selected Samples Temperature (°C): 6.3
 Used I/R Thermometer # 1-2

Inspection Info

1. Initials Inspected By: RGH

Sample Integrity Upon Receipt:

1. COC(s) included and completely filled out..... Yes / No
2. All sample containers arrived intact..... Yes / No
3. All samples listed on COC(s) are present..... Yes / No
4. Information on containers consistent with information on COC(s)..... Yes / No
5. Correct containers and volume for all analyses indicated..... Yes / No
6. All samples received within method holding time..... Yes / No
7. Correct preservation used for all analyses indicated..... Yes / No
8. Name of sampler included on COC(s)..... Yes / No

Notes:

See Temp

Shipping Order Form - Bottle Order



Environment Testing
America



Monrovia, CA (Suite 100)
750 Royal Oaks Drive Suite 100
Monrovia, CA 91016
Phone (626) 386-1100

Shipping Order ID: 9747

Ship Via: FedEx
When To Ship: 7/25/2022

Due On: 7/25/2022 11:59:00PM
Due After: 7/25/2022 12:00:00 AM

Ship To Information

Project Manager: Debbie Frank
Em: Debbie.Frank@et.eurofinsus.com
Company Name: City & County of Honolulu
Attention: Erwin Kawata
Address 1: 630 South Beretania Street
Address 2: Public Service Bldg. Room 308
Address 3:
City: Honolulu
State: HI
Zip: 96843
Phone #: +1-808-748-5841
Project Ref: RED-HILL
Event Desc: RUSH Weekly Red Hill

Notes to Bottle/Shipping Department

Pack with Gel Ice
Label the cooler under the left hand handle with the ID of the samples that are in the cooler (Print extra set of labels to use for this)
Send only medium to large coolers

Shipping Method: Individual sample per cooler (affixed TALS labels)

- | | |
|--|---|
| <input checked="" type="checkbox"/> Ready to Fill | <input type="checkbox"/> Return Shipment Labels |
| <input checked="" type="checkbox"/> Preprinted COC | <input type="checkbox"/> Prepaid Return |
| <input type="checkbox"/> <input type="text" value="1"/> Number of COC Copies | Monrovia, CA (Suite 100) |
| <input type="checkbox"/> Seals on Bottle | <input type="checkbox"/> Short Hold Times |
| <input type="checkbox"/> Seals on Coolers | <input checked="" type="checkbox"/> Temperature Control |
| <input type="checkbox"/> Priority | <input type="checkbox"/> Rush |

Please notify your PM immediately if an error is found in shipment. When returning samples, please return all provided QC samples.

Shipping Assets

Assets	Quantity	Description	Filled
Gel Ice	1	Fill Coolers Accordingly Please	<input type="checkbox"/>

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

Please notify your PM immediately if an error is found in shipment. When returning samples, please return all provided QC samples.

Bottle Order Information

Bottle Order: RUSH RED-HILL WEEKLY
 Bottle Order #: 2757
 Request From Client: 7/20/2022
 Date Order Posted: 7/20/2022 11:12:54AM
 Order Status: Ready To Process
 Prepared By: Davis Haley
 Deliver By Date: 7/25/2022 11:59:00PM
 Lab Project Number: 38001111
 PWSID: HI0000331

Order Completion Information

Creator: Davis Haley
 Filled by:
 Sent Date:
 Sent Via:
 Tracking #:

Sets	Bottles/Set	Qty	Bottle Type Description	Preservative	Method	Matrix	Sample Type	Comments	Lot #
6	4	24	Amber Glass 1 liter - Sodium Thiosulfate	Sodium Thiosulfate	SUBCONTRACT - 625 PAH Physis LL (EAL) + TICs	Water	Normal	625 PAH + MS/MSD Volume	
6	4	24	Voa Vial 40ml - SodiumThio w/HCl-dropper	Sodium Thiosulfate	SUBCONTRACT - 8015 Gas (Purgeable) LL (EAL)	Water	Normal		
6	2	12	Amber Glass 1 L - NaThiosulfate 8mL HCL	Sodium Thiosulfate/Hydrochloric Acid	SUBCONTRACT - 8015 Diesel LL (EAL) and Motor Oil	Water	Normal		
6	2	12	Amber Glass 1 Liter- Sodium Sulfite/HCl	Sodium Sulfite w/HCl	525.2_PREC - (MOD) 525plus Plus TICs	Water	Normal		
6	-0- 2 0	0	VOA Vial 40mL - NaThiosulfate/HCL	Sodium Thiosulfate/Hydrochloric Acid	SUBCONTRACT - 8015 Gas (Purgeable) LL (EAL)	Water	Trip Blank		

Total Bottle Summary

Bottle Type Description	Preservative	Bottle Count
Amber Glass 1 L - NaThiosulfate 8mL HCL	Sodium Thiosulfate/Hydrochloric Acic	12
Amber Glass 1 liter - Sodium Thiosulfate	Sodium Thiosulfate	24
Amber Glass 1 Liter- Sodium Sulfite/HCl	Sodium Sulfite w/HCl	12
VOA Vial 40mL - NaThiosulfate/HCL	Sodium Thiosulfate/Hydrochloric Acic	0
Voa Vial 40ml - SodiumThio w/HCl-dropper	Sodium Thiosulfate	24
Total Bottles:		<u>72</u>

Please notify your PM immediately if an error is found in shipment. When returning samples, please return all provided QC samples.

Notes to Field Staff:



Scan QR code for field sampler instructions

SAMPLER FOLLOW 2 STAGE FIELD PRESERVATION FOR 8015 and 525.2


Health and Safety Notes:

Preservative	Comment
Sodium Sulfite w/HCl	CAUTION! CONTAINS SODIUM SULFITE. Harmful if inhaled. Use adequate ventilation. Avoid skin and eye contact. If contact is made, FLUSH IMMEDIATELY with water.
Sodium Thiosulfate	CAUTION! CONTAINS 10% SODIUM THIOSULFATE. Harmful if inhaled. Use adequate ventilation. Avoid skin and eye contact. If contact is made, FLUSH IMMEDIATELY with water.
Sodium Thiosulfate/Hydrochloric Acid	CAUTION! CONTAINS 10% SODIUM THIOSULFATE. Harmful if inhaled. Use adequate ventilation. Avoid skin and eye contact. If contact is made, FLUSH IMMEDIATELY with water. Contains 13.3% Monochloroacetic Acid. Avoid skin and eye contact. If contact is made, FLUSH IMMEDIATELY with water. CAUTION! CONTAINS 1:1 HYDROCHLORIC ACID. Avoid skin and eye contact. If contact is made, FLUSH IMMEDIATELY with water.

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

Relinquished By	Company	Date	Time	Received By	Company	Seal #: Seal #: Seal #:
Relinquished By	Company	Date	Time	Received By	Company	Seal #: Seal #: Seal #:

Please notify your PM immediately if an error is found in shipment. When returning samples, please return all provided QC samples.



Eaton Analytical

INTERNAL CHAIN OF CUSTODY RECORD

EBA Folder Number: _____

SAMPLE TEMP RECEIVED:
Note: If sampler are out of temperature range, let the ASMs know. ASMs will determine whether to proceed with analysis or not.
SAMPLES REC'D DAY OF COLLECTION? Yes / No

IR Gun ID = 401 (Observation = 1.2 °C) (Corr. Factor 0.1 °C) (Final = 1.1 °C)

TYPE OF ICE: Real _____ Synthetic No Ice _____ CONDITION OF ICE: Frozen _____ Partially Frozen Thawed _____ N/A _____

METHOD OF SHIPMENT: Pick-Up / Walk-in / FedEx / UPS / DHL / Area Fast / Top Line / Other: _____

Compliance Acceptance Criteria: 7776 1799 6231

- 1) Chemistry: >0, ≤ 6°C, not frozen (NELAP) (if received after 24 hrs of sample collection)
- 2) Microbiology, Distribution: < 10°C, not frozen (can be ≥ 10°C if received on ice the same day as sample collection, within 8 hours)
- 3) Microbiology, Surface Water: < 10°C (if received after 2 hours of sample collection)

If out of temperature range for both Chemistry and Microbiology samples and temperature does not confirm, then measure the temperature of each quadrant and record each temperature of the quadrants

1 = (Observation = _____ °C) (Corr. Factor _____ °C) (Final = _____ °C)	2 = (Observation = _____ °C) (Corr. Factor _____ °C) (Final = _____ °C)
3 = (Observation = _____ °C) (Corr. Factor _____ °C) (Final = _____ °C)	4 = (Observation = _____ °C) (Corr. Factor _____ °C) (Final = _____ °C)

4 Dioxin (1813 or 2,3,7,8 TCDD): must be between 0-4 °C, not frozen (if received after 24 hrs of sample collection)

5) pH Check, Manufacturer: _____ Lot Number: _____ pH strip type: 0 - 14 or _____ Expiration Date _____ Results: _____

6) Chlorine check, Manufacturer: Sansafe, Lot No.: _____ Expiration Date: _____ Results: _____

7) VOA and Radon Headspace: No Samples with Headspace: Samples with Headspace (see below):


Headspace Documentation (use additional VOC and Radon Internal COFC for additional bottles)

Exempt from headspace concerns: Methods 816.4, HAA(8261,852), 808, SPME, @CH, 832LCMS, 858, 838, Anatoxin, LCMS methods using 40 ml vials, International Olanzas

Samp ID	Bottle #	None/<8 mm	>8mm	Test	Samp ID	Bottle #	None/<8 mm	>8mm	Test	Samp ID	Bottle #	None/<8 mm	>8mm	Test	Samp ID	Bottle #	None/<8 mm	>8mm	Test	

Note: Sample IDs which have dissimilar headspace (i.e. potential sampling errors): _____

SIGNATURE <u>[Signature]</u>	PRINT NAME <u>R. Rodo</u>	COMPANY/TITLE <u>Eurofins Eaton Analytical</u>	DATE <u>8/10/22</u>	TIME <u>10:20</u>
SIGNATURE <u>[Signature]</u>	PRINT NAME <u>G. REITNER</u>	COMPANY/TITLE <u>Eurofins Eaton Analytical</u>	DATE <u>08/10/2022</u>	TIME <u>16:45</u>



Eaton Analytical

INTERNAL CHAIN OF CUSTODY RECORD

EEA Folder Number: _____

SAMPLE TEMP RECEIVED:

Note: If samples are out of temperature range, let the ASMs know. ASMs will determine whether to proceed with analysis or not.

SAMPLES REC'D DAY OF COLLECTION? Yes / No

IR Gun ID = 630A (Observation = 3.5 °C) (Corr. Factor 0.2 °C) (Final = 3.3 °C)

TYPE OF ICE: Real _____ Synthetic No Ice _____ CONDITION OF ICE: Frozen Partially Frozen _____ Thawed _____ N/A _____

METHOD OF SHIPMENT: Pick-Up / Walk-in / FedEx / UPS / DHL / Area Fast / Top Line / Other: _____

Compliance Acceptance Criteria:

7776 1799 6210

- 1) Chemistry: >0, ≤ 8°C, not frozen (NELAP) (if received after 24 hrs of sample collection)
- 2) Microbiology, Distribution: < 10°C, not frozen (can be ≥ 10°C if received on ice the same day as sample collection, within 8 hours)
- 3) Microbiology, Surface Water: < 10°C (if received after 2 hours of sample collection)

If out of temperature range for both Chemistry and Microbiology samples and temperature does not confirm, then measure the temperature of each quadrant and record each temperature of the quadrants

1 = (Observation = _____ °C) (Corr. Factor _____ °C) (Final = _____ °C)	2 = (Observation = _____ °C) (Corr. Factor _____ °C) (Final = _____ °C)
3 = (Observation = _____ °C) (Corr. Factor _____ °C) (Final = _____ °C)	4 = (Observation = _____ °C) (Corr. Factor _____ °C) (Final = _____ °C)

4 Dioxin (1613 or 2,3,7,8 TCDD): must be between 0-4 °C, not frozen (if received after 24 hrs of sample collection)

5) pH Check. Manufacturer: _____ Lot Number: _____ pH strip type: 0 - 14 or _____ Expiration Date: _____ Results: _____

6) Chlorine check. Manufacturer: Samsafe. Lot No.: _____ Expiration Date: _____ Results: _____

7) VOA and Radon Headspace:

No Samples with Headspace:

Samples with Headspace (see below):

Headspace Documentation (use additional VOA and Radon Internal COFC for additional bottles)

Exempt from headspace concerns: Methods 815.4, HAA (8251, 852), 805, SPME, @CH, 892LCMS, 858, 838, Anatoxin, LCMS methods using 40 ml vials, International clients:

Samp ID	Bottle #	None/<8 mm	>8mm	Test


Samp ID	Bottle #	None/<8 mm	>8mm	Test

Samp ID	Bottle #	None/<8 mm	>8mm	Test

Samp ID	Bottle #	None/<8 mm	>8mm	Test

Note Sample IDs which have dissimilar headspace (i.e. potential sampling errors): _____

RECEIVED BY: <u>Manna</u>	SIGNATURE: <u>Mark Urrutia</u>	PRINT NAME: <u>Mark Urrutia</u>	COMPANY/TITLE: <u>Eurofins Eaton Analytical</u>	DATE: <u>8/10/22</u>	TIME: <u>10:20</u>
SAMPLES CHECKED AGAINST DOC BY: <u>[Signature]</u>	SIGNATURE: <u>G. REUTNER</u>	PRINT NAME: <u>G. REUTNER</u>	COMPANY/TITLE: <u>Eurofins Eaton Analytical</u>	DATE: <u>08/10/2022</u>	TIME: <u>16:45</u>



Eaton Analytical

INTERNAL CHAIN OF CUSTODY RECORD

EEA Folder Number: _____

SAMPLE TEMP RECEIVED:

Note: If samples are out of temperature range, let the ASMs know. ASMs will determine whether to proceed with analysis or not.

SAMPLES REC'D DAY OF COLLECTION? Yes / No

IR Gun ID = 6498 (Observation = 35 °C) (Corr. Factor = 1.3 °C) (Final = 3.2 °C)

TYPE OF ICE: Real _____ Synthetic ✓ No Ice _____ CONDITION OF ICE: Frozen ✓ Partially Frozen _____ Thawed _____ N/A _____

METHOD OF SHIPMENT: Pick-Up / Walk-In / FedEx / UPS / DHL / Area Fast / Top Line / Other: _____

Compliance Acceptance Criteria:

7776 1859 1810

- 1) Chemistry: >0, ≤ 6°C, not frozen (NELAP) (if received after 24 hrs of sample collection)
- 2) Microbiology, Distribution: < 10°C, not frozen (can be ≥ 10°C if received on ice the same day as sample collection, within 8 hours)
- 3) Microbiology, Surface Water: < 10°C (if received after 2 hours of sample collection)

If out of temperature range for both Chemistry and Microbiology samples and temperature does not confirm, then measure the temperature of each quadrant and record each temperature of the quadrants

1 = (Observation = _____ °C) (Corr. Factor _____ °C) (Final = _____ °C)	2 = (Observation = _____ °C) (Corr. Factor _____ °C) (Final = _____ °C)
3 = (Observation = _____ °C) (Corr. Factor _____ °C) (Final = _____ °C)	4 = (Observation = _____ °C) (Corr. Factor _____ °C) (Final = _____ °C)

4) Dioxin (1813 or 2,3,7,8 TCDD): must be between 0-4 °C, not frozen (if received after 24 hrs of sample collection)

5) pH Check. Manufacturer: _____ Lot Number: _____ pH strip type: 0 - 14 or _____ Expiration Date _____ Results: _____

6) Chlorine check. Manufacturer: Sansafe. Lot No.: _____ Expiration Date: _____ Results: _____

7) VOA and Radon Headspace: No Samples with Headspace: Samples with Headspace (see below):

Headspace Documentation (use additional VOC and Radon Internal COFC for additional bottles)

Exempt from headspace concerns: Methods 815.4, HAA(6251,552), 505, SPME, @CH, 532LCMS, 558, 536, Anatoxin, LCMS methods using 40 ml vials, international clients:


Samp ID	Bottle #	None/<8 mm	>8mm	Test	Samp ID	Bottle #	None/<8 mm	>8mm	Test	Samp ID	Bottle #	None/<8 mm	>8mm	Test	Samp ID	Bottle #	None/<8 mm	>8mm	Test	

Note Sample IDs which have dissimilar headspace (i.e. potential sampling errors): _____

SIGNATURE	PRINT NAME	COMPANY/TITLE	DATE	TIME
<u>[Signature]</u>	<u>FLIET CHOU</u>	Eurofins Eaton Analytical	<u>2-10-22</u>	<u>10:20</u>

SIGNATURE	PRINT NAME	COMPANY/TITLE	DATE	TIME
<u>[Signature]</u>	<u>G. REITNER</u>	Eurofins Eaton Analytical	<u>02/10/2022</u>	<u>16:45</u>





Eaton Analytical

INTERNAL CHAIN OF CUSTODY RECORD

EEA Folder Number: _____

SAMPLE TEMP RECEIVED:

Note: If samples are out of temperature range, let the ASMs know. ASMs will determine whether to proceed with analysis or not.

SAMPLES REC'D DAY OF COLLECTION? Yes No

IR Gun ID = 631A (Observation = 3.7 °C) (Corr. Factor = -0.2 °C) (Final = 3.5 °C)

TYPE OF ICE: Real Synthetic No Ice CONDITION OF ICE: Frozen Partially Frozen Thawed N/A

METHOD OF SHIPMENT: Pick-Up / Walk-In / FedEx / UPS / DHL / Area Fast / Top Line / Other: _____

Compliance Acceptance Criteria:

7776 1799 6996

- 1) Chemistry: >0, ≤ 6°C, not frozen (NELAP) (if received after 24 hrs of sample collection)
- 2) Microbiology, Distribution: < 10°C, not frozen (can be ≥ 10°C if received on ice the same day as sample collection, within 8 hours)
- 3) Microbiology, Surface Water: < 10°C (if received after 2 hours of sample collection)

If out of temperature range for both Chemistry and Microbiology samples and temperature does not confirm, then measure the temperature of each quadrant and record each temperature of the quadrants

1 = (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)	2 = (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)
3 = (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)	4 = (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)

4 Dioxin (1,2,3,7,8 TCDD): must be between 0-4 °C, not frozen (if received after 24 hrs of sample collection)

5) pH Check. Manufacturer: _____ Lot Number: _____ pH strip type: 0 - 14 or _____ Expiration Date: _____ Results: _____

6) Chlorine check. Manufacturer: Sansafe. Lot No.: _____ Expiration Date: _____ Results: _____

7) VOA and Radon Headspace:

No Samples with Headspace:

Samples with Headspace (see below):


Headspace Documentation (use additional VOC and Radon Internal COFC for additional bottles)

Exempt from headspace concerns: Methods 815.4, HAA (8251, 852), 805, SPME, @OH, 832LCMS, 855, 838, Anatoxin, LCMS methods using 40 ml vials, International clients:

Samp ID	Bottle #	None/<8 mm	>8mm	Test	Samp ID	Bottle #	None/<8 mm	>8mm	Test	Samp ID	Bottle #	None/<8 mm	>8mm	Test	Samp ID	Bottle #	None/<8 mm	>8mm	Test	

Note Sample IDs which have dissimilar headspace (i.e. potential sampling errors): _____

RECEIVED BY:	SIGNATURE	PRINT NAME	COMPANY/TITLE	DATE	TIME
		Jeremy Hanson	Eurofins Eaton Analytical	8.10.22	10:20
SAMPLES CHECKED AGAINST COC BY:	SIGNATURE	PRINT NAME	COMPANY/TITLE	DATE	TIME
		GRETNER	Eurofins Eaton Analytical	08/10/2022	16:45



Eaton Analytical

INTERNAL CHAIN OF CUSTODY RECORD

EEA Folder Number:

SAMPLE TEMP RECEIVED:

Note: If samples are out of temperature range, let the ASMs know. ASMs will determine whether to proceed with analysis or not.

SAMPLES REC'D DAY OF COLLECTION? Yes / No

IR Gun ID = 618A (Observation = 4.3 °C) (Corr. Factor -0.1 °C) (Final = 4.2 °C)

TYPE OF ICE: Real Synthetic No Ice CONDITION OF ICE: Frozen Partially Frozen Thawed N/A

METHOD OF SHIPMENT: Pick-Up / Walk-In / FedEx / UPS / DHL / Area Fast / Top Line / Other: _____

Compliance Acceptance Criteria:

7776 1799 5441

- 1) Chemistry: >0, ≤ 6°C, not frozen (NELAP) (if received after 24 hrs of sample collection)
- 2) Microbiology, Distribution: < 10°C, not frozen (can be ≥ 10°C if received on ice the same day as sample collection, within 8 hours)
- 3) Microbiology, Surface Water: < 10°C (if received after 2 hours of sample collection)

If out of temperature range for both Chemistry and Microbiology samples and temperature does not confirm, then measure the temperature of each quadrant and record each temperature of the quadrants

1 = (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)	2 = (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)
3 = (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)	4 = (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)

4 Dioxin (1813 or 2,3,7,8 TCDD): must be between 0-4 °C, not frozen (if received after 24 hrs of sample collection)

5) pH Check. Manufacturer: _____ Lot Number: _____ pH strip type: 0 - 14 or _____ Expiration Date _____ Results: _____

6) Chlorine check. Manufacturer: Sansafe. Lot No.: _____ Expiration Date: _____ Results: _____

7) VOA and Radon Headspace:

No Samples with Headspace:

Samples with Headspace (see below):


Headspace Documentation (use additional VOG and Radon Internal COFC for additional bottles)

Exempt from headspace concerns: Methods 815.4, HAA (8251, 822), 806, SPME, @GH, 832LCMS, 859, 838, Anatoxin, LCMS methods using 40 ml vials, international clients:

Samp ID	Bottle #	None/<8 mm	>8mm	Test	Samp ID	Bottle #	None/<8 mm	>8mm	Test	Samp ID	Bottle #	None/<8 mm	>8mm	Test	Samp ID	Bottle #	None/<8 mm	>8mm	Test	

Note Sample IDs which have dissimilar headspace (i.e. potential sampling errors): _____

SIGNATURE	PRINT NAME	COMPANY/TITLE	DATE	TIME
	YUDI	Eurofins Eaton Analytical	8/10/22	10:20
	G. REITNER	Eurofins Eaton Analytical	08/10/2022	16:45



Eaton Analytical

INTERNAL CHAIN OF CUSTODY RECORD

EEA Folder Number: _____

SAMPLE TEMP RECEIVED:
Notes: If sampler srs out of temperature range, let the ASMs know. ASMs will determine whether to proceed with analysis or not.
SAMPLES REC'D DAY OF COLLECTION? Yes / No

IR Gun ID = 6307 (Observation = 4.9 °C) (Corr. Factor 0.2 °C) (Final = 4.7 °C)

TYPE OF ICE: Real _____ Synthetic No Ice _____ CONDITION OF ICE: Frozen Partially Frozen _____ Thawed _____ N/A _____

METHOD OF SHIPMENT: Pick-Up / Walk-In / FedEx / UPS / DHL / Area Fast / Top Line / Other: _____

Compliance Acceptance Criteria:

7776 1799 5360

- 1) Chemistry: >0, ≤8°C, not frozen (NELAP) (if received after 24 hrs of sample collection)
- 2) Microbiology, Distribution: < 10°C, not frozen (can be ≥10°C if received on ice the same day as sample collection, within 8 hours)
- 3) Microbiology, Surface Water: < 10°C (if received after 2 hours of sample collection)

If out of temperature range for both Chemistry and Microbiology samples and temperature does not confirm, then measure the temperature of each quadrant and record each temperature of the quadrants

1 = (Observation = _____ °C) (Corr. Factor _____ °C) (Final = _____ °C)	2 = (Observation = _____ °C) (Corr. Factor _____ °C) (Final = _____ °C)
3 = (Observation = _____ °C) (Corr. Factor _____ °C) (Final = _____ °C)	4 = (Observation = _____ °C) (Corr. Factor _____ °C) (Final = _____ °C)

4 Dioxin (1613 or 2,3,7,8 TCDD): must be between 0-4 °C, not frozen (if received after 24 hrs of sample collection)

5) pH Check. Manufacturer: _____ Lot Number: _____ pH strip type: 0 - 14 or _____ Expiration Date _____ Results: _____

6) Chlorine check. Manufacturer: Sansafe. Lot No.: _____ Expiration Date: _____ Results: _____

7) VOA and Radon Headspace:

No Samples with Headspace:

Samples with Headspace (see below):

Headspace Documentation (use additional VOC and Radon Internal COFC for additional bottles)

Exempt from headspace concerns: Methods 515.4, HAA(5251,552), 505, SPME, @OH, 532LOMS, 555, 536, Anatoxin, LCMS methods using 40 ml vials, International clients:

Samp ID	Bottle #	None/<8 mm	>8mm	Test	Samp ID	Bottle #	None/<8 mm	>8mm	Test	Samp ID	Bottle #	None/<8 mm	>8mm	Test	Samp ID	Bottle #	None/<8 mm	>8mm	Test	

Note Sample IDs which have dissimilar headspace (i.e. potential sampling errors): _____

RECEIVED BY: <u>Mark Urcutia</u>	SIGNATURE: <u>Mark Urcutia</u>	PRINT NAME: <u>Mark Urcutia</u>	COMPANY/TITLE: <u>Eurofins Eaton Analytical</u>	DATE: <u>8/10/22</u>	TIME: <u>1020</u>
SAMPLES CHECKED AGAINST DOG BY: <u>G. REITNER</u>	SIGNATURE: <u>G. REITNER</u>	PRINT NAME: <u>G. REITNER</u>	COMPANY/TITLE: <u>Eurofins Eaton Analytical</u>	DATE: <u>08/10/2022</u>	TIME: <u>1645</u>

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-15847-1

Login Number: 15847

List Source: Eurofins Eaton Monrovia

List Number: 1

Creator: Do, Michelle

Question	Answer	Comment
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	

