

07 September 2021

MEMORANDUM

From: Technical Director, Naval Facilities Engineering and Expeditionary Warfare Center
To: (b) (6), Navy Petroleum Office

Subj: RED HILL FUEL FACILITY PIPELINE FAILURE FULL SYSTEM INTEGRITY REPORT

Encl: (1) Contractor's Root Cause Analysis dtd 07 September 2021

1. In support of the Navy Petroleum Office investigation of the pipeline failure at the Red Hill Fuel Facility on 06 May 2021, Naval Facilities Engineering and Expeditionary Warfare Center (NAVFAC EXWC) deployed a team of civilian and contractor subject matter experts to: objectively assess the event; provide recommendations to assist in returning the facility to full operability; and determine the cause of the failure.

2. NAVFAC's technical authority personnel with warranting and subject matter expertise over POL infrastructure have reviewed the Root Cause Analysis (enclosure), and concur with the findings.

3. NAVFAC EXWC's next deliverable is the Recommended Repair List. This deliverable will provide corrective recommendations to the JP-5 system and is scheduled for delivery on 14 September 2021.

4. If you have any questions on this report or following actions, my point of contact for this effort is (b) (6) (b) (6) (b) (6).

(b) (6)



ROOT CAUSE ANALYSIS OF THE JP-5 PIPELINE DAMAGE

ASSESS TANK 20 PIPING FOR RETURN TO SERVICE
AT RED HILL BULK FUEL STORAGE FACILITY

JOINT BASE PEARL HARBOR-HICKAM (JBPHH), HONOLULU, HI

Prepared for:



1000 23rd Avenue
Port Hueneme, CA 93043

Final

Submitted by:

(b) (6)

A large black rectangular redaction box covering the name of the submitter.

Austin Brockenbrough & Associates, LLC
1011 Boulder Springs Drive, Suite 200
Richmond, Virginia 23225
804.592.3900

September 7, 2021

<u>ACRONYM</u>	<u>DEFINITION</u>
AFHE	Automated Fuel Handling Equipment
ASME	American Society of Mechanical Engineers
ASTM	American Society for Testing and Materials
bbl	Barrel(s)
DBB	Double Block and Bleed
EXWC	Engineering and Expeditionary Warfare Center
FLC	Fleet Logistics Center
JBPHH	Joint Base Pearl Harbor-Hickam
JP-5	Jet Fuel
lbf	Pound Force
lbs	Pounds
MOV	Motor Operated Valve
NAVFAC	Naval Facilities Engineering Command
NC	Normally Closed
NFPA	National Fire Protection Agency
NIWC	Naval Information Warfare Center
NO	Normally Open
PIT	Pressure Indicating Transmitter
psi	Pounds per Square Inch
psig	Pounds Per Square Inch Gauge
RHTF	Red Hill Tank Farm
SCADA	Supervisory Control and Data Acquisition
UGPH	Underground Pumphouse

TABLE OF CONTENTS

	Page
I. EXECUTIVE SUMMARY	1
II. FINDINGS AND OBSERVATIONS.....	2
III. BACKGROUND.....	6
Distribution Piping System.....	6
Column Separation.....	6
IV. ANALYSIS	7
Physical Damage Assessment	7
Hydraulic and Surge Analysis.....	10
Introduction	10
Description of the System.....	11
Description of System Components.....	12
Discussion of Results	13
Valve Analysis.....	15
AFHE Data Analysis (Sequence of Events).....	15
V. CONCLUSION.....	20
Root Cause	20
Supporting Evidence	20
Contributing Factors	20
AFHE Data Discrepancies.....	21
Modelling Corroboration	21
Disclaimer	22
VI. APPENDICES.....	23
APPENDIX 'A' - Master Operational Schematic, Pearl Harbor AFHE	24
APPENDIX 'B' - DFSP Pearl Harbor Specific Operations Order	25
APPENDIX 'C' - Government Furnished Information Listing.....	28
APPENDIX 'D' - Stress Analysis Output	30
APPENDIX 'E' - Surge Analysis Output.....	31
APPENDIX 'F' - Valve Testing Results	32
APPENDIX 'G' - AFHE Data.....	34
VII. REFERENCES AND CRITERIA	38

ASSESS TANK 20 PIPING FOR RETURN TO SERVICE AT RED HILL BULK FUEL STORAGE FACILITY

I. EXECUTIVE SUMMARY

Brockenbrough was contracted under NAVFAC EXWC Contract No. N39430-20-D-2242, Delivery Order No. N3943021F4122, to determine the root cause of the piping failure at Red Hill Tank Farm (RHTF) that occurred on May 6, 2021, at approximately 18:00 hours. See Appendix 'A' for a basic flow schematic of the system at the time.

Based upon collected field data and discussions with various facility personnel during site visits in June and July of 2021, it has been determined that the JP-5 piping system suffered a significant transient surge pressure at the noted date and time. This surge pressure was primarily caused by disregarding the proper valve sequencing dictated in the specific operations orders.

When all of the valves between a tank's closed skin valve at the RHTF and Surge Tank (b) (3) (A) are open except the butterfly valves (b) (3) (A), the closed butterfly valves leak. This allows the (b) (3) (A) column of JP-5 to sag as it tries to reach equilibrium with the atmospheric pressure on Surge Tank (b). The resulting void, technically a vacuum, created in the piping at upper portions of the RHTF will collapse rapidly if subjected to a high pressure source.

The following is what appears to have happened on May 6th. Towards the end of Evolution 3, the valve lineup below Tank 20 was set as described above for a period of over five minutes creating a vacuum with a volume of 23 bbl. Operations then moved to Evolution 4. As Tank 12 was being prepared for use in Evolution 4, the valve lineup was again set to allow for another five minutes of sag creating an additional 16 bbl of vacuum. When Tank 12's skin valve was opened, the inrush from the head in Tank 12 collapsed the 39 bbl of vacuum. This created a calculated transient surge pressure of approximately 350 psig in only milliseconds, or almost instantaneously, near Tanks 18 and 20. This energy displaced the (b) (3) (A) JP-5 mainline piping near Tank 20 at least 16 inches laterally and separated the Dresser couplings at Tanks 18 and 20.

It should be noted that while the incorrect sequencing of the valves was the primary, or root, cause, there were several other contributing factors in addition to the leaking butterfly valves. The AFHE system did not trigger an out-of-balance alarm or low pressure alarm prior to the event, and the use of Dresser couplings in sections of unrestrained pipe profoundly affected the amount of damage.

II. FINDINGS AND OBSERVATIONS

On May 6, 2021, the JP-5 piping system at the RHTF experienced a significant event that caused two Dresser couplings to completely separate and the piping to move enough to damage surrounding features in the area of Tanks 17, 18, 19, and 20. The event occurred during normal operations, and the operators had no explanation for the cause.

The facility had just completed Evolution 3 that involved moving JP-5 from Tank 12 to Tank 20. See Appendix 'B' for the DFSP Pearl Harbor Specific Operations Order (Evolution 3). Due to the piping and tank arrangement and varying vertical depths of product in the tanks at RHTF, product movements between tanks are often a multi-step process and may require the use of the pumps and surge tanks at the UGPH. In the case of Evolution 3, the final step involved pumping JP-5 from Surge Tank (b) (3) to Tank 20.

As Evolution 3 was being completed, the next movement, Evolution 4, was beginning. This evolution was to move product from Tank 12 to Tank 9. See Appendix 'B' for the DFSP Pearl Harbor Specific Operations Order (Evolution 4). This operation also required the use of the UGPH, and the first step was to gravity feed from Tank 12 to Surge Tank (b) (3) (A).

At this point there was not anything amiss to the operations personnel as they began opening (b) (3) (A), the last valve in the lineup between Tank 12 and Surge Tank 2. However, the event occurred as soon as the product started to flow out of Tank 12. A loud bang was heard by the operator who was in the lower piping tunnel near Tank 18 at the time. When the operator went to investigate, fuel was seen on the floor of the tunnel coming down from Tanks 17 through 20. The evolution was quickly stopped, and the system was secured.

It should be noted that the RHTF has been undergoing tank maintenance for several years. This includes changes to or temporary removals of the piping systems at the tank laterals. At the time of the event, the JP-5 piping systems at Tanks 18, 19, and 20 contained Dresser couplings, and the piping at Tanks 17, 18, and 19 was not connected to the tank. Blind flanges had been installed at the ends of any active piping, but no other arrangements had been made to restrain the system.

The primary physical damage clearly points to a large surge pressure created within the piping system. The damage included:

1. The unrestrained (b) (3) (A) piping at Tank 18 separated at the Dresser coupling and fell to the floor. See Photo 1. There did not appear to be any collateral damage.
2. The unrestrained (b) (3) (A) piping at Tank 19 moved longitudinally towards Tank 19 and began to separate at the Dresser coupling until it ran into a pipe support preventing it from completely coming apart. The pipe support and some adjacent conduits were bent, but there did not appear to be any additional collateral damage.
3. The (b) (3) (A) piping at Tank 20 completely separated at the Dresser coupling. See Photo 2. The only obvious collateral damage was to the tunnel's ceiling system directly above the Dresser coupling. The panels were mechanically damaged by the pressurized liquid.
4. The end of the (b) (3) (A) JP-5 mainline piping moved approximately 16 inches laterally towards Tank 19 creating a large indentation in adjacent ductwork and bending the adjacent conduit. See Photo 3.

Since the event, JP-5 Tanks 11, 12, and 20 and their associated piping systems have been secured. JP-5 Tanks 13, 14, 17, 18, and 19 are out of service for unrelated reasons. The remainder of RHTF and UGPH are still in operation but at a limited capacity until the cause is determined and damage is repaired.




Photo 1 - Tank 18 Piping

This is the section of piping including the Dresser coupling seen at the far end that separated and fell to the floor.




Photo 2 - Tank 20 Piping

The piping separated at Tank 20's Dresser coupling.




Photo 3 - Mainline Piping

The end of the (b) (3) (A) mainline piping between Tanks 19 and 20 moved approximately 16 inches laterally (to the right) as seen here by the collateral damage to the ductwork.

III. BACKGROUND

Distribution Piping System

There are three fuel products in the distribution piping systems at RHTF: JP-5, F-24, and F-76. The systems connect the RHTF with the UGPH via the lower tunnel that runs approximately (b) (3) (A) between the two facilities. At the RHTF, the JP-5's (b) (3) (A) mainline pipe runs the entire length of the lower tunnel in the tank farm from Tank 1 to Tank 20 (approximately (b) (3) (A)). The JP-5 pipeline then connects with each JP-5 tank via laterals (also referred to as the cross-tunnel piping) using a combination of (b) (3) (A) and (b) (3) (A) piping.

Within the JP-5 piping system there are numerous valves at both the RHTF and the UGPH. Some of these valves are only for maintenance or emergency purposes, and therefore, they stay open most of the time. These valves are referred to as normally open (NO) valves. The valves that are used to control the flow of JP-5 during each movement of fuel during an evolution are only opened when necessary. These valves are referred to as normally closed (NC) valves.

Each evolution has a specific operations order in which the NC valves are to be opened. The order is very important to control when and where the fuel and its associated pressure, either by pump or static pressure, is applied. The RHTF is very unique in its geographical footprint, elevation changes, physical size, and the volume of fuel within its tanks and piping systems. For this reason, any potential upset in a valve lineup that would not create significant issues at a normal bulk storage fuel facility are multiplied several magnitudes greater at RHTF.

Column Separation

The phenomenon of column separation and vacuum in piping systems and the damaging pressure surges created by it are well documented in scientific and engineering literature. The physics behind the creation of a vacuum in a pipeline vary depending on the situation. Due to the significant elevation change from the RHTF to the UGPH (b) (3) (A), there is always the potential for a large void or vacuum to be created in the piping system if the valves are not opened in the proper sequence. When the system is then exposed to pressure by opening a valve, the void collapses very rapidly creating a significant surge pressure in milliseconds. It is well known that the energy created this way can damage the pipe and any weaker components in the system.

Vacuum is normally measured as a pressure, however in this report the term also represents the void in the piping created by the column separation. All of the gauging at RHTF is measured in barrels, so the amount of vacuum created is also measured in barrels for simplicity.

IV. ANALYSIS

Physical Damage Assessment

A stress analysis of the mainline and cross-tunnel piping at Tanks 19 and 20 was performed based on measured movements indicated by the collateral damage. The purpose was to determine what forces and pressures the piping experienced during the event.

Pipe stress analysis utilizes analytical methods to determine how a piping system responds to the combination of pipe material, process pressures and temperatures, fluid weight, support methodology, and various potential loading conditions as required per ASME B31.3.

Caesar II software was used to analyze the piping system using 3D beam elements. The piping was modeled in accordance with available drawings and physical data taken during the two site visits. After the model was created, the load cases were defined in accordance with the relevant piping code, ASME B31.3. The software then determined the loads on supports and equipment connections, piping displacements, and pipe stresses for the various load cases defined.

The piping had a lateral displacement in the 'X' direction of approximately 16 inches measured at the blind flange at the end of the (b) (3) (A) mainline piping. The piping system at Tanks 19 & 20 were analyzed to determine the approximate forces that resulted in the measured deflection. All piping in the model is (b) (3) (A). The piping was determined to be (b) (3) (A) based on the wall thickness determined by the pipe pedigree report dated 2019 and the data taken during the two site visits (see Figure 3 for piping material input). To determine the approximate force, the piping was modeled in the condition just after the surge event with the Dresser coupling separated and no connection between the lateral and Tank 20. A force was applied at the location of the blind flange on the lateral for Tank 19 (see Figure 4), and the resultant displacement was investigated.

The model was operated in an iterative process until a displacement at the (b) (3) (A) blind flange (location where displacement was measured in field) was approximately 16-inch (see Figure 1 - Caesar II Model). This force was found to be approximately 78,000 lbf which equates to a pressure of 320 psi on the blind flange adjacent to Tank 19. As seen in Figure 2, the stress concentration was found to be most intense at (b) (3) (A) (in the Figure, the color gradient gray/yellow/red indicates increasing stress, with red being the highest stress concentration observed). Refer to Appendix 'D' for the analysis' full output.




Figure 1 - Caesar II Model




Figure 2 - Caesar Model Showing Stress Intensification at Tees/Joints




Figure 3 - Basic Inputs for Caesar Model




Figure 4 - Force Input at Blind Flange Adjacent to Tank 19

Hydraulic and Surge Analysis

The sequence of events on May 6th were hydraulically modelled to determine if the estimated surge matches the measured pipe movement and its associated stress. The hydraulic and surge analysis was conducted independent of the stress analysis.

Introduction

In order to model the surge characteristics from the JP-5 piping located near Tanks 19 and 20, a computer simulation was performed using the KY PIPE 2008: SURGE v. 8.014 computer software program.

The system was modeled using the following steps:

1. First, the system was modeled using a number of pipe segments connected by components and piping junctions between the two tanks. Head losses were calculated using the Hazen Williams equation. The system was then modeled at steady state conditions.
2. Once the steady state conditions were successfully modeled, the next step consisted of modifying the state of one or more components in the system. The modifications to the steady state conditions produces transients throughout the system that can be modeled as a series of waves that travel through the system at the speed of sound. These waves are affected by friction attenuation, junctions, and component state changes.
3. For steady state conditions, the computer program records the pressures and flowrates in every pipe and node throughout the system. For surge analysis, it records the pressures and flowrates for all user defined nodes and updates the data at a specified time increment for a specified node.
4. The last step consisted of formatting and generating the System Report. This report printout consisted of two sections; the first detailed the steady state conditions throughout the system, the second detailed the simulation results. A table was also included showing the maximum and minimum heads (or pressures) encountered over the simulation at every node in the system.

Description of the System

The attached simplified flow schematic, Figure 5, shows the system that was modeled in KY PIPE for computer simulations. It consists of Tank 12 transferring fuel via gravity to Surge Tank ^(b). The valves at Tank 12 open and close at the times indicated, and the resulting pressure surges are calculated.

The tank, pipe segment and components used to build the model are shown below.





Figure 5 - Surge Model

Description of System Components

1. Product: Jet Fuel (JP-5), Specific Gravity: 0.84, Kinematic Viscosity: 1.5 X 10⁻⁵ ft. 2/sec.
2. Piping: (b) (3) (A).
3. Pumps: The scenario modeled in this situation is one in which fuel is transferred using gravity only from Tank 12 to Surge Tank^(b). As a result, no pumps have been modeled in this system.
4. Valves: Valves included in this system include butterfly valves, ball valves and double block and bleed valves. The ball valve (b) (3) (A) at Tank 12 opens first, the double block and bleed valve (b) (3) (A) at Tank 12 then opens. Next the same ball valve starts to close and then the double block and bleed valve begins to close. Finally, the ball valve fully closes, followed by the complete closure of the double block and bleed valve. Butterfly valves (b) (3) (A) and (b) (3) (A) are modeled as being slightly open for the first 100 seconds of the calculation to simulate leakage past the valves. All other valves are modeled to be fully open. This includes the gate valve (b) (3) (A) and the double block and bleed valve (b) (3) (A) at Surge Tank^{(b)(3)}. Valve operation times were taken from Automated Fuel Handling Equipment (AFHE) records at the site. The first operation (the opening of the ball valve) is shown to occur at time = 200 seconds to allow adequate time for the steady state condition to develop. Finally, double block and bleed valves do not open linearly. A majority of the opening time is spent lifting the plug, rather than turning the plug to allow flow through the valve. As a result, the double block and bleed valve is shown opening or closing during the last 14 seconds of its operating time.

Valve operation is summarized below in Table 1. Actual times are taken from reports generated by the AFHE system.



Discussion of Results

The opening of the valves at Tank 12 causes a surge in pressure in the piping system. At the (b) (3) (A) mainline piping between Tank 19 and Tank 20, represented by junction J-6, the maximum pressure surge is seen to be 357 psig as indicated in the nodes results shown in Figure 6, and as shown on the graph in Figure 7. The pressure is seen at t = 335, which is approximately 11 seconds after the double block and bleed valve begins to open. Prior to that, the system pressure in that area falls to -14.4 psig, which indicates that a vacuum (referred to in the calculation output as cavitation) has occurred. Refer to Appendix 'E' for the analysis' full output.





Figure 6 - Node J-6 Pressure Results

Note that this simulation models the system in its current condition and does not consider the failure in the piping system. It is beyond the capability of the surge software to model a rupture in the piping. Everything after the pressure surge, which would have caused the piping failure, indicates pressures that would have been obtained absent the piping failure. The intent of this calculation was to determine the level of the pressure surge that would be responsible for the damage, which was calculated to be 357 psig.

It should also be noted that the software indicated pressure surges elsewhere in the system, including in the area of (b) (3) (A). In reviewing the data from the pressure indicating transmitter, (b) (3) (A) which is in the vicinity of the two butterfly valves (on the Tank 20 side), it was found that the AFHE system captured pressure readings from this transmitter only sporadically, with several seconds between pressure readings. At times, the interval between pressure readings was up to 10 seconds. As the pressure surge would have been very short lived (milliseconds), it is likely that the pressure rise occurred during one of these long intervals between pressure readings and was not read by (b) (3) (A). Although these pressure surges were seen in the system, damage was not incurred at these locations since the piping in these areas had been adequately restrained.

Figure 7: Node J-6 Pressure Graph



Valve Analysis

Only four valves were actuated during the timeframe of the event. They are:

1. (b) (3) (A) – (b) (3) (A) DBB valve at Tank 12.
2. (b) (3) (A) – (b) (3) (A) ball valve at Tank 12.
3. (b) (3) (A) – (b) (3) (A) ball valve in the (b) (3) (A) Outer Loop section of the UGPH.
4. (b) (3) (A) – (b) (3) (A) gate valve in the (b) (3) (A) branch line in the UGPH that leads to Surge Tank (b) (3) (A).

The AFHE system had trouble opening (b) (3) (A) for over 30 minutes leading up to the event, and (b) (3) (A) had both torque limit and stall alarms just four minutes before the event. We suspect that these problems are not related to the valve or its actuator but are due to the pressure differentials across the valves at the time.

The two valves in the UGPH did not have any issues on May 6, 2021 and operated normally without any alarms.

To confirm that all four valves are operating normally, each one was operated numerous times under no-load conditions during the field investigation trip of July 2021. All four valves performed properly. See the results in Appendix ‘F’. The valves generally do take longer to open/close than what is stamped on the nameplates, but they did not overload based on the measured amperages.

The testing also found that it takes the AFHE system from three to five seconds to sense movement in a valve, and the DBB valve’s plug only rotates during the last 14 seconds when going from 0% to 100% open.


There is no indication that an equipment failure on any of these valves occurred at the time of the event.

AFHE Data Analysis (Sequence of Events)

The recorded data from the AFHE control system was the primary source of data to establish the sequence of events between 17:15:00 and 18:30:00 on May 6, 2021. See Figure 8. This image is an actual snapshot from the AFHE system. Using the system’s event log, alarm log, data logging and charting features, a single chronological order of every event, alarm, and data point during the time frame can be determined. See Appendix ‘G’ for the printed data. This information, along with numerous discussions with FLC operations, FLC maintenance, NIWC, and ENGlobal personnel, has been used to develop the following general sequence shown in Table 2. The AFHE control system does monitor and record every data point that it measures. However, it does not measure/record it at a high enough frequency to detect an event that lasts for only milliseconds (such as a transient surge pressure).

It should be noted that the event occurred during the transition between the last step of Evolution 3 and the first step of Evolution 4. Evolution 3 involved completely filling Tank 20 from Tank 12 in steps using Surge Tank (b) (3) (A). Evolution 4 involved transferring JP-5 from Tank 12 to Tank 9 in steps using Surge Tank (b) (3) (A). Most of the valve lineup was already set from Evolution 3 prior to beginning Evolution 4, and only four valves were actuated during the time frame in question. The general sequence below only addresses the equipment and instrumentation readings that were involved with the event, and we have not included the unrelated events and alarms that occurred.

Figure 8 : AFHE Data Logging Chart



(b) (3) (A)

Notes:
1. See Table 2 for keyed notes.
2. Items along the top of the chart were not plotted. The indication is simply indicating the time stamp when the action occurred.

TABLE 2 - Sequence of Events

Time Stamp (interval)	Figure 8 Keyed Notes	Equipment Item	Action/Reading	Commentary
17:24:58	1a	(b) (3) (A)	Valve is set to open	Once this gate valve in the branch line to Surge Tank ^(b) is opened, all valves between Tank 20 and Surge Tank ^(b) are now open except for the two butterfly valves (b) (3) (A) in the UGPH.
	1b	(b) (3) (A)	(b) (3) (A)	This pressure represents the full height of Tank 20 on the system between the RHTF and the UGPH. This represents the pressure on the closed butterfly valves that are leaking.
	1c	Tank 20	(b) (3) (A)	Tank 20's gross volume is steady at this time and does not start to show the expected decrease in volume for approximately 7.5 minutes. It is believed that the tank is losing volume at this time, and the delayed response is due to the tank gauging's precision and the AFHE polling frequency.
17:25:14 (00:16)	2	Surge Tank ^(b)	(b) (3) (A)	Surge Tank ^(b) net volume almost immediately starts to show an increase in volume. This appears to indicate that one or both butterfly valves are leaking. The butterfly valves could not be tested for leakage during the field investigation of July 2021, but FLC will be conducting a test to verify.
17:32:33 (07:19)	3	Tank 20	(b) (3) (A)	The AFHE system finally sees the drop in Tank 20's volume that has most likely been occurring since 17:24:58. It loses 44 bbl during this one reading. It finally settles out at (b) (3) (A) around 17:45:03 with a total loss of 58 bbl.
17:33:28 (00:55)	4	(b) (3) (A)	Valves set to close	The ball valve at Tank 20 (F) begins closing first with the DBB valve (E) starting to close about 1 minute later. Both the tank skin and ball valves are fully closed at 17:35:57.
17:35:41 (02:13)	5	(b) (3) (A)	31 psig	While Tank 20's skin and ball valves are closing the pressure in the UGPH drops 94 psi over a period of 82 seconds. This is expected as the 79.3 psi of head from Tank 20 has been removed from the system by the closing of Tank 20's skin and ball valve. An additional 14.7 psi is lost due to the vacuum created by the leaking butterfly valve(s). The pressure essentially remains at this level until the event at 18:11:07.
17:41:38 (05:57)	6a	(b) (3) (A)	Valve 0% open	Once this valve is closed, the flow to Surge Tank ^(b) stops as would be expected.
	6b	Surge Tank ^(b)	(b) (3) (A)	Surge Tank ^(b) 's volume has settled at this point with a total gain of 81 bbl over 16 minutes. Therefore, a vacuum of approximately 23 bbl (Tank 20's loss of 58 bbl minus Surge Tank ^(b) 's gain of 81

TABLE 2 - Sequence of Events

Time Stamp (interval)	Figure 8 Keyed Notes	Equipment Item	Action/Reading	Commentary
				bbl) has formed in the piping at RHTF. AFHE does check for an out-of-balance between tanks during a transfer, but the tolerance is too high to catch this small amount.
18:00:21 (18:43)	7	Evolution 3	Complete	
18:00:52 (00:31)	8	Evolution 4	Start	
18:02:31 (01:39)	9	(b) (3) (A)	Valve is set to open	Once this gate valve in the branch line to Surge Tank (b) (3) (A) is opened, all valves between RHTF and Surge Tank (b) (3) (A) are now open except for the two butterfly valves in the UGPH.
18:03:06 (00:35)	10	Surge Tank (b) (3) (A)	(b) (3) (A)	Within 35 seconds of opening (b) (3) (A), Surge Tank (b) (3) (A) starts gaining volume due the leaking butterfly valve(s).
18:07:31 (04:25)	11a	(b) (3) (A)	Valve is 0% open	Once this ball valve in the outer loop header is closed, the flow to Surge Tank (b) (3) (A) stops as would be expected.
	11b	Surge Tank (b) (3) (A)	(b) (3) (A)	Surge Tank (b) (3) (A)'s volume has settled at this point with a total gain of 16 bbl over 4.5 minutes. The vacuum in the piping at RHTF has now grown to approximately 39 bbl. As noted above, AFHE does check for an out-of-balance between tanks during a transfer, but the tolerance is too high to catch this small amount.
18:09:21 (01:50)	12	(b) (3) (A)	100% open	Tank 12's ball valve is fully open.
18:11:01 (01:40)	13	(b) (3) (A)	100% open	Tank 12's DBB valve is fully open. It should be noted that field testing indicated that while it takes (b) (3) (A) seconds for the motor actuator to completely open the valve, the plug goes from (b) (3) (A) open over the last (b) (3) (A) seconds. It is impossible to determine the exact moment of the surge, but it most likely occurred between when the valve started opening at 18:10:02 and when the plug first started to rotate at 18:10:46. There is also some lag or latency between when the valve actuator starts and the AFHE system detects the valve moving. Field testing indicated the lag to be about (b) (3) (A) seconds.
18:11:07 (00:06)	14	(b) (3) (A)	110 psig	Once Tank 12's skin and ball valves are open, the pressure at the UGPH immediately goes from 30 psig to 110 psig in 22 seconds indicating a transient surge pressure in the system. This is approximately when the 39 bbl of vacuum collapses as the head of Tank

TABLE 2 - Sequence of Events

Time Stamp (interval)	Figure 8 Keyed Notes	Equipment Item	Action/Reading	Commentary
				12 is introduced to the system. The transient surge pressure then causes the unrestrained piping to move which separates the Dresser coupling fittings.
18:12:18 (01:11)	15	(b) (3) (A)	Valve set to close	Tank 12's ball valve starts closing.
18:12:24 (00:06)	16	(b) (3) (A)	Valve set to close	Tank 12's DBB valve starts closing.
18:12:33 (00:09)	17	(b) (3) (A)	6 psig	As the valves start closing, the waveform changes and the system reaches its lowest point during the attenuation. This waveform, while not the same magnitude as the model, does mimic the model's shape.
18:12:56 (00:23)	18	Tank 12	(b) (3) (A)	Tank 12's net volume finally drops 473 bbl over 50 seconds. It is believed that the tank is losing volume before this time, and as noted above, the delayed response is due to the tank gauging's precision and the AFHE polling frequency.
18:12:57 (00:01)	19	(b) (3) (A)	0% open	Tank 12's ball valve is fully closed.
18:13:15 (00:18)	20	(b) (3) (A)	0% open	Tank 12's DBB valve is fully closed.
18:25:00 (11:45)	21	(b) (3) (A)	43 psig	The pressure has now settled, and it now shows the expected pressure of the head from the piping between UGPH and the ruptured pipe at Tank 18.

V. CONCLUSION

Root Cause

Our assessment of the data determined that the root cause of the event was procedural error. If the personnel had closed all of the normally closed valves at the end of Evolution 3 as prescribed by the operations order and then opened the valves in the prescribed order for Evolution 4, the system would have not experienced the damaging surge. This omission allowed either one or both of the closed butterfly valves in the lineup to leak, causing the column of fuel to sag into Surge Tank (b) (3) (A). This led to a vacuum in the main piping at the top of RHTF that rapidly collapsed when Tank 12 was opened for Evolution 4.

Supporting Evidence

At the end of Evolution 3, the valves in the lineup between Tank 20 and Surge Tank (b) (3) (A) were open except for the two butterfly valves for approximately 10 minutes. The AFHE data indicates Surge Tank (b) (3) (A) increasing in volume during this time, and it also shows a corresponding drop in Tank 20's volume of approximately the same amount. Therefore, the butterfly valve(s) must have been leaking due to the head from the column of JP-5 from the open Tank 20 (approximately (b) (3) (A)). Tank 20's skin and ball valves were then closed, but Surge Tank (b) (3) (A) continued to gain volume while none of the RHTF tanks lost any volume and the pressure in the pipeline quickly sagged. This indicates continued leakage around the butterfly valve(s) and the creation of a vacuum. The pocket of vacuum did not stop growing until approximately five minutes later when (b) (3) (A) was closed. The presence of this vacuum pocket is corroborated by the expected and immediate drop in pressure at (b) (3) (A) from approximately 120 psig to 30 psig.

Approximately 25 minutes later at the official start of Evolution 4 (Tank 12 to Surge Tank (b) (3) (A) (b) (3) (A) was re-opened. This made all of the valves in the lineup between RHTF and Surge Tank (b) (3) (A) with the exception of the two butterfly valves, open for approximately five additional minutes. The AFHE data indicates a second increase in Surge Tank (b) (3) (A)'s volume during this time without the expected decrease in volume by one of the Red Hill tanks. Therefore, the butterfly valve(s) must have been leaking again as the column of JP-5 trapped below all of the tanks' closed skin valves sagged a little more trying to reach its natural state of equilibrium with Surge Tank (b) (3) (A).

The large pocket of perfect vacuum was probably created at the highest points in the JP-5 piping (the area of Tanks 17 – 20) while the column of JP-5 sagged through the leaking butterfly valve(s). It is estimated that the pocket was almost 39 bbl (the amount that Surge Tank (b) (3) (A) gained after (b) (3) (A) closed). When the last remaining closed valve in the lineup for Tank 12 was finally opened to start Evolution 4, the quick opening nature of the double block and bleed valve ((b) (3) (A)) allowed a rapid inflow of JP-5 to collapse the pocket of vacuum. The resulting pressure wave from the collapse of the vacuum pocket is what displaced the unrestrained piping and separated the Dresser couplings creating all of the collateral damage.

Contributing Factors

The contributory causes of the piping failure at the RHTF include:

1. The butterfly valves were used for shut-off service during both evolutions, but butterfly valves are not appropriate for bubble-tight shut-off service. Therefore, the leaking butterfly valves contributed to the event.

2. AFHE's out-of-balance alarm during Evolutions 3 and 4 was set to (b) (3) (A). Evolution 3 involved an extra 23 bbl flowing into Surge Tank (b) (3) (A) (without the corresponding decrease in Tank 12 or Tank 20's volume), and Evolution 4 involved an additional 16 bbl into Surge Tank (b) (3) (A). The lack of an out-of-balance alarm prior to the event was a contributing factor.
3. AFHE's low pressure alarm for (b) (3) (A) was set to -9 psig. When the tank skin and ball valves at Tank 20 were closed at the end of Evolution 3, (b) (3) (A) indicated a pressure drop from 125 psig down to 31 psig. This rapid drop alone was an indicator of a significant problem, and the 31 psig reading was clearly outside of the usual norm for Evolution 3. The lack of a low pressure alarm for (b) (3) (A) prior to the event was another contributing factor.
4. The use of Dresser couplings in sections of unrestrained piping was a contributing factor in this case. The physical damage seen at Tanks 17 – 20 would not have occurred if the piping systems had been fully installed and inherently restrained by connection to the tanks.

AFHE Data Discrepancies

The pressure at (b) (3) (A) dropped rapidly after the skin and ball valves at Tank 20 were closed as would be expected if the butterfly valve(s) were leaking. However, the pressure only sagged to 31 psig, while physics would say that the column of JP-5 should drop to about 40 feet above the level of Surge Tank (b) (3) (A) (14.7 psig). Our assumption is that while the butterfly valve(s) leak when there is 120 psi on the system, they don't appear to leak when only seeing 31 psig.

A vacuum was being created during the periods that Surge Tank (b) (3) (A) was gaining volume without a corresponding loss from the RHTF. In both instances of this, (b) (3) (A) did not see an appreciable drop in pressure. This is because the pipeline at RHTF is only sloped (b) (3) (A), so the total 39 bbl of vacuum created would only change the pressure a modest 1 psi.

It should be noted that Tank 20's data indicates a single, immediate drop of about 40 bbl followed by another drop of 20 bbl over 2.5 minutes. It appears the rapid drop is not accurate, and it was most likely a steady decrease over the 10-minute timeframe between (b) (3) (A)'s opening and closing. The misleading rapid drop is simply a function of the gauging system's precision along with the SCADA system's polling speed. These tanks are unique in the world, and the gauging system is a one-of-its-kind with limited precision under extremely rare conditions such as this anomaly. During normal operations, this does not present any problems as the volumes are large enough and occur over a much longer period that are easily measured by the system in real time.

(b) (3) (A) shows a maximum pressure of 110 psig at the time of the event and a minimum pressure of 6 psig afterwards while it attenuated the surge over a period of almost 15 minutes. During this time, the interval between SCADA readings was up to 20 seconds. Our model shows the same waveform of the attenuation but with much higher and lower pressures. This is because the model is calculating the pressure every millisecond. We believe the time interval between SCADA readings essentially failed to capture the spikes seen in the model.

Modelling Corroboration

The physical damage that was created during the event left enough evidence to verify the above conclusion. The (b) (3) (A) JP-5 mainline pipeline moved laterally 16 inches away from Tank 20 as measured from the large dent in the adjacent ductwork. As noted in Section IV, Physical Damage Assessment, our pipe stress analysis determined that a force of approximately 78,000 lbs was required to move the pipe the 16 inches. The 78,000 lbs of force is equivalent to a pressure of (b) (3) (A) applied to the interior of an (b) (3) (A) pipe, and in Section IV, Hydraulic and Surge Analysis, our surge analysis predicted

a transient surge pressure of approximately 357 psi created in milliseconds in the piping between Tanks 19 and 20. Therefore, it is reasonable to conclude that the surge pressure's energy created by the collapsing vacuum pocket was powerful enough to move the pipe, separate the Dresser coupling, and create the damage to the adjacent ductwork.

Considering that this analysis ignores any thrust from the fuel leaving the piping at Tank 20's separated Dresser coupling, the pipe should have moved even more. However, a pipe support on the section of pipe going to Tank 19 prevented it. The support has obvious damage from where the pipe's flange hit the support stopping the pipe's trajectory and preventing the Dresser coupling at Tank 19 from separating.

Disclaimer

Report is based on information known as of the date of the report and subject to revision should new information become available.

VI. APPENDICES

APPENDIX 'A' - Master Operational Schematic, Pearl Harbor AFHE

(b) (3) (A)

APPENDIX 'B' - DFSP Pearl Harbor Specific Operations Order

i. **Evolution 3**

DFSP Pearl Harbor Specific Operations Order

FINAL

1	Date	05/06/21	Time	~TBD	Location	Transfer fuel from JP5 tank RH 12 to STK [REDACTED], then to RH 20 for Tank Tightness Testing			
2	Operation								
	Set procedure to transfer fuel from RH 12 to STK [REDACTED]. Once filled, transfer fuel to RH tank 20.								
3	References								
	<ul style="list-style-type: none"> • DoD 4140.25-M, DoD Management of Bulk Petroleum Products, Natural Gas, and Coal • 33 CFR Part 154, Facilities Transferring Oil or Hazardous Materials in Bulk • 29 CFR §1910.38, Occupational Safety and Health Standards • MIL-STD 3004-1: DoD Standard Practice Quality Assurance for Bulk Fuels, Lubricants, and Related Products • UFC 3-460-03 Operation and Maintenance: Maintenance of Petroleum Fuel systems • Operations, Maintenance, Environmental, and Safety Plan (OMES) 								
4	Personnel Assignments								
	<ul style="list-style-type: none"> • WG-11 Control Operator • WG-09/WG-08 Pump Operator • One Kuahua rover to check pipeline during the fill process • One Red Hill Rover to monitor the source tank as required by Papa. 								
5	Issue Tank	RH [REDACTED], STK [REDACTED]	6	Receipt Tank	STK [REDACTED], RH 20	7	Volume/Qty	~TBD bbl.	
8	Communications Plan								
	Handheld radios on channel 5-a								
9	Tools and Materials								
	<ul style="list-style-type: none"> • Hard Hat if in the Red Hill Tunnel Complex • Portable radios 								
10	Preliminary								
	<p style="background-color: yellow;">This fuel transfer is for Tank Tightness Testing.</p> Transfer fuel from RH 12 to STK [REDACTED]; then fill tanks RH 20 to its High Operating Limit.								
11	Operational Procedure								
	<p style="background-color: yellow; display: inline-block; padding: 2px;">FILL SURGE TANK [REDACTED]</p>								

DFSP Pearl Harbor Specific Operations Order

- Source tank is RH 12.
- Receipt tank is Surge Tank # [REDACTED]
- Control operator will make preparations to transfer JPS fuel from Red Hill tank 10 to STK [REDACTED]. He will notify the Red Hill rover that fuel transfer is about to start.
- Control operator will line up the piping and valve systems as follows:

(b) (3) (A)

FILL RH 20

- Issue tank is STK [REDACTED]
- Receipt tank is RH 20. High limit is (b) (3) (A).
- Use JPS transfer pumps (b) (3) (A) as applicable
- Control operator will make preparations to transfer JP-S fuel from STK [REDACTED] to RH 20. Papa will notify both the Red Hill and the Kuahua rovers when fuel transfer is about to start.
- Control Operator will line up the piping and valve systems as follows:

(b) (3) (A)

- The pump suction is from the inside line and will discharge to the outside line, then to RH 20:

(b) (3) (A)

- Control operator and the rovers will verify that all other valves remain closed.
- Once the control operator opens up the skin valve of the source and destination tanks, both rovers will verify that the valves are open.
- Fill RH 20 up to its high operating limit and STOP pumping. DO NOT EXCEED THE HIGH OPERATING LIMIT

DFSP Pearl Harbor Specific Operations Order

	<ul style="list-style-type: none"> • Once the transfer is complete, close all valves and return the piping system to its normal configuration. • Once the transfer is complete, close all valves and proceed to the next tank. 					
12	Quality Plan					
	1. None					
13	Emergency Response Plan					
	<ul style="list-style-type: none"> a. Stop all transfer operations and close all valves. b. Notify the chain of command of the emergency and respond to the emergency with clean up material and containers and drip pans as required by the emergency. c. If needed, make alignment preparations to pump the fuel back to the source tank. 					
14	Safety Plan					
	<ul style="list-style-type: none"> a. Maintain communication between the control room operator and all involved parties. b. Do not lose focus or become complacent. c. Do not be impatient. Think all steps through. d. Accidents happen without warning. Be aware of your surroundings. Do not become distracted. e. Be aware of strange sounds or smells. f. Remain calm in an emergency. g. The worker must be able to react quickly and properly in a safe mode. h. Contact Control Room Operator by radio to secure the operation. Slowly close valves, taking at least 15 seconds to shut the valve completely. Inform the Fuel Supervisors of the situation. i. Anyone has the authority and responsibility to call a halt to an operation if they believe an unsafe condition exists. 					
15	ORM					
	Overall RAC code of: <u> RAC 3 Mitigated to a RAC 4 </u>					
Hazard Threat/effect	Assess	RAC	Risk Control Action	Re-assess	Residual	Supervision
Leak at pipe flanges.	D, I	3	Area manned and monitored by, qualified operators	D, II	4	YES
Overfill the tank.	C, III	4	Area manned and monitored, qualified operators, Certified AFHE overfill protection	D, III	5	YES

DFSP Pearl Harbor Specific Operations Order

Risk Assessment Matrix			PROBABILITY			
			Frequency of Occurrence Over Time			
			A Likely	B Probable	C May	D Unlikely
I	Loss of Mission Capability, Unit Readiness or Asset; Death	1	1	2	3	
II	Significantly Degraded Mission Capability or Unit Readiness; Severe Injury or Damage	1	2	3	4	
III	Degraded Mission Capability or Unit Readiness; Minor injury or Damage	2	3	4	5	
IV	Little or No Impact to Mission Capability or Unit Readiness; Minimal Injury or Damage.	3	4	5	5	

Risk Assessment Codes

1 – Critical 2 – Serious 3 – Moderate 4 – Minor 5 – Negligible

Prepared By: (b) (6)

(b) (6) Supervisor

(b) (6)

Approved by: _____

(b) (6) Bulk Fuel Operations Supervisor

ii. Evolution 4

DFSP Pearl Harbor Specific Operations Order



COPY

1	Date	05/06/21	Time	~TBD	Location	Transfer fuel from JP5 tank RH 12 to STK ^(b) , then to RH 09 for Tank Tightness Testing
2 Operation						
Set procedure to transfer fuel from RH 12 to STK ^(b) . Once filled, transfer fuel to RH tank 09						
3 References						
<ul style="list-style-type: none"> • DoD 4140.25-M, DoD Management of Bulk Petroleum Products, Natural Gas, and Coal • 33 CFR Part 154, Facilities Transferring Oil or Hazardous Materials in Bulk • 29 CFR §1910.38, Occupational Safety and Health Standards • MIL-STD 3004-1: DoD Standard Practice Quality Assurance for Bulk Fuels, Lubricants, and Related Products • UFC 3-460-03 Operation and Maintenance: Maintenance of Petroleum Fuel systems • Operations, Maintenance, Environmental, and Safety Plan (OMES) 						
4 Personnel Assignments						
<ul style="list-style-type: none"> • WG-11 Control Operator • WG-09/WG-08 Pump Operator • One Kuahua rover to check pipeline during the fill process • One Red Hill Rover to monitor the source tank as required by Papa. 						
5	Issue Tank	RH 12, STK ^(b)	6	Receipt Tank	STK ^(b) , RH 09	7 Volume/Qty ~TBD bbl.
8 Communications Plan						
Handheld radios on channel 5-a						
9 Tools and Materials						
<ul style="list-style-type: none"> • Hard Hat if in the Red Hill Tunnel Complex • Portable radios 						
10 Preliminary						
This fuel transfer is for Tank Tightness Testing. Transfer fuel from RH 12 to STK ^(b) ; then fill tanks RH 09 to its High Operating Limit.						
11 Operational Procedure						
FILL SURGE TANK^{(b)(c)}						

DFSP Pearl Harbor Specific Operations Order

- Source tank is RH 12.
- Receipt tank is Surge Tank # [REDACTED]
- Control operator will make preparations to transfer JP5 fuel from Red Hill tank 10 to STK [REDACTED]. He will notify the Red Hill rover that fuel transfer is about to start.
- Control operator will line up the piping and valve systems as follows:

(b) (3) (A) (normally open)

FILL RH 09

- Issue tank is STK [REDACTED]
- Receipt tank is RH 09. **High operating limit is (b) (3) (A).**
- Use JP5 transfer pumps (b) (3) (A) as applicable
- Control operator will make preparations to transfer JP-5 fuel from STK [REDACTED] to RH 09. Papa will notify both the Red Hill and the Kuahua rovers when fuel transfer is about to start.
- Control Operator will line up the piping and valve systems as follows:

(b) (3) (A)

- The pump suction is from the inside line and will discharge to the outside line, then to RH 20:

(b) (3) (A)

- Control operator and the rovers will verify that all other valves remain closed.
- Once the control operator opens up the skin valve of the source and destination tanks, both rovers will verify that the valves are open.
- **Fill RH 09 up to its high operating limit and STOP pumping. DO NOT EXCEED THE HIGH OPERATING LIMIT**

DFSP Pearl Harbor Specific Operations Order

	<ul style="list-style-type: none"> • Once the transfer is complete, close all valves and return the piping system to its normal configuration. • Once the transfer is complete, close all valves and proceed to the next tank. 						
12	Quality Plan						
	1. None						
13	Emergency Response Plan						
	<ul style="list-style-type: none"> a. Stop all transfer operations and close all valves. b. Notify the chain of command of the emergency and respond to the emergency with clean up material and containers and drip pans as required by the emergency. c. If needed, make alignment preparations to pump the fuel back to the source tank. 						
14	Safety Plan						
	<ul style="list-style-type: none"> a. Maintain communication between the control room operator and all involved parties. b. Do not lose focus or become complacent. c. Do not be impatient. Think all steps through. d. Accidents happen without warning. Be aware of your surroundings. Do not become distracted. e. Be aware of strange sounds or smells. f. Remain calm in an emergency. g. The worker must be able to react quickly and properly in a safe mode. h. Contact Control Room Operator by radio to secure the operation. Slowly close valves, taking at least 15 seconds to shut the valve completely. Inform the Fuel Supervisors of the situation. i. Anyone has the authority and responsibility to call a halt to an operation if they believe an unsafe condition exists. 						
15	ORM						
	Overall RAC code of: <u> RAC 3 Mitigated to a RAC 4 </u>						
	Hazard Threat/effect	Assess	RAC	Risk Control Action	Re-assess	Residual	Supervision
	Leak at pipe flanges.	D, I	3	Area manned and monitored by, qualified operators	D, II	4	YES
	Overfill the tank.	C, III	4	Area manned and monitored, qualified operators, Certified AFHE overfill protection	D, III	5	YES

DFSP Pearl Harbor Specific Operations Order

Risk Assessment Matrix			PROBABILITY			
			Frequency of Occurrence Over Time			
			A Likely	B Probable	C May	D Unlikely
I	Loss of Mission Capability, Unit Readiness or Asset; Death	1	1	2	3	
II	Significantly Degraded Mission Capability or Unit Readiness; Severe Injury or Damage	1	2	3	4	
III	Degraded Mission Capability or Unit Readiness; Minor injury or Damage	2	3	4	5	
IV	Little or No Impact to Mission Capability or Unit Readiness; Minimal Injury or Damage.	3	4	5	5	

Risk Assessment Codes

1 – Critical 2 – Serious 3 – Moderate 4 – Minor 5 – Negligible

Prepared By:

(b) (6)

(b) (6) , FBSO Supervisor

Approved by:

(b) (6)

(b) (6) , Bulk Fuel Operations Supervisor

APPENDIX 'C' - Government Furnished Information Listing

Government Furnished Information Listing

1. DFSP Pearl Harbor Specific Operations Order (Evolution 3); May 6, 2021.
2. DFSP Pearl Harbor Specific Operations Order (Evolution 4); May 6, 2021.
3. Pipe Stress Analysis Red Hill Lower Tunnel Piping, Tanks 1 to 16; April 2004; Draft; Weston Solutions.
4. Hydraulic Analysis and Dynamic Transient Surge Evaluation; September 2010; Final Report; Enterprise Engineering, Inc.
5. AFHE Data – Alarm Logs, Event Logs, and Data Export.
6. Red Hill Skin Valve Piping Analytical Review of Piping Configuration; 23 June 1999; Thermal Engineering Corporation.
7. Red Hill Skin Valve Piping Addendum to the Analytical Review of Piping Configuration; 12 November 1999; Thermal Engineering Corporation.
8. Inspection and Repair of Red Hill Pipelines – Technical Note; March, 8 2019; Enterprise Engineering, Inc.
9. Inspection and Repair of Red Hill Pipelines – Pipe Pedigree Report; April 2019; Enterprise Engineering, Inc.

APPENDIX 'D' - Stress Analysis Output

Job Name: 21-032 STRESS ANALYSIS

DISPLACEMENTS REPORT: Nodal Movements

CASE 1 (OPE) W+T1+P1+F1

Node	DX in.	DY in.	DZ in.	RX deg.	RY deg.	RZ deg.
10	-0.0000	0.0000	-0.0000	0.0000	0.0000	0.0000
20	-1.4350	0.0876	-0.0208	0.1365	2.2677	0.2376
30	-6.7537	0.3917	-0.0521	0.1838	3.5432	0.5940
40	-7.0843	0.4018	0.0409	0.1838	3.5432	0.5609
50	-13.6800	0.7082	-0.0886	0.1518	3.5432	0.5940
60	-15.5970	0.7898	-0.0987	0.1509	3.5432	0.5940
70	-15.9913	0.8066	-0.1008	0.1509	3.5432	0.5940
90	-7.1672	0.4046	0.0666	0.1838	3.5432	0.5108
100	-7.1148	1.7493	-9.8899	0.1838	3.5432	0.4666
110	-7.1096	1.8796	-10.8793	0.1838	3.5432	0.4665
300	-7.2539	-0.0000	10.4559	0.1838	3.5432	-0.0138
310	-7.3582	-0.0413	22.9478	0.1838	3.5432	0.0133
320	-7.3659	-0.0444	23.8136	0.1838	3.5432	0.0118
330	-7.3802	-0.0485	25.2978	0.1838	3.5432	0.0094
340	-33.3802	-0.0412	25.6688	0.1838	3.5432	-0.1306
350	-33.3909	-0.0000	26.7820	0.1838	3.5432	-0.1301
360	-33.4088	0.0676	28.6372	0.1838	3.5432	-0.1289
370	-33.4107	0.0794	28.9619	0.1838	3.5432	-0.1289
400	-7.1050	1.9935	-11.7451	0.1838	3.5432	0.4665

CAESAR II Ver.12.00.00.4000, (Build 200403) Date: AUG 16, 2021 Time: 15:0
Job.: 21-032 STRESS ANALYSIS

RESTRAINTS REPORT: Loads On Restraints
CASE 1 (OPE) W+T1+P1+F1

Node	FX lb.	FY lb.	FZ lb.	MX ft.lb.	MY ft.lb.	MZ ft.lb.	Restraint Type/Tag
10	-78000	4930	-0	63852.5	1039999.6	67469.7	TYPE=Rigid ANC;
20	0	0	0	0.0	0.0	0.0	TYPE=Rigid +Y;
50	0	0	0	0.0	0.0	0.0	TYPE=Rigid +Y;
100	0	0	0	0.0	0.0	0.0	TYPE=Rigid +Y;
110	0	0	0	0.0	0.0	0.0	TYPE=Rigid +Y;
300	0	-15213	0	0.0	0.0	0.0	TYPE=Rigid +Y;
350	0	-964	0	0.0	0.0	0.0	TYPE=Rigid +Y;

GLOBAL ELEMENT FORCES REPORT: Forces on Elements
 CASE 1 (OPE) W+T1+P1+F1

Node	FX lb.	FY lb.	FZ lb.	MX ft.lb.	MY ft.lb.	MZ ft.lb.	Element Name
10	78000	-4930	0	-63852.5	-	-67469.7	
20	-78000	5652	-0	35634.9	1039999.6	67469.7	
20	78000	-5652	0	-35634.9	-623999.8	-67469.7	
30	-78000	6736	-0	-13915.9	-0.0	67469.7	
30	78000	-8703	0	0.0	0.0	-67469.7	
40	-78000	9030	-0	-0.0	-0.0	-121030.2	
30	0	1967	0	13915.9	-0.0	0.0	
50	-0	-703	-0	-1457.1	0.0	-0.0	
50	0	703	0	1457.1	-0.0	0.0	
60	-0	-353	-0	-93.7	0.0	-0.0	
60	0	353	0	93.7	-0.0	0.0	
70	-0	0	-0	-0.0	0.0	0.0	FLANGE_FLG_300
40	78000	-9030	0	0.0	0.0	121030.2	
90	-78000	9120	-0	0.0	-0.0	-173030.2	
90	0	2120	0	-0.0	-0.0	16602.7	
100	-0	-303	-0	0.0	0.0	-347.4	
100	0	303	0	-0.0	-0.0	347.4	
110	-0	-122	-0	0.0	0.0	-64.0	
90	78000	-11241	0	-0.0	0.0	156427.5	
300	-78000	13137	-0	0.0	-0.0	14215.1	
300	78000	2076	0	-0.0	0.0	-14215.1	
310	-78000	204	-0	0.0	-0.0	-1536.6	
310	78000	-204	0	-0.0	0.0	1536.6	
320	-78000	327	-0	0.0	-0.0	-1219.5	
320	78000	-327	0	-0.0	0.0	1219.5	
330	-78000	480	-0	0.0	-0.0	-413.3	
330	78000	-480	0	-0.0	0.0	413.3	
340	-78000	500	-0	0.0	-0.0	-168.3	
340	78000	-500	0	-0.0	0.0	168.3	
350	-78000	615	-0	0.0	-0.0	668.4	

CAESAR II Ver.12.00.00.4000, (Build 200403) Date: AUG 16, 2021 Time: 15:0
Job.: 21-032 STRESS ANALYSIS

GLOBAL ELEMENT FORCES REPORT: Forces on Elements
CASE 1 (OPE) W+T1+P1+F1

Node	FX lb.	FY lb.	FZ lb.	MX ft.lb.	MY ft.lb.	MZ ft.lb.	Element Name
350	78000	349	0	-0.0	0.0	-668.4	
360	-78000	-158	-0	0.0	-0.0	34.5	
360	78000	158	-0	-0.0	0.0	-34.5	
370	-78000	-0	0	0.0	-0.0	0.0	FLANGE_FLG_300
110	0	122	0	-0.0	-0.0	64.0	
400	0	0	0	0.0	-0.0	0.0	

CAESAR II Ver.12.00.00.4000, (Build 200403) Date: AUG 16, 2021 Time: 15:0
 Job:: 21-032 STRESS ANALYSIS

B31.3 STRESSES REPORT: Stresses on Elements
 CASE 1 (OPE) W+T1+P1+F1

Piping Code (1 of 1): B31.3 -2018, Aug 30, 2019

The SLP column shows the longitudinal pressure stress.

Highest Stresses: (lb./sq.in.)

F/A	7945.0	@Node	320
Bending	204924.1	@Node	10
Torsion	6634.7	@Node	10
SIF/Index In-Plane	1.0	@Node	10
SIF/Index Out-Plane	1.0	@Node	10
SIF/Index Torsion	1.0	@Node	10
SIF/Index Axial	1.0	@Node	10

Node	SLP lb./sq.in.	F/A lb./sq.in.	Bending lb./sq.in.	Torsion lb./sq.in.	SIF/Index In-Plane	SIF/Index Out- Plane	SIF/Index Torsion	SIF/Index Axial	Code lb./sq.in.
10		0.0	204924.1	6634.7	1.000	1.000	1.000	1.000	205353.2
20		0.0	122923.3	-6634.7	1.000	1.000	1.000	1.000	123637.4
20		0.0	122923.3	6634.7	1.000	1.000	1.000	1.000	123637.4
30		0.0	2736.9	-6634.7	1.000	1.000	1.000	1.000	13548.7
30		624.3	13269.4	0.0	1.000	1.000	1.000	1.000	13893.7
40		647.7	23803.3	-0.0	1.000	1.000	1.000	1.000	24451.0
30		0.0	2736.9	-0.0	1.000	1.000	1.000	1.000	2736.9
50		0.0	286.6	0.0	1.000	1.000	1.000	1.000	286.6
50		0.0	286.6	-0.0	1.000	1.000	1.000	1.000	286.6
60		0.0	18.4	0.0	1.000	1.000	1.000	1.000	18.4
60									
70									
40		647.7	23803.3	0.0	1.000	1.000	1.000	1.000	24451.0
90		654.2	34030.2	-0.0	1.000	1.000	1.000	1.000	34684.4

CAESAR II Ver.12.00.00.4000, (Build 200403) Date: AUG 16, 2021 Time: 15:0
 Job:: 21-032 STRESS ANALYSIS

B31.3 STRESSES REPORT: Stresses on Elements
 CASE 1 (OPE) W+T1+P1+F1

Node	SLP lb./sq.in.	F/A lb./sq.in.	Bending lb./sq.in.	Torsion lb./sq.in.	SIF/Index In-Plane	SIF/Index Out-Plane	SIF/Index Torsion	SIF/Index Axial	Code lb./sq.in.
90		-0.0	3265.3	-0.0	1.000	1.000	1.000	1.000	3265.3
100		-0.0	68.3	0.0	1.000	1.000	1.000	1.000	68.3
100		-0.0	68.3	-0.0	1.000	1.000	1.000	1.000	68.3
110		-0.0	12.6	0.0	1.000	1.000	1.000	1.000	12.6
90		5595.1	30764.9	0.0	1.000	1.000	1.000	1.000	36360.0
300		5595.1	2795.7	-0.0	1.000	1.000	1.000	1.000	8390.8
300		5595.1	2795.7	0.0	1.000	1.000	1.000	1.000	8390.8
310		5595.1	302.2	-0.0	1.000	1.000	1.000	1.000	5897.3
310		5595.1	302.2	0.0	1.000	1.000	1.000	1.000	5897.3
320		7945.0	486.4	-0.0	1.000	1.000	1.000	1.000	8431.4
320		7945.0	486.4	0.0	1.000	1.000	1.000	1.000	8431.4
330		7945.0	164.8	-0.0	1.000	1.000	1.000	1.000	8109.8
330									
340									
340		7945.0	67.1	0.0	1.000	1.000	1.000	1.000	8012.1
350		7945.0	266.5	-0.0	1.000	1.000	1.000	1.000	8211.6
350		7945.0	266.5	0.0	1.000	1.000	1.000	1.000	8211.6
360		7945.0	13.8	-0.0	1.000	1.000	1.000	1.000	7958.8
360									
370									
110		-0.0	12.6	-0.0	1.000	1.000	1.000	1.000	12.6
400		0.0	0.0	0.0	1.000	1.000	1.000	1.000	0.0

APPENDIX 'E' - Surge Analysis Output

* * * * * S U R G E * * * * *
*
* Transient Flow Modeling Software *
*
* CopyRighted by KYPIPE LLC (www.kypipe.com) *
* Version: 8.014 01/11/2016 *
* Company: AustinBroc Serial #: 592067 *
* Interface: Classic *
* Licensed for Pipe2008 *
*
* * * * *

INPUT: g:\21 jobs\21-032 assess tank 20 piping - red hill\calcs\m\21-032 surge
analysis\21-032_s.DAT
OUTPUT: g:\21 jobs\21-032 assess tank 20 piping - red hill\calcs\m\21-032 surge
analysis\21-032_s.OUT

RUN DATE = 08/05/21
RUN TIME = 22:29:53

SYSTEM DATA

THE FOLLOWING DEFAULT OVERRIDES HAVE BEEN DEFINED:

Liquid Specific Gravity = 0.839999974
Cavitation Head = 7.76000023E-02
Time Increment Factor = 1
Flow Conversion Factor = 448.859985
Head Conversion Factor = 1.00000000

of Increments for Cavity collapse: 1
CV Setting for Inertial effects: 0.00000000E+00

Pressure Sensitive Demands at Junction Nodes.
Exit Head = 0.00000000E+00

Total Simulation Time = 600.0 sec
Time Increment = 0.00280 sec

ENGLISH UNITS ARE SPECIFIED:
FLOW in Gallons/Minute & HEAD in feet

Dynamic Friction Option Selected.
Pipe resistance changes with flowrate.

NUMBERS OF SPECIFIC ELEMENTS:

Line Segments = 19 Components = 6
Junctions = 13 Bypass Lines = 0
Side Orifices = 0 Relief Valves = 0
Check Valves = 0 Variable Inputs = 4

=====

LineSegment Data

 LINE SEGMENT DATA

POSITION OF END NODES		TRAVEL INCREMENTS	C/GA	INITIAL FLOWRATE	SEGMENT RESISTANCE	WAVE SPEED
Tank 12	I-AV-1	1	(b)	(3)	(A)	
O-AV-1	I-AV-2	1				
O-AV-2	J-3	3				
J-1	J-2	1				
J-3	J-1	1716				
J-2	I-AV-3	1				
O-AV-3	J-4b	1				
J-4b	J-4c	2				
J-4c	J-4e	1				
J-4e	I-AV-5	1				
O-AV-5	J-4f	1				
J-4f	J-4g	15				
J-4g	I-AV-4	4				
J-1	J-4	1				
O-AV-4	Tank 2	1				
I-AV-6	J-5	1				
J-4	O-AV-6	1				
J-5	J-4c	2				
J-3	J-6	20				

Total Number of Time Increments: 3549
 (Limit is: 400,000)

=====
 Component Data

 COMPONENT DATA

COMPONENT CHARACTERISTICS AND INITIAL CONDITIONS:

POS. #1	POS. #2	-- (A)	CHARACTERISTICS (B)	-- (C)	INITIAL FLOW	HEAD #1	HEAD #2
I-AV-1	O-AV-1	0.00	0.00	-0.346E-01	(b)	(3)	(A)
I-AV-2	O-AV-2	0.00	0.00	-0.123E-01			
I-AV-3	O-AV-3	0.00	0.00	-0.903E+03			
I-AV-5	O-AV-5	0.00	0.00	-0.123E-01			
I-AV-4	O-AV-4	0.00	0.00	-0.123E-01			
I-AV-6	O-AV-6	0.00	0.00	-0.365E+05			

=====
 Junction Data

 JUNCTION DATA

JUNCTION NUMBER INITIAL INITIAL CONNECTING

(b) (3) (A)

LOCATION	OF LEGS	DEMAND	POSITIONS	
Tank 12	0	0.000		
Tank 2	0	0.000		
J-1	3	0.005	27	34
J-2	2	0.000	28	
J-3	3	0.000	26	38
J-4	2	0.000	35	
J-5	2	0.000	36	
J-6	1	0.000		
J-4b	2	0.000	29	
J-4c	3	0.000	30	37
J-4e	2	0.000	31	
J-4f	2	0.000	32	
J-4g	2	0.000	33	

Protection Data

Variable Input Data

VARIABLE INPUT DATA

INPUT # 1:

A VARIABLE AREA VALVE IS SPECIFIED AT POSITION #: I-AV-1
REFERENCE VALUE FOR VALVE RESISTANCE (R=1) = 0.03458

TIME - RATIO INPUT DATA:

TIME	RATIO
0.000	0.0000
324.000	0.0000
338.000	1.0000
458.000	1.0000
472.000	0.0000

Following initial value is calculated for this variable input:

... This should agree with initial value previously defined (in parentheses)
Initial valve resistance = 0.00 (0.0346)

INPUT # 2:

REFERENCE VALUE FOR VALVE RESISTANCE (R=1) = 0.01233
A BALL VALVE IS AT POSITION I-AV-2

TIME	RATIO
0.0000	0.0000
200.0000	0.0000
203.8000	0.0430
207.6000	0.1136
211.4000	0.2031
215.2000	0.3062
219.0000	0.4188
222.8000	0.5371
226.6000	0.6578
230.4000	0.7773
234.2000	0.8924
238.0000	1.0000

415.0000	1.0000
418.9000	0.8924
422.8000	0.7773
426.7000	0.6578
430.6000	0.5371
434.5000	0.4188
438.4000	0.3062
442.3000	0.2031
446.2000	0.1136
450.1000	0.0430
454.0000	0.0000

Following initial value is calculated for this variable input:

... This should agree with initial value previously defined (in parentheses)
 Initial valve resistance = 0.00 (0.0123)

INPUT # 3:

REFERENCE VALUE FOR VALVE RESISTANCE (R=1) = 0.03417
 A BUTTERFLY VALVE IS AT POSITION I-AV-3

TIME	RATIO

0.0000	0.0031
100.0000	0.0031
100.1000	0.0025
100.2000	0.0020
100.3000	0.0015
100.4000	0.0011
100.5000	0.0008
100.6000	0.0005
100.7000	0.0003
100.8000	0.0001
100.9000	0.0000
101.0000	0.0000

Following initial value is calculated for this variable input:

... This should agree with initial value previously defined (in parentheses)
 Initial valve resistance = 0.00 (903.3859)

INPUT # 4:

REFERENCE VALUE FOR VALVE RESISTANCE (R=1) = 1.38097
 A BUTTERFLY VALVE IS AT POSITION I-AV-6

TIME	RATIO

0.0000	0.0031
100.0000	0.0031
100.1000	0.0025
100.2000	0.0020
100.3000	0.0015
100.4000	0.0011
100.5000	0.0008
100.6000	0.0005
100.7000	0.0003
100.8000	0.0001
100.9000	0.0000
101.0000	0.0000

Following initial value is calculated for this variable input:


... This should agree with initial value previously defined (in parentheses)
 Initial valve resistance = 0.00 (36507.4766)

Initial Conditions

 **** SUMMARY OF INITIAL CONDITIONS FOR LINE SEGMENTS ****

END POSITION DESIGNATIONS: J - JUNCTION, C - COMPONENT, S - SDO
 * - THIS DENOTES AN UNDESIGNATED END POSITION (UNACCEPTABLE) - CORRECT DATA

----- END POSITIONS -----		FLOW	----- HEAD -----		HEAD	ELEVATION
#1	#2	#1 to #2	#1	#2	LOSS	DIFFERENCE
Tank 12 J	I-AV-1 C					
O-AV-1 C	I-AV-2 C					
O-AV-2 C	J-3 J					
J-1 J	J-2 J					
J-3 J	J-1 J					
J-2 J	I-AV-3 C					
O-AV-3 C	J-4b J					
J-4b J	J-4c J					
J-4c J	J-4e J					
J-4e J	I-AV-5 C					
O-AV-5 C	J-4f J					
J-4f J	J-4g J					
J-4g J	I-AV-4 C					
J-1 J	J-4 J					
O-AV-4 C	Tank 2 J					
I-AV-6 C	J-5 J					
J-4 J	O-AV-6 C					
J-5 J	J-4c J					
J-3 J	J-6 J					




Tabulated Results

 ***** FLOWRATE AND PRESSURE RESULTS *****

TIME Head at Head at Head at
 J-6 J-3 J-1

0.000	(b)	(3)	(A)
0.498	(b)	(3)	(A)
0.997	(b)	(3)	(A)
1.495	(b)	(3)	(A)
1.994	(b)	(3)	(A)
2.492	(b)	(3)	(A)
2.990	(b)	(3)	(A)
3.489	(b)	(3)	(A)
3.987	(b)	(3)	(A)
4.486	(b)	(3)	(A)
4.984	(b)	(3)	(A)
5.482	(b)	(3)	(A)
5.981	(b)	(3)	(A)
6.479	(b)	(3)	(A)
6.978	(b)	(3)	(A)
7.476	(b)	(3)	(A)
7.974	(b)	(3)	(A)



(b) (3) (A)

8.473
8.971
9.470
9.968
10.466
10.965
11.463
11.962
12.460
12.958
13.457
13.955
14.454
14.952
15.450
15.949
16.447
16.946
17.444
17.942
18.441
18.939
19.438
19.936
20.434
20.933
21.431
21.930
22.428
22.926
23.425
23.923
24.421
24.920
25.418
25.917
26.415
26.913
27.412
27.910
28.409
28.907
29.405
29.904
30.402
30.901
31.399
31.897
32.396
32.894
33.393
33.891
34.389
34.888
35.386
35.885
36.383
36.881
37.380
37.878
38.377
38.875
39.373

(b) (3) (A)

39.872
40.370
40.869
41.367
41.865
42.364
42.862
43.361
43.859
44.357
44.856
45.354
45.853
46.351
46.849
47.348
47.846
48.345
48.843
49.341
49.840
50.338
50.837
51.335
51.833
52.332
52.830
53.329
53.827
54.325
54.824
55.322
55.821
56.319
56.817
57.316
57.814
58.313
58.811
59.309
59.808
60.306
60.805
61.303
61.801
62.300
62.798
63.297
63.795
64.293
64.792
65.290
65.789
66.287
66.785
67.284
67.782
68.281
68.779
69.277
69.776
70.274
70.772

(b) (3) (A)

71.271
71.769
72.268
72.766
73.264
73.763
74.261
74.760
75.258
75.756
76.255
76.753
77.252
77.750
78.248
78.747
79.245
79.744
80.242
80.740
81.239
81.737
82.236
82.734
83.232
83.731
84.229
84.728
85.226
85.724
86.223
86.721
87.220
87.718
88.216
88.715
89.213
89.712
90.210
90.708
91.207
91.705
92.204
92.702
93.200
93.699
94.197
94.696
95.194
95.692
96.191
96.689
97.188
97.686
98.184
98.683
99.181
99.680
100.178
100.676
101.175
101.673
102.172

102.670
103.168
103.667
104.165
104.664
105.162
105.660
106.159
106.657
107.156
107.654
108.152
108.651
109.149
109.648
110.146
110.644
111.143
111.641
112.140
112.638
113.136
113.635
114.133
114.632
115.130
115.628
116.127
116.625
117.123
117.622
118.120
118.619
119.117
119.615
120.114
120.612
121.111
121.609
122.107
122.606
123.104
123.603
124.101
124.599
125.098
125.596
126.095
126.593
127.091
127.590
128.088
128.588
129.088
129.588
130.088
130.587
131.087
131.587
132.087
132.586
133.086
133.586

(b) (3) (A)

134.086
134.585
135.085
135.585
136.085
136.584
137.084
137.584
138.084
138.583
139.083
139.583
140.083
140.582
141.082
141.582
142.082
142.581
143.081
143.581
144.081
144.580
145.080
145.580
146.080
146.579
147.079
147.579
148.079
148.578
149.078
149.578
150.078
150.577
151.077
151.577
152.077
152.577
153.076
153.576
154.076
154.576
155.075
155.575
156.075
156.575
157.074
157.574
158.074
158.574
159.073
159.573
160.073
160.573
161.072
161.572
162.072
162.572
163.071
163.571
164.071
164.571
165.070

(b) (3) (A)

165.570
166.070
166.570
167.069
167.569
168.069
168.569
169.068
169.568
170.068
170.568
171.067
171.567
172.067
172.567
173.067
173.566
174.066
174.566
175.066
175.565
176.065
176.565
177.065
177.564
178.064
178.564
179.064
179.563
180.063
180.563
181.063
181.562
182.062
182.562
183.062
183.561
184.061
184.561
185.061
185.560
186.060
186.560
187.060
187.559
188.059
188.559
189.059
189.558
190.058
190.558
191.058
191.557
192.057
192.557
193.057
193.557
194.056
194.556
195.056
195.556
196.055
196.555

(b) (3) (A)

197.055
197.555
198.054
198.554
199.054
199.554
200.053
200.553
201.053
201.553
202.052
202.552
203.052
203.552
204.051
204.551
205.051
205.551
206.050
206.550
207.050
207.550
208.049
208.549
209.049
209.549
210.048
210.548
211.048
211.548
212.047
212.547
213.047
213.547
214.046
214.546
215.046
215.546
216.046
216.545
217.045
217.545
218.045
218.544
219.044
219.544
220.044
220.543
221.043
221.543
222.043
222.542
223.042
223.542
224.042
224.541
225.041
225.541
226.041
226.540
227.040
227.540
228.040

(b) (3) (A)

228.539
229.039
229.539
230.039
230.538
231.038
231.538
232.038
232.537
233.037
233.537
234.037
234.536
235.036
235.536
236.036
236.536
237.035
237.535
238.035
238.535
239.034
239.534
240.034
240.534
241.033
241.533
242.033
242.533
243.032
243.532
244.032
244.532
245.031
245.531
246.031
246.531
247.030
247.530
248.030
248.530
249.029
249.529
250.029
250.529
251.028
251.528
252.028
252.528
253.027
253.527
254.027
254.527
255.026
255.526
256.026
256.526
257.025
257.525
258.025
258.525
259.025
259.524

(b) (3) (A)

260.024
260.524
261.024
261.523
262.023
262.523
263.023
263.522
264.022
264.522
265.022
265.521
266.021
266.521
267.021
267.520
268.020
268.520
269.020
269.519
270.019
270.519
271.019
271.518
272.018
272.518
273.018
273.517
274.017
274.517
275.017
275.516
276.016
276.516
277.016
277.515
278.015
278.515
279.015
279.514
280.014
280.514
281.014
281.514
282.013
282.513
283.013
283.513
284.012
284.512
285.012
285.512
286.011
286.511
287.011
287.511
288.010
288.510
289.010
289.510
290.009
290.509
291.009

(b) (3) (A)

291.509
292.008
292.508
293.008
293.508
294.007
294.507
295.007
295.507
296.006
296.506
297.006
297.506
298.005
298.505
299.005
299.505
300.004
300.504
301.004
301.504
302.004
302.503
303.003
303.503
304.003
304.502
305.002
305.502
306.002
306.501
307.001
307.501
308.001
308.500
309.000
309.500
310.000
310.499
310.999
311.499
311.999
312.498
312.998
313.498
313.998
314.497
314.997
315.497
315.997
316.496
316.996
317.496
317.996
318.495
318.995
319.495
319.995
320.494
320.994
321.494
321.994
322.493

(b) (3) (A)

322.993
323.493
323.993
324.493
324.992
325.492
325.992
326.492
326.991
327.491
327.991
328.491
328.990
329.490
329.990
330.490
330.989
331.489
331.989
332.489
332.988
333.488
333.988
334.488
334.987
335.487
335.987
336.487
336.986
337.486
337.986
338.486
338.985
339.485
339.985
340.485
340.984
341.484
341.984
342.484
342.983
343.483
343.983
344.483
344.983
345.482
345.982
346.482
346.982
347.481
347.981
348.481
348.981
349.480
349.980
350.480
350.980
351.479
351.979
352.479
352.979
353.478
353.978

(b) (3) (A)

354.478
354.978
355.477
355.977
356.477
356.977
357.476
357.976
358.476
358.976
359.475
359.975
360.475
360.975
361.474
361.974
362.474
362.974
363.473
363.973
364.473
364.973
365.473
365.972
366.472
366.972
367.472
367.971
368.471
368.971
369.471
369.970
370.470
370.970
371.470
371.969
372.469
372.969
373.469
373.968
374.468
374.968
375.468
375.967
376.467
376.967
377.467
377.966
378.466
378.966
379.466
379.965
380.465
380.965
381.465
381.964
382.464
382.964
383.464
383.963
384.463
384.963
385.463

(b) (3) (A)

385.962
386.462
386.962
387.462
387.962
388.461
388.961
389.461
389.961
390.460
390.960
391.460
391.960
392.459
392.959
393.459
393.959
394.458
394.958
395.458
395.958
396.457
396.957
397.457
397.957
398.456
398.956
399.456
399.956
400.455
400.955
401.455
401.955
402.454
402.954
403.454
403.954
404.453
404.953
405.453
405.953
406.452
406.952
407.452
407.952
408.452
408.951
409.451
409.951
410.451
410.950
411.450
411.950
412.450
412.949
413.449
413.949
414.449
414.948
415.448
415.948
416.448
416.947

(b) (3) (A)

417.447
417.947
418.447
418.946
419.446
419.946
420.446
420.945
421.445
421.945
422.445
422.944
423.444
423.944
424.444
424.943
425.443
425.943
426.443
426.942
427.442
427.942
428.442
428.941
429.441
429.941
430.441
430.941
431.440
431.940
432.440
432.940
433.439
433.939
434.439
434.939
435.438
435.938
436.438
436.938
437.437
437.937
438.437
438.937
439.436
439.936
440.436
440.936
441.435
441.935
442.435
442.935
443.434
443.934
444.434
444.934
445.433
445.933
446.433
446.933
447.432
447.932
448.432

(b) (3) (A)

448.932
449.431
449.931
450.431
450.931
451.431
451.930
452.430
452.930
453.430
453.929
454.429
454.929
455.429
455.928
456.428
456.928
457.428
457.927
458.427
458.927
459.427
459.926
460.426
460.926
461.426
461.925
462.425
462.925
463.425
463.924
464.424
464.924
465.424
465.923
466.423
466.923
467.423
467.922
468.422
468.922
469.422
469.921
470.421
470.921
471.421
471.921
472.420
472.920
473.420
473.920
474.419
474.919
475.419
475.919
476.418
476.918
477.418
477.918
478.417
478.917
479.417
479.917

(b) (3) (A)

480.416
480.916
481.416
481.916
482.415
482.915
483.415
483.915
484.414
484.914
485.414
485.914
486.413
486.913
487.413
487.913
488.412
488.912
489.412
489.912
490.411
490.911
491.411
491.911
492.410
492.910
493.410
493.910
494.410
494.909
495.409
495.909
496.409
496.908
497.408
497.908
498.408
498.907
499.407
499.907
500.407
500.906
501.406
501.906
502.406
502.905
503.405
503.905
504.405
504.904
505.404
505.904
506.404
506.903
507.403
507.903
508.403
508.902
509.402
509.902
510.402
510.901
511.401

(b) (3) (A)

511.901
512.401
512.900
513.400
513.900
514.400
514.899
515.399
515.899
516.399
516.898
517.398
517.898
518.398
518.898
519.397
519.897
520.397
520.897
521.396
521.896
522.396
522.896
523.395
523.895
524.395
524.895
525.394
525.894
526.394
526.894
527.393
527.893
528.393
528.893
529.392
529.892
530.392
530.892
531.391
531.891
532.391
532.891
533.390
533.890
534.390
534.890
535.389
535.889
536.389
536.889
537.388
537.888
538.388
538.888
539.388
539.887
540.387
540.887
541.387
541.886
542.386
542.886

(b) (3) (A)

543.386
543.885
544.385
544.885
545.385
545.884
546.384
546.884
547.384
547.883
548.383
548.883
549.383
549.882
550.382
550.882
551.382
551.881
552.381
552.881
553.381
553.880
554.380
554.880
555.380
555.879
556.379
556.879
557.379
557.878
558.378
558.878
559.378
559.878
560.377
560.877
561.377
561.877
562.376
562.876
563.376
563.876
564.375
564.875
565.375
565.875
566.374
566.874
567.374
567.874
568.373
568.873
569.373
569.873
570.372
570.872
571.372
571.872
572.371
572.871
573.371
573.871
574.370

(b) (3) (A)

574.870
575.370
575.870
576.369
576.869
577.369
577.869
578.368
578.868
579.368
579.868
580.367
580.867
581.367
581.867
582.367
582.866
583.366
583.866
584.366
584.865
585.365
585.865
586.365
586.864
587.364
587.864
588.364
588.863
589.363
589.863
590.363
590.862
591.362
591.862
592.362
592.861
593.361
593.861
594.361
594.860
595.360
595.860
596.360
596.859
597.359
597.859
598.359
598.858
599.358
599.858

(b) (3) (A)

=====
Max/Min Summary

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead ft	MinHead ft	Time Reverse Grad.	MaxPressure psi	MinPressure psi	MaxTime (sec)	MinTime (sec)
Tank 12	(b) (3) (A)	(b) (3) (A)	0.000	62.157	62.157	0.00280	0.00280
Tank 2	(b) (3) (A)	(b) (3) (A)	0.000	2.661	2.661	0.00280	0.00280
I-AV-1	(b) (3) (A)	(b) (3) (A)	0.022	232.151	-5.724	326.19394	385.45432
I-AV-2	(b) (3) (A)	(b) (3) (A)	441.806	227.335	-14.391	326.19113	5.31718
I-AV-3	(b) (3) (A)	(b) (3) (A)	0.414	394.635	-14.391	331.02866	340.70370
O-AV-4	(b) (3) (A)	(b) (3) (A)	0.011	6.645	-3.551	0.21840	0.07280
O-AV-5	(b) (3) (A)	(b) (3) (A)	0.980	13.207	-7.255	0.30240	0.44520
O-AV-6	(b) (3) (A)	(b) (3) (A)	1.039	464.738	-14.391	331.02304	331.16342
J-1	(b) (3) (A)	(b) (3) (A)	0.272	378.752	-14.391	331.02304	340.72336
J-2	(b) (3) (A)	(b) (3) (A)	0.305	387.197	-14.391	331.02585	340.70651
J-3	(b) (3) (A)	(b) (3) (A)	281.926	214.030	-14.391	335.84653	58.53375
J-4	(b) (3) (A)	(b) (3) (A)	0.532	442.151	-14.391	331.02585	340.69809
J-5	(b) (3) (A)	(b) (3) (A)	0.258	18.566	-6.096	0.28000	0.12320
J-6	(b) (3) (A)	(b) (3) (A)	284.007	356.952	-14.391	335.90268	48.84579
J-4b	(b) (3) (A)	(b) (3) (A)	1.064	15.134	-9.175	0.28560	0.14000
J-4c	(b) (3) (A)	(b) (3) (A)	1.002	13.739	-8.376	0.27440	0.12880
J-4e	(b) (3) (A)	(b) (3) (A)	1.014	12.826	-7.437	0.27720	0.45080
J-4f	(b) (3) (A)	(b) (3) (A)	0.980	13.578	-7.375	0.29960	0.44520
J-4g	(b) (3) (A)	(b) (3) (A)	0.454	9.642	-7.223	0.98840	0.07840
O-AV-1	(b) (3) (A)	(b) (3) (A)	0.022	213.474	-14.391	326.19394	5.31998
O-AV-2	(b) (3) (A)	(b) (3) (A)	441.806	227.156	-14.391	326.19113	48.95499
O-AV-3	(b) (3) (A)	(b) (3) (A)	0.414	15.325	-9.940	0.28280	0.13440
I-AV-5	(b) (3) (A)	(b) (3) (A)	0.980	13.208	-7.254	0.30240	0.44520
I-AV-4	(b) (3) (A)	(b) (3) (A)	0.011	6.645	-3.549	0.21840	0.07280
I-AV-6	(b) (3) (A)	(b) (3) (A)	1.039	15.229	-10.171	0.28280	0.12040

=====
Max/Min Line Pressures

SUMMARY OF MAX/MIN LINE PRESSURES:

START NODE	END NODE	MAX PRESS. psi	MIN PRESS. psi	
Tank 12	I-AV-1	232.15	-5.72	
O-AV-1	I-AV-2	227.34	-14.39	Cavitation
O-AV-2	J-3	227.16	-14.39	Cavitation
J-1	J-2	387.20	-14.39	Cavitation
J-3	J-1	378.75	-14.39	Cavitation
J-2	I-AV-3	394.63	-14.39	Cavitation
O-AV-3	J-4b	15.33	-9.94	
J-4b	J-4c	15.13	-9.17	
J-4c	J-4e	13.74	-8.38	
J-4e	I-AV-5	13.21	-7.44	
O-AV-5	J-4f	13.58	-7.38	
J-4f	J-4g	13.58	-7.38	
J-4g	I-AV-4	9.64	-7.22	
J-1	J-4	442.15	-14.39	Cavitation
O-AV-4	Tank 2	6.64	-3.55	
I-AV-6	J-5	18.57	-10.17	
J-4	O-AV-6	464.74	-14.39	Cavitation
J-5	J-4c	18.57	-8.38	
J-3	J-6	356.95	-14.39	Cavitation

Highest Surge Pressure in the Network: 464.74 psi at Node: O-AV-6

Lowest Surge Pressure in the Network: -14.39 psi at Node: I-AV-2

***** END OF THIS SIMULATION *****


END RUN AT TIME 22:32:51

APPENDIX 'F' - Valve Testing Results

Valve Testing Results

7/12/2021 & 7/13/2021

Nameplate Data:



APPENDIX 'G' - AFHE Data

i. **Event Log**

EventId	GroupName	TagName	LoggingNode	EventType	EventState	EventPriority	EventValue	EventLimit	LimitString	ValueString	OriginationTime	EventStamp	OperatorName	OperatorNode	Comment	
527781	(b) (3) (A)		PH-VS-APP02	OPR		999	0	0			5/7/2021 3:24:58	5/6/2021 17:24:58	(b) (6)	PH-WS-HMI01	Valve Position set to Open	
527782			PH-VS-APP02	OPR		999	0	0			5/7/2021 3:33:28	5/6/2021 17:33:28		PH-WS-HMI01	Valve Position set to Close	
527783			PH-VS-APP01	OPR		999	0	0				5/7/2021 3:34:19		5/6/2021 17:34:19	PH-WS-HMI01	Audible Alarm Reset
527784			PH-VS-APP01	OPR		999	0	0				5/7/2021 3:34:21		5/6/2021 17:34:21	PH-WS-HMI01	Audible Alarm Reset
527785			PH-VS-APP02	OPR		999	0	0				5/7/2021 3:34:40		5/6/2021 17:34:40	PH-WS-HMI01	Valve Position set to Close
527786			PH-VS-APP01	OPR		999	0	0				5/7/2021 3:35:41		5/6/2021 17:35:41	PH-WS-HMI01	Alarm Acknowledged All Tank-RH-20 From Alarm Detail
527787			PH-VS-APP01	OPR		999	0	0				5/7/2021 3:35:47		5/6/2021 17:35:48	PH-WS-HMI01	Audible Alarm Reset
527788			PH-VS-APP01	OPR		999	0	0				5/7/2021 3:35:50		5/6/2021 17:35:50	PH-WS-HMI01	Audible Alarm Reset
527789			PH-VS-APP02	OPR		999	0	0				5/7/2021 3:36:12		5/6/2021 17:36:12	PH-WS-HMI01	Valve Percent Open Set To: 50%
527790			PH-VS-APP02	OPR		999	0	0				5/7/2021 3:36:55		5/6/2021 17:36:55	PH-WS-HMI01	Valve Percent Open Set To: 50%
527791			PH-VS-APP02	OPR		999	0	0				5/7/2021 3:37:45		5/6/2021 17:37:45	PH-WS-HMI01	Valve Percent Open Set To: 50%
527792			PH-VS-APP02	OPR		999	0	0				5/7/2021 3:37:54		5/6/2021 17:37:54	PH-WS-HMI01	Valve Percent Open Set To: 50%
527793			PH-VS-APP01	OPR		999	0	0				5/7/2021 3:38:53		5/6/2021 17:38:53	PH-WS-HMI01	Evolution Product Type: JPS
527794			PH-VS-APP01	OPR		999	0	0				5/7/2021 3:38:57		5/6/2021 17:38:57	PH-WS-HMI01	Evolution Type: Transfer
527795			PH-VS-APP01	OPR		999	0	0				5/7/2021 3:38:58		5/6/2021 17:38:58	PH-WS-HMI01	Product Filter Selected
527796			PH-VS-APP01	OPR		999	0	0				5/7/2021 3:39:06		5/6/2021 17:39:06	PH-WS-HMI01	Audible Alarm Reset
527797			PH-VS-APP01	OPR		999	0	0				5/7/2021 3:39:18		5/6/2021 17:39:18	PH-WS-HMI01	Evolution Client: JP-5 TRANSFER
527798			PH-VS-APP01	OPR		999	0	0				5/7/2021 3:39:31		5/6/2021 17:39:31	PH-WS-HMI01	Evolution Document Number: NWO
527799			PH-VS-APP01	OPR		999	0	0				5/7/2021 3:39:38		5/6/2021 17:39:38	PH-WS-HMI01	Evolution 4 Tank_RH_12 Selected as Source
527800			PH-VS-APP01	OPR		999	0	0				5/7/2021 3:39:43		5/6/2021 17:39:43	PH-WS-HMI01	Evolution 4 Tank_STK_1 Selected as Intermediate
527801			PH-VS-APP01	OPR		999	0	0				5/7/2021 3:39:50		5/6/2021 17:39:50	PH-WS-HMI01	Evolution 4 Tank_RH_09 Selected as Destination
527802			PH-VS-APP02	OPR		999	0	0				5/7/2021 3:40:34		5/6/2021 17:40:34	PH-WS-HMI01	Valve Position set to Close
527803			PH-VS-APP02	OPR		999	0	0				5/7/2021 3:41:54		5/6/2021 17:41:54	PH-WS-HMI02	Alarm Acknowledged All MOV-0112B From Alarm Detail
527804			PH-VS-APP01	OPR		999	0	0				5/7/2021 3:42:02		5/6/2021 17:42:02	PH-WS-HMI01	Audible Alarm Reset
527805			PH-VS-APP01	OPR		999	0	0				5/7/2021 4:00:21		5/6/2021 18:00:21	PH-WS-HMI01	Complete Evolution
527806			PH-VS-APP01	OPR		999	0	0				5/7/2021 4:00:52		5/6/2021 18:00:52	PH-WS-HMI01	Start Evolution
527807			PH-VS-APP01	OPR		999	0	0				5/7/2021 4:00:59		5/6/2021 18:00:59	PH-WS-HMI01	Log Data Was Selected
527808			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:02:31		5/6/2021 18:02:31	PH-WS-HMI01	Valve Position set to Open
527809			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:03:13		5/6/2021 18:03:13	PH-WS-HMI02	Alarm Acknowledged All MOV-0112B From Alarm Detail
527810			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:03:30		5/6/2021 18:03:30	PH-WS-HMI02	Valve Position set to Open
527811			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:04:01		5/6/2021 18:04:01	PH-WS-HMI02	Valve Position set to Stop
527812			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:04:40		5/6/2021 18:04:40	PH-WS-HMI02	Valve Percent Open Set To: 50%
527813			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:05:52		5/6/2021 18:05:52	PH-WS-HMI02	Valve Percent Open Set To: 50%
527814			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:06:24		5/6/2021 18:06:24	PH-WS-HMI01	Valve Position set to Close
527815			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:06:38		5/6/2021 18:06:38	PH-WS-HMI02	Valve Position set to Open
527816			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:06:58		5/6/2021 18:06:58	PH-WS-HMI02	Valve Position set to Close
527817			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:07:20		5/6/2021 18:07:20	PH-WS-HMI02	Valve Percent Open Set To: 50%
527818			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:07:35		5/6/2021 18:07:35	PH-WS-HMI02	Valve Position set to Stop
527819			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:07:46		5/6/2021 18:07:46	PH-WS-HMI02	Alarm Acknowledged All (b) (3) (A) From Alarm Detail
527820			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:07:47		5/6/2021 18:07:47	PH-WS-HMI02	Alarm Acknowledged All (b) (3) (A) From Alarm Detail
527821			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:07:54		5/6/2021 18:07:54	PH-WS-HMI02	Valve Position set to Open
527822			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:08:05		5/6/2021 18:08:05	PH-WS-HMI02	Valve Position set to Close
527823			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:08:25		5/6/2021 18:08:25	PH-WS-HMI02	Alarm Acknowledged All (b) (3) (A) From Alarm Detail
527824			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:08:26		5/6/2021 18:08:26	PH-WS-HMI02	Alarm Acknowledged All (b) (3) (A) From Alarm Detail
527825			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:08:37		5/6/2021 18:08:37	PH-WS-HMI02	Valve Position set to Open
527826			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:10:02		5/6/2021 18:10:02	PH-WS-HMI02	Valve Position set to Open
527827			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:12:11		5/6/2021 18:12:11	PH-WS-HMI02	Valve Position set to Close
527828			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:12:17		5/6/2021 18:12:17	PH-WS-HMI02	Valve Position set to Close
527829			PH-VS-APP01	OPR		999	0	0				5/7/2021 4:13:09		5/6/2021 18:13:09	PH-WS-HMI01	Audible Alarm Reset
527830			PH-VS-APP01	OPR		999	0	0				5/7/2021 4:13:28		5/6/2021 18:13:28	PH-WS-HMI01	Evolution Product Type: None
527831			PH-VS-APP01	OPR		999	0	0				5/7/2021 4:13:31		5/6/2021 18:13:31	PH-WS-HMI01	Evolution Type: Transfer
527832			PH-VS-APP01	OPR		999	0	0				5/7/2021 4:13:32		5/6/2021 18:13:32	PH-WS-HMI01	Product Filter Selected
527833			PH-VS-APP01	OPR		999	0	0				5/7/2021 4:13:49		5/6/2021 18:13:49	PH-WS-HMI01	Evolution Client: JP-5 TRANSFER
527834			PH-VS-APP01	OPR		999	0	0				5/7/2021 4:13:54		5/6/2021 18:13:54	PH-WS-HMI01	Evolution Document Number: NWO
527835			PH-VS-APP01	OPR		999	0	0				5/7/2021 4:13:55		5/6/2021 18:13:55	PH-WS-HMI01	Evolution P-Code: N/A
527836			PH-VS-APP01	OPR		999	0	0				5/7/2021 4:14:04		5/6/2021 18:14:04	PH-WS-HMI01	Evolution 5 Tank_RH_20 Selected as Source
527837			PH-VS-APP01	OPR		999	0	0				5/7/2021 4:14:15		5/6/2021 18:14:15	PH-WS-HMI01	Evolution 5 Tank_STK_1 Selected as Destination
527838			PH-VS-APP01	OPR		999	0	0				5/7/2021 4:16:35		5/6/2021 18:16:35	PH-WS-HMI01	Set Pump To Off
527839			PH-VS-APP01	OPR		999	0	0				5/7/2021 4:17:54		5/6/2021 18:17:54	PH-WS-HMI01	Complete Evolution
527840			PH-VS-APP01	OPR		999	0	0				5/7/2021 4:18:41		5/6/2021 18:18:41	PH-WS-HMI01	Start Evolution
527841			PH-VS-APP01	OPR		999	0	0				5/7/2021 4:18:45		5/6/2021 18:18:45	PH-WS-HMI01	Log Data Was Selected
527842			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:19:47		5/6/2021 18:19:47	PH-WS-HMI02	Valve Position set to Close
527843			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:19:59		5/6/2021 18:19:59	PH-WS-HMI02	Valve Position set to Close
527844			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:20:07		5/6/2021 18:20:07	PH-WS-HMI02	Valve Position set to Close
527845			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:20:13		5/6/2021 18:20:13	PH-WS-HMI02	Valve Position set to Close
527846			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:23:13		5/6/2021 18:23:13	PH-WS-HMI01	Valve Position set to Open
527847			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:23:58		5/6/2021 18:23:58	PH-WS-HMI01	Valve Position set to Close
527848			PH-VS-APP02	OPR		999	0	0				5/7/2021 4:24:07		5/6/2021 18:24:07	PH-WS-HMI01	Valve Position set to Close

ii. **Alarm Log**

AlarmId	GroupName	TagName	TagType	LoggingNode	Priority	AlarmType	LimitString	ValueString	OriginationTime	EventStamp	ACKTime	NormalTime	UnAckDuration	OperatorName	OperatorNode	AlarmTransition	AlarmState	Comment	AlarmDetailId
16366567	PD06_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 3:25:11	5/6/2021 17:25:11	25:16.9	25:16.8	000 00:00:00.006	NULL	NULL	NULL	NULL	NULL	6742936
16366568	PD06_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 3:26:04	5/6/2021 17:26:04	26:11.8	26:11.8	000 00:00:00.792	NULL	NULL	NULL	NULL	NULL	6742939
16366569	PD21_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 3:33:39	5/6/2021 17:33:39	33:47.0	33:47.0	000 00:00:00.008	NULL	NULL	NULL	NULL	NULL	6742943
16366570	PD21_Tanks	(b) (3) (A)	S	PH-VS-APP01	1	DSC	TRUE	TRUE	5/7/2021 3:34:13	5/6/2021 17:34:13	35:43.0	35:26.3	NULL	DefaultUser	PH-WS-HMIO1	NULL	NULL	NULL	6742946
16366571	PD21_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 3:34:36	5/6/2021 17:34:36	34:42.0	34:42.0	000 00:00:00.021	NULL	NULL	NULL	NULL	6742947	
16366572	PD21_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 3:35:08	5/6/2021 17:35:08	35:16.9	35:16.9	000 00:00:00.089	NULL	NULL	NULL	NULL	6742950	
16366573	PD21_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 3:35:57	5/6/2021 17:35:57	36:01.9	36:01.9	000 00:00:00.958	NULL	NULL	NULL	NULL	6742957	
16366574	PD02_Valves	(b) (3) (A)	S	PH-VS-APP02	1	DSC	Alarm	Alarm	5/7/2021 3:39:01	5/6/2021 17:39:01	41:53.3	03:29.3	000 00:02:52.697	DefaultUser	PH-WS-HMIO2	NULL	NULL	NULL	6742960
16366575	PD06_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 3:40:45	5/6/2021 17:40:45	40:51.7	40:51.7	000 00:00:00.997	NULL	NULL	NULL	NULL	6742961	
16366576	PD06_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 3:41:38	5/6/2021 17:41:38	41:46.7	41:46.7	000 00:00:00.999	NULL	NULL	NULL	NULL	6742964	
16366577	PD06_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:02:42	5/6/2021 18:02:42	02:51.4	02:51.4	000 00:00:00.997	NULL	NULL	NULL	NULL	6742971	
16366578	PD06_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:03:34	5/6/2021 18:03:34	03:41.4	03:41.4	000 00:00:00.999	NULL	NULL	NULL	NULL	6742975	
16366579	PD02_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:03:37	5/6/2021 18:03:37	03:46.3	03:46.3	000 00:00:00.004	NULL	NULL	NULL	NULL	6742976	
16366580	PD02_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:04:11	5/6/2021 18:04:11	04:16.3	04:16.3	000 00:00:00.006	NULL	NULL	NULL	NULL	6742981	
16366581	PD02_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:04:14	5/6/2021 18:04:14	04:21.3	04:21.3	000 00:00:00.000	NULL	NULL	NULL	NULL	6742982	
16366582	PD02_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:04:48	5/6/2021 18:04:48	04:56.3	04:56.3	000 00:00:00.996	NULL	NULL	NULL	NULL	6742987	
16366583	PD02_Valves	(b) (3) (A)	S	PH-VS-APP02	250	DSC	Alarm	Alarm	5/7/2021 4:04:52	5/6/2021 18:04:52	07:46.0	08:11.3	000 00:02:53.709	DefaultUser	PH-WS-HMIO2	NULL	NULL	NULL	6742988
16366584	PD02_Valves	(b) (3) (A)	S	PH-VS-APP02	250	DSC	Alarm	Alarm	5/7/2021 4:04:57	5/6/2021 18:04:57	07:46.0	08:11.3	000 00:02:48.717	DefaultUser	PH-WS-HMIO2	NULL	NULL	NULL	6742991
16366585	PD02_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:04:59	5/6/2021 18:04:59	05:06.3	05:06.3	000 00:00:00.999	NULL	NULL	NULL	NULL	6742992	
16366586	PD22_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:06:36	5/6/2021 18:06:36	06:41.6	06:41.6	000 00:00:00.005	NULL	NULL	NULL	NULL	6742995	
16366587	PD02_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:07:06	5/6/2021 18:07:06	07:11.3	07:11.3	000 00:00:00.996	NULL	NULL	NULL	NULL	6743000	
16366588	PD22_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:07:31	5/6/2021 18:07:31	07:36.6	07:36.6	000 00:00:00.999	NULL	NULL	NULL	NULL	6743003	
16366589	PD02_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:07:31	5/6/2021 18:07:31	07:36.3	07:36.3	000 00:00:00.003	NULL	NULL	NULL	NULL	6743004	
16366590	PD02_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:08:13	5/6/2021 18:08:13	08:21.3	08:21.3	000 00:00:00.006	NULL	NULL	NULL	NULL	6743013	
16366591	PD02_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:08:19	5/6/2021 18:08:19	08:25.0	08:26.3	000 00:00:00.712	DefaultUser	PH-WS-HMIO2	NULL	NULL	NULL	6743014
16366592	PD02_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:08:44	5/6/2021 18:08:44	08:51.3	08:51.3	000 00:00:00.996	NULL	NULL	NULL	NULL	6743019	
16366593	PD02_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:09:26	5/6/2021 18:09:26	09:31.3	09:31.3	000 00:00:00.993	NULL	NULL	NULL	NULL	6743022	
16366594	PD02_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:10:12	5/6/2021 18:10:12	10:21.3	10:21.3	000 00:00:00.004	NULL	NULL	NULL	NULL	6743025	
16366595	PD02_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:11:04	5/6/2021 18:11:04	11:11.3	11:11.3	000 00:00:00.998	NULL	NULL	NULL	NULL	6743028	
16366596	PD02_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:12:18	5/6/2021 18:12:18	12:26.2	12:26.2	000 00:00:00.999	NULL	NULL	NULL	NULL	6743031	
16366597	PD02_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:12:24	5/6/2021 18:12:24	12:31.2	12:31.2	000 00:00:00.003	NULL	NULL	NULL	NULL	6743032	
16366598	Evolution	(b) (3) (A)	S	PH-VS-APP01	1	DSC	TRUE	TRUE	5/7/2021 4:12:58	5/6/2021 18:12:58	37:26.5	17:57.8	NULL	DefaultUser	NULL	NULL	NULL	NULL	6743039
16366599	PD02_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:13:00	5/6/2021 18:13:00	13:06.2	13:06.2	000 00:00:00.995	NULL	NULL	NULL	NULL	6743040	
16366600	PD02_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:13:19	5/6/2021 18:13:19	13:26.2	13:26.2	000 00:00:00.998	NULL	NULL	NULL	NULL	6743043	
16366601	PD22_Pumps	(b) (3) (A)	S	PH-VS-APP01	500	DSC	TRUE	TRUE	5/7/2021 4:16:27	5/6/2021 18:16:27	NULL	16:27.7	NULL	NULL	NULL	NULL	NULL	6743048	
16366602	PD18_Pumps	(b) (3) (A)	S	PH-VS-APP01	500	DSC	TRUE	TRUE	5/7/2021 4:16:40	5/6/2021 18:16:40	NULL	16:40.6	NULL	NULL	NULL	NULL	NULL	6743050	
16366603	PD22_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:19:55	5/6/2021 18:19:55	20:01.5	20:01.5	000 00:00:00.979	NULL	NULL	NULL	NULL	6743054	
16366604	PD22_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:20:02	5/6/2021 18:20:02	20:11.5	20:11.5	000 00:00:00.004	NULL	NULL	NULL	NULL	6743057	
16366605	PD22_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:20:10	5/6/2021 18:20:10	20:16.5	20:16.5	000 00:00:00.995	NULL	NULL	NULL	NULL	6743058	
16366606	PD22_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:20:29	5/6/2021 18:20:29	20:36.5	20:36.5	000 00:00:00.983	NULL	NULL	NULL	NULL	6743063	
16366607	PD22_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:23:25	5/6/2021 18:23:25	23:31.5	23:31.5	000 00:00:00.021	NULL	NULL	NULL	NULL	6743066	
16366608	PD08_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:24:09	5/6/2021 18:24:09	24:16.2	24:16.2	000 00:00:00.977	NULL	NULL	NULL	NULL	6743069	
16366609	PD09_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:24:16	5/6/2021 18:24:16	24:21.3	24:21.3	000 00:00:00.034	NULL	NULL	NULL	NULL	6743072	
16366610	PD22_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:24:19	5/6/2021 18:24:19	24:26.4	24:26.4	000 00:00:00.008	NULL	NULL	NULL	NULL	6743073	
16366611	PD11_Valves	(b) (3) (A)	S	PH-VS-APP02	250	DSC	Alarm	Alarm	5/7/2021 4:24:58	5/6/2021 18:24:58	NULL	25:48.3	NULL	NULL	NULL	NULL	NULL	6743084	
16366611	PD08_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:25:07	5/6/2021 18:25:07	25:16.2	25:16.2	000 00:00:00.002	NULL	NULL	NULL	NULL	6743078	
16366612	PD09_Valves	(b) (3) (A)	S	PH-VS-APP02	500	DSC	TRUE	TRUE	5/7/2021 4:25:09	5/6/2021 18:25:09	25:16.3	25:16.3	000 00:00:00.009	NULL	NULL	NULL	NULL	6743079	

(b) (3) (A) Status: Off, LOR: Remote
(b) (3) (A) Status: Off-Cooling 19 sec, LOR: Remote

(b) (3) (A) Network Channel A Failed

iii. Data Export

Time	Tag Name	Server	Value	Quality
5/6/2021 17:15:00	(b) (3) (A)	PH-VS-SQL	4	Good
5/6/2021 17:15:00	(b) (3) (A)	PH-VS-SQL	2	Good
5/6/2021 17:15:00	(b) (3) (A)	PH-VS-SQL	107	Good
5/6/2021 17:15:00	(b) (3) (A)	PH-VS-SQL	213092	Good
5/6/2021 17:15:00	(b) (3) (A)	PH-VS-SQL	272297	Good
5/6/2021 17:15:00	(b) (3) (A)	PH-VS-SQL	1233	Good
5/6/2021 17:15:03	(b) (3) (A)	PH-VS-SQL	213092	Good
5/6/2021 17:15:03	(b) (3) (A)	PH-VS-SQL	1231	Good
5/6/2021 17:15:08	(b) (3) (A)	PH-VS-SQL	137	Good
5/6/2021 17:15:14	(b) (3) (A)	PH-VS-SQL	1233	Good
5/6/2021 17:15:19	(b) (3) (A)	PH-VS-SQL	106	Good
5/6/2021 17:15:20	(b) (3) (A)	PH-VS-SQL	110	Good
5/6/2021 17:15:27	(b) (3) (A)	PH-VS-SQL	136	Good
5/6/2021 17:15:33	(b) (3) (A)	PH-VS-SQL	213092	Good
5/6/2021 17:15:33	(b) (3) (A)	PH-VS-SQL	1227	Good
5/6/2021 17:15:38	(b) (3) (A)	PH-VS-SQL	107	Good
5/6/2021 17:15:39	(b) (3) (A)	PH-VS-SQL	109	Good
5/6/2021 17:15:40	(b) (3) (A)	PH-VS-SQL	112	Good
5/6/2021 17:15:43	(b) (3) (A)	PH-VS-SQL	1239	Good
5/6/2021 17:15:44	(b) (3) (A)	PH-VS-SQL	272297	Good
5/6/2021 17:15:48	(b) (3) (A)	PH-VS-SQL	135	Good
5/6/2021 17:15:53	(b) (3) (A)	PH-VS-SQL	213092	Good
5/6/2021 17:15:53	(b) (3) (A)	PH-VS-SQL	1232	Good
5/6/2021 17:15:57	(b) (3) (A)	PH-VS-SQL	108	Good
5/6/2021 17:15:58	(b) (3) (A)	PH-VS-SQL	108	Good
5/6/2021 17:15:59	(b) (3) (A)	PH-VS-SQL	110	Good
5/6/2021 17:16:03	(b) (3) (A)	PH-VS-SQL	1235	Good
5/6/2021 17:16:07	(b) (3) (A)	PH-VS-SQL	135	Good
5/6/2021 17:16:14	(b) (3) (A)	PH-VS-SQL	1238	Good
5/6/2021 17:16:17	(b) (3) (A)	PH-VS-SQL	109	Good
5/6/2021 17:16:18	(b) (3) (A)	PH-VS-SQL	109	Good
5/6/2021 17:16:19	(b) (3) (A)	PH-VS-SQL	111	Good
5/6/2021 17:16:23	(b) (3) (A)	PH-VS-SQL	213092	Good
5/6/2021 17:16:23	(b) (3) (A)	PH-VS-SQL	1231	Good
5/6/2021 17:16:27	(b) (3) (A)	PH-VS-SQL	134	Good
5/6/2021 17:16:33	(b) (3) (A)	PH-VS-SQL	1234	Good
5/6/2021 17:16:36	(b) (3) (A)	PH-VS-SQL	109	Good
5/6/2021 17:16:38	(b) (3) (A)	PH-VS-SQL	110	Good
5/6/2021 17:16:39	(b) (3) (A)	PH-VS-SQL	112	Good
5/6/2021 17:16:43	(b) (3) (A)	PH-VS-SQL	1233	Good
5/6/2021 17:16:46	(b) (3) (A)	PH-VS-SQL	133	Good
5/6/2021 17:16:53	(b) (3) (A)	PH-VS-SQL	1236	Good
5/6/2021 17:16:56	(b) (3) (A)	PH-VS-SQL	110	Good
5/6/2021 17:16:57	(b) (3) (A)	PH-VS-SQL	110	Good
5/6/2021 17:16:58	(b) (3) (A)	PH-VS-SQL	111	Good
5/6/2021 17:17:03	(b) (3) (A)	PH-VS-SQL	1239	Good

5/6/2021 17:17:06	(b) (3) (A)	PH-VS-SQL	133	Good
5/6/2021 17:17:14	(b) (3) (A)	PH-VS-SQL	1235	Good
5/6/2021 17:17:16	(b) (3) (A)	PH-VS-SQL	110	Good
5/6/2021 17:17:17	(b) (3) (A)	PH-VS-SQL	111	Good
5/6/2021 17:17:18	(b) (3) (A)	PH-VS-SQL	113	Good
5/6/2021 17:17:23	(b) (3) (A)	PH-VS-SQL	1236	Good
5/6/2021 17:17:26	(b) (3) (A)	PH-VS-SQL	132	Good
5/6/2021 17:17:33	(b) (3) (A)	PH-VS-SQL	1230	Good
5/6/2021 17:17:37	(b) (3) (A)	PH-VS-SQL	111	Good
5/6/2021 17:17:38	(b) (3) (A)	PH-VS-SQL	113	Good
5/6/2021 17:17:44	(b) (3) (A)	PH-VS-SQL	1237	Good
5/6/2021 17:17:45	(b) (3) (A)	PH-VS-SQL	132	Good
5/6/2021 17:17:53	(b) (3) (A)	PH-VS-SQL	1230	Good
5/6/2021 17:17:55	(b) (3) (A)	PH-VS-SQL	111	Good
5/6/2021 17:17:56	(b) (3) (A)	PH-VS-SQL	112	Good
5/6/2021 17:17:57	(b) (3) (A)	PH-VS-SQL	112	Good
5/6/2021 17:18:03	(b) (3) (A)	PH-VS-SQL	1236	Good
5/6/2021 17:18:05	(b) (3) (A)	PH-VS-SQL	131	Good
5/6/2021 17:18:13	(b) (3) (A)	PH-VS-SQL	213092	Good
5/6/2021 17:18:15	(b) (3) (A)	PH-VS-SQL	112	Good
5/6/2021 17:18:16	(b) (3) (A)	PH-VS-SQL	112	Good
5/6/2021 17:18:17	(b) (3) (A)	PH-VS-SQL	114	Good
5/6/2021 17:18:23	(b) (3) (A)	PH-VS-SQL	1239	Good
5/6/2021 17:18:24	(b) (3) (A)	PH-VS-SQL	272297	Good
5/6/2021 17:18:25	(b) (3) (A)	PH-VS-SQL	131	Good
5/6/2021 17:18:33	(b) (3) (A)	PH-VS-SQL	1235	Good
5/6/2021 17:18:34	(b) (3) (A)	PH-VS-SQL	112	Good
5/6/2021 17:18:35	(b) (3) (A)	PH-VS-SQL	113	Good
5/6/2021 17:18:36	(b) (3) (A)	PH-VS-SQL	113	Good
5/6/2021 17:18:43	(b) (3) (A)	PH-VS-SQL	1235	Good
5/6/2021 17:18:45	(b) (3) (A)	PH-VS-SQL	130	Good
5/6/2021 17:18:54	(b) (3) (A)	PH-VS-SQL	272297	Good
5/6/2021 17:18:54	(b) (3) (A)	PH-VS-SQL	113	Good
5/6/2021 17:18:55	(b) (3) (A)	PH-VS-SQL	113	Good
5/6/2021 17:18:56	(b) (3) (A)	PH-VS-SQL	113	Good
5/6/2021 17:19:03	(b) (3) (A)	PH-VS-SQL	1232	Good
5/6/2021 17:19:04	(b) (3) (A)	PH-VS-SQL	130	Good
5/6/2021 17:19:14	(b) (3) (A)	PH-VS-SQL	1232	Good
5/6/2021 17:19:14	(b) (3) (A)	PH-VS-SQL	113	Good
5/6/2021 17:19:15	(b) (3) (A)	PH-VS-SQL	114	Good
5/6/2021 17:19:16	(b) (3) (A)	PH-VS-SQL	115	Good
5/6/2021 17:19:25	(b) (3) (A)	PH-VS-SQL	129	Good
5/6/2021 17:19:33	(b) (3) (A)	PH-VS-SQL	1235	Good
5/6/2021 17:19:34	(b) (3) (A)	PH-VS-SQL	114	Good
5/6/2021 17:19:35	(b) (3) (A)	PH-VS-SQL	114	Good
5/6/2021 17:19:43	(b) (3) (A)	PH-VS-SQL	1233	Good
5/6/2021 17:19:44	(b) (3) (A)	PH-VS-SQL	272297	Good

(b) (3) (A)

5/6/2021 17:19:45	PH-VS-SQL	129	Good
5/6/2021 17:19:53	PH-VS-SQL	114	Good
5/6/2021 17:19:53	PH-VS-SQL	1236	Good
5/6/2021 17:19:54	PH-VS-SQL	114	Good
5/6/2021 17:19:55	PH-VS-SQL	115	Good
5/6/2021 17:20:03	PH-VS-SQL	129	Good
5/6/2021 17:20:03	PH-VS-SQL	1235	Good
5/6/2021 17:20:12	PH-VS-SQL	115	Good
5/6/2021 17:20:14	PH-VS-SQL	1234	Good
5/6/2021 17:20:14	PH-VS-SQL	272297	Good
5/6/2021 17:20:14	PH-VS-SQL	115	Good
5/6/2021 17:20:15	PH-VS-SQL	116	Good
5/6/2021 17:20:23	PH-VS-SQL	128	Good
5/6/2021 17:20:23	PH-VS-SQL	1237	Good
5/6/2021 17:20:33	PH-VS-SQL	115	Good
5/6/2021 17:20:33	PH-VS-SQL	1236	Good
5/6/2021 17:20:34	PH-VS-SQL	115	Good
5/6/2021 17:20:42	PH-VS-SQL	128	Good
5/6/2021 17:20:43	PH-VS-SQL	272297	Good
5/6/2021 17:20:53	PH-VS-SQL	115	Good
5/6/2021 17:20:53	PH-VS-SQL	1234	Good
5/6/2021 17:20:54	PH-VS-SQL	116	Good
5/6/2021 17:21:02	PH-VS-SQL	128	Good
5/6/2021 17:21:03	PH-VS-SQL	1233	Good
5/6/2021 17:21:03	PH-VS-SQL	272297	Good
5/6/2021 17:21:12	PH-VS-SQL	115	Good
5/6/2021 17:21:13	PH-VS-SQL	115	Good
5/6/2021 17:21:14	PH-VS-SQL	1232	Good
5/6/2021 17:21:22	PH-VS-SQL	127	Good
5/6/2021 17:21:32	PH-VS-SQL	116	Good
5/6/2021 17:21:33	PH-VS-SQL	116	Good
5/6/2021 17:21:33	PH-VS-SQL	1234	Good
5/6/2021 17:21:33	PH-VS-SQL	272297	Good
5/6/2021 17:21:41	PH-VS-SQL	127	Good
5/6/2021 17:21:44	PH-VS-SQL	1236	Good
5/6/2021 17:21:52	PH-VS-SQL	116	Good
5/6/2021 17:21:53	PH-VS-SQL	116	Good
5/6/2021 17:21:53	PH-VS-SQL	1235	Good
5/6/2021 17:22:01	PH-VS-SQL	126	Good
5/6/2021 17:22:03	PH-VS-SQL	1235	Good
5/6/2021 17:22:03	PH-VS-SQL	272297	Good
5/6/2021 17:22:11	PH-VS-SQL	116	Good
5/6/2021 17:22:12	PH-VS-SQL	116	Good
5/6/2021 17:22:13	PH-VS-SQL	1234	Good
5/6/2021 17:22:22	PH-VS-SQL	126	Good
5/6/2021 17:22:23	PH-VS-SQL	1233	Good
5/6/2021 17:22:31	PH-VS-SQL	116	Good

(b) (3) (A)

5/6/2021 17:22:32	PH-VS-SQL	117	Good
5/6/2021 17:22:33	PH-VS-SQL	1235	Good
5/6/2021 17:22:33	PH-VS-SQL	272297	Good
5/6/2021 17:22:41	PH-VS-SQL	126	Good
5/6/2021 17:22:44	PH-VS-SQL	1233	Good
5/6/2021 17:22:51	PH-VS-SQL	117	Good
5/6/2021 17:22:52	PH-VS-SQL	117	Good
5/6/2021 17:22:53	PH-VS-SQL	1234	Good
5/6/2021 17:23:01	PH-VS-SQL	126	Good
5/6/2021 17:23:03	PH-VS-SQL	1235	Good
5/6/2021 17:23:10	PH-VS-SQL	118	Good
5/6/2021 17:23:11	PH-VS-SQL	117	Good
5/6/2021 17:23:13	PH-VS-SQL	1236	Good
5/6/2021 17:23:21	PH-VS-SQL	126	Good
5/6/2021 17:23:23	PH-VS-SQL	272297	Good
5/6/2021 17:23:30	PH-VS-SQL	117	Good
5/6/2021 17:23:31	PH-VS-SQL	118	Good
5/6/2021 17:23:33	PH-VS-SQL	1234	Good
5/6/2021 17:23:41	PH-VS-SQL	125	Good
5/6/2021 17:23:44	PH-VS-SQL	213092	Good
5/6/2021 17:23:44	PH-VS-SQL	1234	Good
5/6/2021 17:23:50	PH-VS-SQL	117	Good
5/6/2021 17:23:51	PH-VS-SQL	117	Good
5/6/2021 17:23:53	PH-VS-SQL	1234	Good
5/6/2021 17:23:53	PH-VS-SQL	272297	Good
5/6/2021 17:23:58	PH-VS-SQL	125	Good
5/6/2021 17:24:03	PH-VS-SQL	1234	Good
5/6/2021 17:24:09	PH-VS-SQL	117	Good
5/6/2021 17:24:10	PH-VS-SQL	117	Good
5/6/2021 17:24:14	PH-VS-SQL	1234	Good
5/6/2021 17:24:19	PH-VS-SQL	125	Good
5/6/2021 17:24:23	PH-VS-SQL	1234	Good
5/6/2021 17:24:24	PH-VS-SQL	272297	Good
5/6/2021 17:24:29	PH-VS-SQL	118	Good
5/6/2021 17:24:30	PH-VS-SQL	118	Good
5/6/2021 17:24:33	PH-VS-SQL	1235	Good
5/6/2021 17:24:38	PH-VS-SQL	125	Good
5/6/2021 17:24:43	PH-VS-SQL	1234	Good
5/6/2021 17:24:48	PH-VS-SQL	119	Good
5/6/2021 17:24:49	PH-VS-SQL	118	Good
5/6/2021 17:24:53	PH-VS-SQL	1234	Good
5/6/2021 17:24:53	PH-VS-SQL	272297	Good
5/6/2021 17:24:58	PH-VS-SQL	125	Good
5/6/2021 17:25:03	PH-VS-SQL	1234	Good
5/6/2021 17:25:08	PH-VS-SQL	118	Good
5/6/2021 17:25:09	PH-VS-SQL	118	Good
5/6/2021 17:25:14	PH-VS-SQL	1234	Good

(b) (3) (A)

5/6/2021 17:25:14	PH-VS-SQL	110	Good
5/6/2021 17:25:23	PH-VS-SQL	1235	Good
5/6/2021 17:25:28	PH-VS-SQL	131	Good
5/6/2021 17:25:29	PH-VS-SQL	130	Good
5/6/2021 17:25:33	PH-VS-SQL	1237	Good
5/6/2021 17:25:37	PH-VS-SQL	112	Good
5/6/2021 17:25:43	PH-VS-SQL	1237	Good
5/6/2021 17:25:47	PH-VS-SQL	128	Good
5/6/2021 17:25:48	PH-VS-SQL	127	Good
5/6/2021 17:25:53	PH-VS-SQL	1237	Good
5/6/2021 17:25:54	PH-VS-SQL	115	Good
5/6/2021 17:26:03	PH-VS-SQL	1239	Good
5/6/2021 17:26:07	PH-VS-SQL	127	Good
5/6/2021 17:26:08	PH-VS-SQL	126	Good
5/6/2021 17:26:14	PH-VS-SQL	272297	Good
5/6/2021 17:26:15	PH-VS-SQL	116	Good
5/6/2021 17:26:23	PH-VS-SQL	1241	Good
5/6/2021 17:26:27	PH-VS-SQL	125	Good
5/6/2021 17:26:28	PH-VS-SQL	124	Good
5/6/2021 17:26:33	PH-VS-SQL	1242	Good
5/6/2021 17:26:36	PH-VS-SQL	117	Good
5/6/2021 17:26:43	PH-VS-SQL	1243	Good
5/6/2021 17:26:44	PH-VS-SQL	125	Good
5/6/2021 17:26:46	PH-VS-SQL	124	Good
5/6/2021 17:26:47	PH-VS-SQL	123	Good
5/6/2021 17:26:53	PH-VS-SQL	213092	Good
5/6/2021 17:26:53	PH-VS-SQL	1244	Good
5/6/2021 17:26:54	PH-VS-SQL	117	Good
5/6/2021 17:27:03	PH-VS-SQL	1245	Good
5/6/2021 17:27:04	PH-VS-SQL	272297	Good
5/6/2021 17:27:04	PH-VS-SQL	124	Good
5/6/2021 17:27:06	PH-VS-SQL	123	Good
5/6/2021 17:27:07	PH-VS-SQL	123	Good
5/6/2021 17:27:13	PH-VS-SQL	213092	Good
5/6/2021 17:27:13	PH-VS-SQL	1246	Good
5/6/2021 17:27:14	PH-VS-SQL	118	Good
5/6/2021 17:27:20	PH-VS-SQL	123	Good
5/6/2021 17:27:23	PH-VS-SQL	1247	Good
5/6/2021 17:27:25	PH-VS-SQL	122	Good
5/6/2021 17:27:26	PH-VS-SQL	122	Good
5/6/2021 17:27:30	PH-VS-SQL	119	Good
5/6/2021 17:27:43	PH-VS-SQL	1250	Good
5/6/2021 17:27:44	PH-VS-SQL	123	Good
5/6/2021 17:27:45	PH-VS-SQL	122	Good
5/6/2021 17:27:46	PH-VS-SQL	122	Good
5/6/2021 17:27:53	PH-VS-SQL	1251	Good
5/6/2021 17:27:54	PH-VS-SQL	119	Good

(b) (3) (A)

5/6/2021 17:28:02	PH-VS-SQL	123	Good
5/6/2021 17:28:03	PH-VS-SQL	1250	Good
5/6/2021 17:28:05	PH-VS-SQL	121	Good
5/6/2021 17:28:06	PH-VS-SQL	121	Good
5/6/2021 17:28:13	PH-VS-SQL	120	Good
5/6/2021 17:28:14	PH-VS-SQL	213092	Good
5/6/2021 17:28:14	PH-VS-SQL	1254	Good
5/6/2021 17:28:22	PH-VS-SQL	122	Good
5/6/2021 17:28:23	PH-VS-SQL	1253	Good
5/6/2021 17:28:24	PH-VS-SQL	122	Good
5/6/2021 17:28:25	PH-VS-SQL	121	Good
5/6/2021 17:28:32	PH-VS-SQL	120	Good
5/6/2021 17:28:33	PH-VS-SQL	1255	Good
5/6/2021 17:28:39	PH-VS-SQL	122	Good
5/6/2021 17:28:43	PH-VS-SQL	1254	Good
5/6/2021 17:28:44	PH-VS-SQL	121	Good
5/6/2021 17:28:45	PH-VS-SQL	121	Good
5/6/2021 17:28:50	PH-VS-SQL	120	Good
5/6/2021 17:28:53	PH-VS-SQL	1256	Good
5/6/2021 17:28:58	PH-VS-SQL	122	Good
5/6/2021 17:29:03	PH-VS-SQL	213092	Good
5/6/2021 17:29:03	PH-VS-SQL	1256	Good
5/6/2021 17:29:04	PH-VS-SQL	122	Good
5/6/2021 17:29:05	PH-VS-SQL	121	Good
5/6/2021 17:29:10	PH-VS-SQL	120	Good
5/6/2021 17:29:13	PH-VS-SQL	1258	Good
5/6/2021 17:29:22	PH-VS-SQL	122	Good
5/6/2021 17:29:23	PH-VS-SQL	121	Good
5/6/2021 17:29:23	PH-VS-SQL	1259	Good
5/6/2021 17:29:24	PH-VS-SQL	121	Good
5/6/2021 17:29:29	PH-VS-SQL	120	Good
5/6/2021 17:29:33	PH-VS-SQL	1261	Good
5/6/2021 17:29:41	PH-VS-SQL	122	Good
5/6/2021 17:29:43	PH-VS-SQL	122	Good
5/6/2021 17:29:43	PH-VS-SQL	1262	Good
5/6/2021 17:29:44	PH-VS-SQL	121	Good
5/6/2021 17:29:47	PH-VS-SQL	120	Good
5/6/2021 17:29:53	PH-VS-SQL	1264	Good
5/6/2021 17:29:54	PH-VS-SQL	272297	Good
5/6/2021 17:29:57	PH-VS-SQL	122	Good
5/6/2021 17:30:03	PH-VS-SQL	121	Good
5/6/2021 17:30:03	PH-VS-SQL	1264	Good
5/6/2021 17:30:04	PH-VS-SQL	121	Good
5/6/2021 17:30:08	PH-VS-SQL	120	Good
5/6/2021 17:30:13	PH-VS-SQL	213092	Good
5/6/2021 17:30:19	PH-VS-SQL	122	Good
5/6/2021 17:30:22	PH-VS-SQL	122	Good

(b) (3) (A)

5/6/2021 17:30:23	PH-VS-SQL	122	Good
5/6/2021 17:30:23	PH-VS-SQL	1264	Good
5/6/2021 17:30:23	PH-VS-SQL	272297	Good
5/6/2021 17:30:27	PH-VS-SQL	120	Good
5/6/2021 17:30:33	PH-VS-SQL	1264	Good
5/6/2021 17:30:38	PH-VS-SQL	122	Good
5/6/2021 17:30:42	PH-VS-SQL	121	Good
5/6/2021 17:30:43	PH-VS-SQL	121	Good
5/6/2021 17:30:43	PH-VS-SQL	213092	Good
5/6/2021 17:30:43	PH-VS-SQL	1270	Good
5/6/2021 17:30:52	PH-VS-SQL	120	Good
5/6/2021 17:30:53	PH-VS-SQL	1269	Good
5/6/2021 17:30:55	PH-VS-SQL	122	Good
5/6/2021 17:31:01	PH-VS-SQL	121	Good
5/6/2021 17:31:02	PH-VS-SQL	121	Good
5/6/2021 17:31:03	PH-VS-SQL	1268	Good
5/6/2021 17:31:10	PH-VS-SQL	121	Good
5/6/2021 17:31:13	PH-VS-SQL	213092	Good
5/6/2021 17:31:14	PH-VS-SQL	1273	Good
5/6/2021 17:31:14	PH-VS-SQL	272297	Good
5/6/2021 17:31:17	PH-VS-SQL	122	Good
5/6/2021 17:31:21	PH-VS-SQL	121	Good
5/6/2021 17:31:22	PH-VS-SQL	121	Good
5/6/2021 17:31:23	PH-VS-SQL	1273	Good
5/6/2021 17:31:27	PH-VS-SQL	121	Good
5/6/2021 17:31:33	PH-VS-SQL	213092	Good
5/6/2021 17:31:33	PH-VS-SQL	1274	Good
5/6/2021 17:31:35	PH-VS-SQL	122	Good
5/6/2021 17:31:40	PH-VS-SQL	121	Good
5/6/2021 17:31:42	PH-VS-SQL	121	Good
5/6/2021 17:31:43	PH-VS-SQL	122	Good
5/6/2021 17:31:43	PH-VS-SQL	1274	Good
5/6/2021 17:31:44	PH-VS-SQL	272297	Good
5/6/2021 17:31:53	PH-VS-SQL	1275	Good
5/6/2021 17:32:00	PH-VS-SQL	121	Good
5/6/2021 17:32:01	PH-VS-SQL	121	Good
5/6/2021 17:32:03	PH-VS-SQL	1278	Good
5/6/2021 17:32:07	PH-VS-SQL	122	Good
5/6/2021 17:32:14	PH-VS-SQL	1277	Good
5/6/2021 17:32:14	PH-VS-SQL	272297	Good
5/6/2021 17:32:18	PH-VS-SQL	121	Good
5/6/2021 17:32:20	PH-VS-SQL	121	Good
5/6/2021 17:32:21	PH-VS-SQL	122	Good
5/6/2021 17:32:23	PH-VS-SQL	1278	Good
5/6/2021 17:32:28	PH-VS-SQL	122	Good
5/6/2021 17:32:31	PH-VS-SQL	121	Good
5/6/2021 17:32:33	PH-VS-SQL	1278	Good

(b) (3) (A)

5/6/2021 17:32:33	PH-VS-SQL	272253	Good
5/6/2021 17:32:40	PH-VS-SQL	121	Good
5/6/2021 17:32:41	PH-VS-SQL	121	Good
5/6/2021 17:32:43	PH-VS-SQL	1279	Good
5/6/2021 17:32:53	PH-VS-SQL	122	Good
5/6/2021 17:32:53	PH-VS-SQL	1278	Good
5/6/2021 17:32:54	PH-VS-SQL	120	Good
5/6/2021 17:32:59	PH-VS-SQL	121	Good
5/6/2021 17:33:00	PH-VS-SQL	121	Good
5/6/2021 17:33:03	PH-VS-SQL	1281	Good
5/6/2021 17:33:04	PH-VS-SQL	272250	Good
5/6/2021 17:33:12	PH-VS-SQL	122	Good
5/6/2021 17:33:14	PH-VS-SQL	1282	Good
5/6/2021 17:33:17	PH-VS-SQL	121	Good
5/6/2021 17:33:19	PH-VS-SQL	121	Good
5/6/2021 17:33:21	PH-VS-SQL	121	Good
5/6/2021 17:33:23	PH-VS-SQL	1285	Good
5/6/2021 17:33:26	PH-VS-SQL	121	Good
5/6/2021 17:33:33	PH-VS-SQL	122	Good
5/6/2021 17:33:33	PH-VS-SQL	1286	Good
5/6/2021 17:33:33	PH-VS-SQL	272246	Good
5/6/2021 17:33:38	PH-VS-SQL	121	Good
5/6/2021 17:33:39	PH-VS-SQL	122	Good
5/6/2021 17:33:42	PH-VS-SQL	121	Good
5/6/2021 17:33:43	PH-VS-SQL	213092	Good
5/6/2021 17:33:43	PH-VS-SQL	1288	Good
5/6/2021 17:33:44	PH-VS-SQL	122	Good
5/6/2021 17:33:53	PH-VS-SQL	1289	Good
5/6/2021 17:33:58	PH-VS-SQL	121	Good
5/6/2021 17:33:59	PH-VS-SQL	121	Good
5/6/2021 17:34:01	PH-VS-SQL	122	Good
5/6/2021 17:34:03	PH-VS-SQL	1286	Good
5/6/2021 17:34:04	PH-VS-SQL	272245	Good
5/6/2021 17:34:13	PH-VS-SQL	213092	Good
5/6/2021 17:34:13	PH-VS-SQL	1289	Good
5/6/2021 17:34:18	PH-VS-SQL	120	Good
5/6/2021 17:34:19	PH-VS-SQL	121	Good
5/6/2021 17:34:23	PH-VS-SQL	1289	Good
5/6/2021 17:34:24	PH-VS-SQL	272244	Good
5/6/2021 17:34:33	PH-VS-SQL	1294	Good
5/6/2021 17:34:37	PH-VS-SQL	93	Good
5/6/2021 17:34:38	PH-VS-SQL	91	Good
5/6/2021 17:34:43	PH-VS-SQL	213092	Good
5/6/2021 17:34:43	PH-VS-SQL	1290	Good
5/6/2021 17:34:53	PH-VS-SQL	1292	Good
5/6/2021 17:34:54	PH-VS-SQL	272245	Good
5/6/2021 17:34:57	PH-VS-SQL	56	Good

(b) (3) (A)

5/6/2021 17:34:58	PH-VS-SQL	55	Good
5/6/2021 17:35:03	PH-VS-SQL	1294	Good
5/6/2021 17:35:13	PH-VS-SQL	213092	Good
5/6/2021 17:35:14	PH-VS-SQL	1297	Good
5/6/2021 17:35:17	PH-VS-SQL	38	Good
5/6/2021 17:35:18	PH-VS-SQL	38	Good
5/6/2021 17:35:23	PH-VS-SQL	1293	Good
5/6/2021 17:35:24	PH-VS-SQL	272244	Good
5/6/2021 17:35:33	PH-VS-SQL	1297	Good
5/6/2021 17:35:36	PH-VS-SQL	32	Good
5/6/2021 17:35:37	PH-VS-SQL	32	Good
5/6/2021 17:35:41	PH-VS-SQL	31	Good
5/6/2021 17:35:44	PH-VS-SQL	1294	Good
5/6/2021 17:35:53	PH-VS-SQL	272243	Good
5/6/2021 17:35:56	PH-VS-SQL	32	Good
5/6/2021 17:35:57	PH-VS-SQL	32	Good
5/6/2021 17:36:03	PH-VS-SQL	31	Good
5/6/2021 17:36:03	PH-VS-SQL	1295	Good
5/6/2021 17:36:13	PH-VS-SQL	1300	Good
5/6/2021 17:36:14	PH-VS-SQL	272243	Good
5/6/2021 17:36:14	PH-VS-SQL	32	Good
5/6/2021 17:36:16	PH-VS-SQL	31	Good
5/6/2021 17:36:17	PH-VS-SQL	31	Good
5/6/2021 17:36:18	PH-VS-SQL	32	Good
5/6/2021 17:36:23	PH-VS-SQL	1297	Good
5/6/2021 17:36:27	PH-VS-SQL	31	Good
5/6/2021 17:36:33	PH-VS-SQL	1301	Good
5/6/2021 17:36:35	PH-VS-SQL	31	Good
5/6/2021 17:36:36	PH-VS-SQL	32	Good
5/6/2021 17:36:43	PH-VS-SQL	31	Good
5/6/2021 17:36:43	PH-VS-SQL	1301	Good
5/6/2021 17:36:44	PH-VS-SQL	272243	Good
5/6/2021 17:36:54	PH-VS-SQL	32	Good
5/6/2021 17:36:55	PH-VS-SQL	31	Good
5/6/2021 17:36:56	PH-VS-SQL	31	Good
5/6/2021 17:36:58	PH-VS-SQL	31	Good
5/6/2021 17:37:00	PH-VS-SQL	31	Good
5/6/2021 17:37:03	PH-VS-SQL	1299	Good
5/6/2021 17:37:13	PH-VS-SQL	1299	Good
5/6/2021 17:37:14	PH-VS-SQL	272242	Good
5/6/2021 17:37:14	PH-VS-SQL	31	Good
5/6/2021 17:37:15	PH-VS-SQL	31	Good
5/6/2021 17:37:23	PH-VS-SQL	1301	Good
5/6/2021 17:37:24	PH-VS-SQL	31	Good
5/6/2021 17:37:32	PH-VS-SQL	31	Good
5/6/2021 17:37:33	PH-VS-SQL	1301	Good
5/6/2021 17:37:34	PH-VS-SQL	31	Good

(b) (3) (A)

5/6/2021 17:37:35	PH-VS-SQL	31	Good
5/6/2021 17:37:43	PH-VS-SQL	1305	Good
5/6/2021 17:37:44	PH-VS-SQL	272242	Good
5/6/2021 17:37:53	PH-VS-SQL	213092	Good
5/6/2021 17:37:53	PH-VS-SQL	1306	Good
5/6/2021 17:37:54	PH-VS-SQL	31	Good
5/6/2021 17:37:55	PH-VS-SQL	31	Good
5/6/2021 17:37:57	PH-VS-SQL	31	Good
5/6/2021 17:38:03	PH-VS-SQL	1302	Good
5/6/2021 17:38:03	PH-VS-SQL	272242	Good
5/6/2021 17:38:06	PH-VS-SQL	31	Good
5/6/2021 17:38:13	PH-VS-SQL	31	Good
5/6/2021 17:38:14	PH-VS-SQL	1307	Good
5/6/2021 17:38:14	PH-VS-SQL	31	Good
5/6/2021 17:38:18	PH-VS-SQL	31	Good
5/6/2021 17:38:23	PH-VS-SQL	31	Good
5/6/2021 17:38:23	PH-VS-SQL	1303	Good
5/6/2021 17:38:33	PH-VS-SQL	31	Good
5/6/2021 17:38:33	PH-VS-SQL	1306	Good
5/6/2021 17:38:33	PH-VS-SQL	272242	Good
5/6/2021 17:38:34	PH-VS-SQL	31	Good
5/6/2021 17:38:36	PH-VS-SQL	30	Good
5/6/2021 17:38:42	PH-VS-SQL	31	Good
5/6/2021 17:38:44	PH-VS-SQL	1305	Good
5/6/2021 17:38:53	PH-VS-SQL	31	Good
5/6/2021 17:38:53	PH-VS-SQL	1305	Good
5/6/2021 17:38:54	PH-VS-SQL	31	Good
5/6/2021 17:38:57	PH-VS-SQL	30	Good
5/6/2021 17:39:02	PH-VS-SQL	31	Good
5/6/2021 17:39:03	PH-VS-SQL	1310	Good
5/6/2021 17:39:04	PH-VS-SQL	272241	Good
5/6/2021 17:39:12	PH-VS-SQL	30	Good
5/6/2021 17:39:13	PH-VS-SQL	31	Good
5/6/2021 17:39:14	PH-VS-SQL	1311	Good
5/6/2021 17:39:18	PH-VS-SQL	31	Good
5/6/2021 17:39:23	PH-VS-SQL	1310	Good
5/6/2021 17:39:27	PH-VS-SQL	30	Good
5/6/2021 17:39:32	PH-VS-SQL	30	Good
5/6/2021 17:39:33	PH-VS-SQL	30	Good
5/6/2021 17:39:33	PH-VS-SQL	1309	Good
5/6/2021 17:39:34	PH-VS-SQL	272241	Good
5/6/2021 17:39:43	PH-VS-SQL	1309	Good
5/6/2021 17:39:47	PH-VS-SQL	31	Good
5/6/2021 17:39:50	PH-VS-SQL	30	Good
5/6/2021 17:39:52	PH-VS-SQL	30	Good
5/6/2021 17:39:53	PH-VS-SQL	30	Good
5/6/2021 17:39:53	PH-VS-SQL	1309	Good

(b) (3) (A)

5/6/2021 17:40:03	PH-VS-SQL	31	Good
5/6/2021 17:40:03	PH-VS-SQL	1309	Good
5/6/2021 17:40:04	PH-VS-SQL	272241	Good
5/6/2021 17:40:11	PH-VS-SQL	30	Good
5/6/2021 17:40:12	PH-VS-SQL	30	Good
5/6/2021 17:40:14	PH-VS-SQL	1314	Good
5/6/2021 17:40:18	PH-VS-SQL	30	Good
5/6/2021 17:40:23	PH-VS-SQL	1313	Good
5/6/2021 17:40:24	PH-VS-SQL	272241	Good
5/6/2021 17:40:28	PH-VS-SQL	30	Good
5/6/2021 17:40:31	PH-VS-SQL	30	Good
5/6/2021 17:40:32	PH-VS-SQL	30	Good
5/6/2021 17:40:33	PH-VS-SQL	30	Good
5/6/2021 17:40:33	PH-VS-SQL	1312	Good
5/6/2021 17:40:42	PH-VS-SQL	30	Good
5/6/2021 17:40:44	PH-VS-SQL	1312	Good
5/6/2021 17:40:50	PH-VS-SQL	30	Good
5/6/2021 17:40:51	PH-VS-SQL	30	Good
5/6/2021 17:40:53	PH-VS-SQL	1316	Good
5/6/2021 17:40:54	PH-VS-SQL	272241	Good
5/6/2021 17:40:56	PH-VS-SQL	30	Good
5/6/2021 17:41:01	PH-VS-SQL	30	Good
5/6/2021 17:41:10	PH-VS-SQL	30	Good
5/6/2021 17:41:11	PH-VS-SQL	30	Good
5/6/2021 17:41:14	PH-VS-SQL	1314	Good
5/6/2021 17:41:19	PH-VS-SQL	30	Good
5/6/2021 17:41:23	PH-VS-SQL	1315	Good
5/6/2021 17:41:23	PH-VS-SQL	272241	Good
5/6/2021 17:41:30	PH-VS-SQL	35	Good
5/6/2021 17:41:31	PH-VS-SQL	36	Good
5/6/2021 17:41:33	PH-VS-SQL	1315	Good
5/6/2021 17:41:35	PH-VS-SQL	37	Good
5/6/2021 17:41:44	PH-VS-SQL	1315	Good
5/6/2021 17:41:44	PH-VS-SQL	272241	Good
5/6/2021 17:41:45	PH-VS-SQL	25	Good
5/6/2021 17:41:49	PH-VS-SQL	31	Good
5/6/2021 17:41:50	PH-VS-SQL	31	Good
5/6/2021 17:41:53	PH-VS-SQL	213092	Good
5/6/2021 17:41:54	PH-VS-SQL	33	Good
5/6/2021 17:42:09	PH-VS-SQL	29	Good
5/6/2021 17:42:10	PH-VS-SQL	28	Good
5/6/2021 17:42:14	PH-VS-SQL	1317	Good
5/6/2021 17:42:14	PH-VS-SQL	272241	Good
5/6/2021 17:42:15	PH-VS-SQL	27	Good
5/6/2021 17:42:24	PH-VS-SQL	33	Good
5/6/2021 17:42:29	PH-VS-SQL	29	Good
5/6/2021 17:42:30	PH-VS-SQL	29	Good

(b) (3) (A)

5/6/2021 17:42:33	PH-VS-SQL	28	Good
5/6/2021 17:42:33	PH-VS-SQL	1319	Good
5/6/2021 17:42:42	PH-VS-SQL	32	Good
5/6/2021 17:42:44	PH-VS-SQL	1315	Good
5/6/2021 17:42:44	PH-VS-SQL	272241	Good
5/6/2021 17:42:48	PH-VS-SQL	31	Good
5/6/2021 17:42:49	PH-VS-SQL	31	Good
5/6/2021 17:42:53	PH-VS-SQL	213092	Good
5/6/2021 17:42:53	PH-VS-SQL	1319	Good
5/6/2021 17:42:59	PH-VS-SQL	29	Good
5/6/2021 17:43:03	PH-VS-SQL	1316	Good
5/6/2021 17:43:08	PH-VS-SQL	32	Good
5/6/2021 17:43:09	PH-VS-SQL	31	Good
5/6/2021 17:43:12	PH-VS-SQL	31	Good
5/6/2021 17:43:14	PH-VS-SQL	1316	Good
5/6/2021 17:43:14	PH-VS-SQL	272241	Good
5/6/2021 17:43:17	PH-VS-SQL	29	Good
5/6/2021 17:43:24	PH-VS-SQL	1318	Good
5/6/2021 17:43:27	PH-VS-SQL	30	Good
5/6/2021 17:43:28	PH-VS-SQL	30	Good
5/6/2021 17:43:33	PH-VS-SQL	1315	Good
5/6/2021 17:43:34	PH-VS-SQL	272240	Good
5/6/2021 17:43:37	PH-VS-SQL	31	Good
5/6/2021 17:43:43	PH-VS-SQL	1315	Good
5/6/2021 17:43:46	PH-VS-SQL	29	Good
5/6/2021 17:43:47	PH-VS-SQL	29	Good
5/6/2021 17:43:48	PH-VS-SQL	29	Good
5/6/2021 17:43:53	PH-VS-SQL	1315	Good
5/6/2021 17:43:55	PH-VS-SQL	31	Good
5/6/2021 17:44:03	PH-VS-SQL	1318	Good
5/6/2021 17:44:04	PH-VS-SQL	272240	Good
5/6/2021 17:44:07	PH-VS-SQL	30	Good
5/6/2021 17:44:08	PH-VS-SQL	30	Good
5/6/2021 17:44:09	PH-VS-SQL	30	Good
5/6/2021 17:44:14	PH-VS-SQL	1316	Good
5/6/2021 17:44:14	PH-VS-SQL	31	Good
5/6/2021 17:44:23	PH-VS-SQL	1316	Good
5/6/2021 17:44:26	PH-VS-SQL	31	Good
5/6/2021 17:44:27	PH-VS-SQL	31	Good
5/6/2021 17:44:33	PH-VS-SQL	1315	Good
5/6/2021 17:44:33	PH-VS-SQL	272240	Good
5/6/2021 17:44:35	PH-VS-SQL	30	Good
5/6/2021 17:44:43	PH-VS-SQL	1315	Good
5/6/2021 17:44:45	PH-VS-SQL	31	Good
5/6/2021 17:44:46	PH-VS-SQL	31	Good
5/6/2021 17:44:47	PH-VS-SQL	30	Good
5/6/2021 17:44:53	PH-VS-SQL	30	Good

(b) (3) (A)

5/6/2021 17:44:53	PH-VS-SQL	213092	Good
5/6/2021 17:44:53	PH-VS-SQL	1316	Good
5/6/2021 17:45:02	PH-VS-SQL	31	Good
5/6/2021 17:45:03	PH-VS-SQL	1317	Good
5/6/2021 17:45:03	PH-VS-SQL	272239	Good
5/6/2021 17:45:06	PH-VS-SQL	30	Good
5/6/2021 17:45:07	PH-VS-SQL	30	Good
5/6/2021 17:45:14	PH-VS-SQL	1318	Good
5/6/2021 17:45:15	PH-VS-SQL	31	Good
5/6/2021 17:45:23	PH-VS-SQL	1318	Good
5/6/2021 17:45:23	PH-VS-SQL	272239	Good
5/6/2021 17:45:24	PH-VS-SQL	30	Good
5/6/2021 17:45:25	PH-VS-SQL	30	Good
5/6/2021 17:45:26	PH-VS-SQL	30	Good
5/6/2021 17:45:33	PH-VS-SQL	1316	Good
5/6/2021 17:45:34	PH-VS-SQL	31	Good
5/6/2021 17:45:41	PH-VS-SQL	30	Good
5/6/2021 17:45:44	PH-VS-SQL	1319	Good
5/6/2021 17:45:45	PH-VS-SQL	30	Good
5/6/2021 17:45:46	PH-VS-SQL	30	Good
5/6/2021 17:45:48	PH-VS-SQL	30	Good
5/6/2021 17:45:53	PH-VS-SQL	1318	Good
5/6/2021 17:45:54	PH-VS-SQL	272239	Good
5/6/2021 17:46:03	PH-VS-SQL	31	Good
5/6/2021 17:46:03	PH-VS-SQL	1318	Good
5/6/2021 17:46:04	PH-VS-SQL	30	Good
5/6/2021 17:46:06	PH-VS-SQL	30	Good
5/6/2021 17:46:13	PH-VS-SQL	30	Good
5/6/2021 17:46:14	PH-VS-SQL	1316	Good
5/6/2021 17:46:16	PH-VS-SQL	31	Good
5/6/2021 17:46:23	PH-VS-SQL	1318	Good
5/6/2021 17:46:23	PH-VS-SQL	272239	Good
5/6/2021 17:46:24	PH-VS-SQL	31	Good
5/6/2021 17:46:25	PH-VS-SQL	30	Good
5/6/2021 17:46:31	PH-VS-SQL	30	Good
5/6/2021 17:46:33	PH-VS-SQL	1315	Good
5/6/2021 17:46:39	PH-VS-SQL	31	Good
5/6/2021 17:46:43	PH-VS-SQL	1318	Good
5/6/2021 17:46:44	PH-VS-SQL	30	Good
5/6/2021 17:46:45	PH-VS-SQL	30	Good
5/6/2021 17:46:53	PH-VS-SQL	1317	Good
5/6/2021 17:46:54	PH-VS-SQL	272239	Good
5/6/2021 17:46:55	PH-VS-SQL	30	Good
5/6/2021 17:46:59	PH-VS-SQL	31	Good
5/6/2021 17:47:03	PH-VS-SQL	30	Good
5/6/2021 17:47:03	PH-VS-SQL	1316	Good
5/6/2021 17:47:04	PH-VS-SQL	30	Good

(b) (3) (A)

5/6/2021 17:47:12	PH-VS-SQL	30	Good
5/6/2021 17:47:14	PH-VS-SQL	1318	Good
5/6/2021 17:47:14	PH-VS-SQL	272239	Good
5/6/2021 17:47:16	PH-VS-SQL	31	Good
5/6/2021 17:47:23	PH-VS-SQL	30	Good
5/6/2021 17:47:23	PH-VS-SQL	1316	Good
5/6/2021 17:47:24	PH-VS-SQL	31	Good
5/6/2021 17:47:30	PH-VS-SQL	30	Good
5/6/2021 17:47:33	PH-VS-SQL	1318	Good
5/6/2021 17:47:43	PH-VS-SQL	30	Good
5/6/2021 17:47:44	PH-VS-SQL	1316	Good
5/6/2021 17:47:44	PH-VS-SQL	30	Good
5/6/2021 17:47:53	PH-VS-SQL	31	Good
5/6/2021 17:47:53	PH-VS-SQL	1316	Good
5/6/2021 17:47:53	PH-VS-SQL	272239	Good
5/6/2021 17:48:02	PH-VS-SQL	30	Good
5/6/2021 17:48:03	PH-VS-SQL	31	Good
5/6/2021 17:48:03	PH-VS-SQL	213092	Good
5/6/2021 17:48:03	PH-VS-SQL	1317	Good
5/6/2021 17:48:10	PH-VS-SQL	31	Good
5/6/2021 17:48:11	PH-VS-SQL	30	Good
5/6/2021 17:48:14	PH-VS-SQL	1316	Good
5/6/2021 17:48:14	PH-VS-SQL	272239	Good
5/6/2021 17:48:22	PH-VS-SQL	31	Good
5/6/2021 17:48:23	PH-VS-SQL	30	Good
5/6/2021 17:48:23	PH-VS-SQL	1315	Good
5/6/2021 17:48:26	PH-VS-SQL	30	Good
5/6/2021 17:48:33	PH-VS-SQL	1318	Good
5/6/2021 17:48:41	PH-VS-SQL	31	Good
5/6/2021 17:48:42	PH-VS-SQL	30	Good
5/6/2021 17:48:43	PH-VS-SQL	30	Good
5/6/2021 17:48:43	PH-VS-SQL	1317	Good
5/6/2021 17:48:44	PH-VS-SQL	272239	Good
5/6/2021 17:48:53	PH-VS-SQL	31	Good
5/6/2021 17:48:53	PH-VS-SQL	1317	Good
5/6/2021 17:48:56	PH-VS-SQL	30	Good
5/6/2021 17:49:01	PH-VS-SQL	31	Good
5/6/2021 17:49:02	PH-VS-SQL	30	Good
5/6/2021 17:49:03	PH-VS-SQL	1317	Good
5/6/2021 17:49:06	PH-VS-SQL	31	Good
5/6/2021 17:49:08	PH-VS-SQL	30	Good
5/6/2021 17:49:14	PH-VS-SQL	1316	Good
5/6/2021 17:49:14	PH-VS-SQL	272239	Good
5/6/2021 17:49:21	PH-VS-SQL	30	Good
5/6/2021 17:49:22	PH-VS-SQL	30	Good
5/6/2021 17:49:23	PH-VS-SQL	1316	Good
5/6/2021 17:49:33	PH-VS-SQL	1316	Good

(b) (3) (A)

5/6/2021 17:49:33	PH-VS-SQL	272239	Good
5/6/2021 17:49:34	PH-VS-SQL	30	Good
5/6/2021 17:49:38	PH-VS-SQL	31	Good
5/6/2021 17:49:41	PH-VS-SQL	30	Good
5/6/2021 17:49:42	PH-VS-SQL	30	Good
5/6/2021 17:49:44	PH-VS-SQL	1316	Good
5/6/2021 17:49:44	PH-VS-SQL	30	Good
5/6/2021 17:49:49	PH-VS-SQL	31	Good
5/6/2021 17:49:53	PH-VS-SQL	1317	Good
5/6/2021 17:50:00	PH-VS-SQL	30	Good
5/6/2021 17:50:01	PH-VS-SQL	30	Good
5/6/2021 17:50:03	PH-VS-SQL	30	Good
5/6/2021 17:50:03	PH-VS-SQL	1318	Good
5/6/2021 17:50:04	PH-VS-SQL	272239	Good
5/6/2021 17:50:14	PH-VS-SQL	1318	Good
5/6/2021 17:50:16	PH-VS-SQL	31	Good
5/6/2021 17:50:20	PH-VS-SQL	30	Good
5/6/2021 17:50:21	PH-VS-SQL	30	Good
5/6/2021 17:50:23	PH-VS-SQL	1317	Good
5/6/2021 17:50:33	PH-VS-SQL	1317	Good
5/6/2021 17:50:33	PH-VS-SQL	272239	Good
5/6/2021 17:50:38	PH-VS-SQL	31	Good
5/6/2021 17:50:39	PH-VS-SQL	30	Good
5/6/2021 17:50:40	PH-VS-SQL	31	Good
5/6/2021 17:50:44	PH-VS-SQL	1317	Good
5/6/2021 17:50:49	PH-VS-SQL	30	Good
5/6/2021 17:50:53	PH-VS-SQL	272239	Good
5/6/2021 17:50:57	PH-VS-SQL	31	Good
5/6/2021 17:50:59	PH-VS-SQL	30	Good
5/6/2021 17:51:00	PH-VS-SQL	30	Good
5/6/2021 17:51:03	PH-VS-SQL	1318	Good
5/6/2021 17:51:09	PH-VS-SQL	30	Good
5/6/2021 17:51:19	PH-VS-SQL	31	Good
5/6/2021 17:51:20	PH-VS-SQL	30	Good
5/6/2021 17:51:23	PH-VS-SQL	1316	Good
5/6/2021 17:51:27	PH-VS-SQL	31	Good
5/6/2021 17:51:32	PH-VS-SQL	30	Good
5/6/2021 17:51:33	PH-VS-SQL	1317	Good
5/6/2021 17:51:34	PH-VS-SQL	272238	Good
5/6/2021 17:51:38	PH-VS-SQL	31	Good
5/6/2021 17:51:39	PH-VS-SQL	31	Good
5/6/2021 17:51:43	PH-VS-SQL	31	Good
5/6/2021 17:51:43	PH-VS-SQL	1317	Good
5/6/2021 17:51:53	PH-VS-SQL	1316	Good
5/6/2021 17:51:53	PH-VS-SQL	272238	Good
5/6/2021 17:51:58	PH-VS-SQL	30	Good
5/6/2021 17:51:59	PH-VS-SQL	31	Good

(b) (3) (A)

5/6/2021 17:52:03	PH-VS-SQL	1316	Good
5/6/2021 17:52:10	PH-VS-SQL	30	Good
5/6/2021 17:52:13	PH-VS-SQL	31	Good
5/6/2021 17:52:14	PH-VS-SQL	1318	Good
5/6/2021 17:52:18	PH-VS-SQL	30	Good
5/6/2021 17:52:20	PH-VS-SQL	30	Good
5/6/2021 17:52:23	PH-VS-SQL	31	Good
5/6/2021 17:52:23	PH-VS-SQL	213092	Good
5/6/2021 17:52:23	PH-VS-SQL	1316	Good
5/6/2021 17:52:24	PH-VS-SQL	272238	Good
5/6/2021 17:52:32	PH-VS-SQL	30	Good
5/6/2021 17:52:33	PH-VS-SQL	1317	Good
5/6/2021 17:52:37	PH-VS-SQL	31	Good
5/6/2021 17:52:38	PH-VS-SQL	31	Good
5/6/2021 17:52:41	PH-VS-SQL	30	Good
5/6/2021 17:52:44	PH-VS-SQL	1317	Good
5/6/2021 17:52:44	PH-VS-SQL	272238	Good
5/6/2021 17:52:48	PH-VS-SQL	31	Good
5/6/2021 17:52:53	PH-VS-SQL	1316	Good
5/6/2021 17:52:57	PH-VS-SQL	31	Good
5/6/2021 17:52:58	PH-VS-SQL	30	Good
5/6/2021 17:53:00	PH-VS-SQL	30	Good
5/6/2021 17:53:03	PH-VS-SQL	1317	Good
5/6/2021 17:53:09	PH-VS-SQL	31	Good
5/6/2021 17:53:13	PH-VS-SQL	213092	Good
5/6/2021 17:53:14	PH-VS-SQL	272238	Good
5/6/2021 17:53:16	PH-VS-SQL	30	Good
5/6/2021 17:53:17	PH-VS-SQL	31	Good
5/6/2021 17:53:20	PH-VS-SQL	31	Good
5/6/2021 17:53:23	PH-VS-SQL	1317	Good
5/6/2021 17:53:33	PH-VS-SQL	1317	Good
5/6/2021 17:53:34	PH-VS-SQL	30	Good
5/6/2021 17:53:36	PH-VS-SQL	30	Good
5/6/2021 17:53:37	PH-VS-SQL	31	Good
5/6/2021 17:53:40	PH-VS-SQL	31	Good
5/6/2021 17:53:44	PH-VS-SQL	213092	Good
5/6/2021 17:53:44	PH-VS-SQL	1317	Good
5/6/2021 17:53:44	PH-VS-SQL	272238	Good
5/6/2021 17:53:51	PH-VS-SQL	30	Good
5/6/2021 17:53:53	PH-VS-SQL	1316	Good
5/6/2021 17:53:56	PH-VS-SQL	31	Good
5/6/2021 17:53:57	PH-VS-SQL	30	Good
5/6/2021 17:53:59	PH-VS-SQL	30	Good
5/6/2021 17:54:03	PH-VS-SQL	1316	Good
5/6/2021 17:54:04	PH-VS-SQL	272238	Good
5/6/2021 17:54:07	PH-VS-SQL	31	Good
5/6/2021 17:54:13	PH-VS-SQL	213092	Good

(b) (3) (A)

5/6/2021 17:54:14	PH-VS-SQL	1317	Good
5/6/2021 17:54:15	PH-VS-SQL	31	Good
5/6/2021 17:54:16	PH-VS-SQL	30	Good
5/6/2021 17:54:21	PH-VS-SQL	30	Good
5/6/2021 17:54:23	PH-VS-SQL	31	Good
5/6/2021 17:54:23	PH-VS-SQL	1317	Good
5/6/2021 17:54:33	PH-VS-SQL	1317	Good
5/6/2021 17:54:33	PH-VS-SQL	272238	Good
5/6/2021 17:54:35	PH-VS-SQL	31	Good
5/6/2021 17:54:36	PH-VS-SQL	30	Good
5/6/2021 17:54:44	PH-VS-SQL	1317	Good
5/6/2021 17:54:48	PH-VS-SQL	31	Good
5/6/2021 17:54:50	PH-VS-SQL	30	Good
5/6/2021 17:54:53	PH-VS-SQL	1316	Good
5/6/2021 17:54:55	PH-VS-SQL	30	Good
5/6/2021 17:54:56	PH-VS-SQL	31	Good
5/6/2021 17:55:03	PH-VS-SQL	1317	Good
5/6/2021 17:55:03	PH-VS-SQL	272238	Good
5/6/2021 17:55:10	PH-VS-SQL	30	Good
5/6/2021 17:55:12	PH-VS-SQL	31	Good
5/6/2021 17:55:14	PH-VS-SQL	1317	Good
5/6/2021 17:55:14	PH-VS-SQL	31	Good
5/6/2021 17:55:15	PH-VS-SQL	31	Good
5/6/2021 17:55:32	PH-VS-SQL	31	Good
5/6/2021 17:55:33	PH-VS-SQL	213092	Good
5/6/2021 17:55:33	PH-VS-SQL	1317	Good
5/6/2021 17:55:33	PH-VS-SQL	272238	Good
5/6/2021 17:55:34	PH-VS-SQL	30	Good
5/6/2021 17:55:35	PH-VS-SQL	31	Good
5/6/2021 17:55:40	PH-VS-SQL	31	Good
5/6/2021 17:55:44	PH-VS-SQL	1317	Good
5/6/2021 17:55:49	PH-VS-SQL	30	Good
5/6/2021 17:55:53	PH-VS-SQL	213092	Good
5/6/2021 17:55:53	PH-VS-SQL	1317	Good
5/6/2021 17:55:53	PH-VS-SQL	272238	Good
5/6/2021 17:55:54	PH-VS-SQL	31	Good
5/6/2021 17:55:55	PH-VS-SQL	31	Good
5/6/2021 17:56:03	PH-VS-SQL	1317	Good
5/6/2021 17:56:07	PH-VS-SQL	30	Good
5/6/2021 17:56:11	PH-VS-SQL	31	Good
5/6/2021 17:56:13	PH-VS-SQL	30	Good
5/6/2021 17:56:14	PH-VS-SQL	30	Good
5/6/2021 17:56:23	PH-VS-SQL	213092	Good
5/6/2021 17:56:23	PH-VS-SQL	1317	Good
5/6/2021 17:56:23	PH-VS-SQL	272238	Good
5/6/2021 17:56:25	PH-VS-SQL	30	Good
5/6/2021 17:56:31	PH-VS-SQL	31	Good

(b) (3) (A)

5/6/2021 17:56:33	PH-VS-SQL	31	Good
5/6/2021 17:56:33	PH-VS-SQL	1317	Good
5/6/2021 17:56:34	PH-VS-SQL	31	Good
5/6/2021 17:56:37	PH-VS-SQL	30	Good
5/6/2021 17:56:44	PH-VS-SQL	1317	Good
5/6/2021 17:56:49	PH-VS-SQL	31	Good
5/6/2021 17:56:52	PH-VS-SQL	31	Good
5/6/2021 17:56:53	PH-VS-SQL	30	Good
5/6/2021 17:56:53	PH-VS-SQL	1317	Good
5/6/2021 17:56:53	PH-VS-SQL	272238	Good
5/6/2021 17:57:00	PH-VS-SQL	31	Good
5/6/2021 17:57:03	PH-VS-SQL	1317	Good
5/6/2021 17:57:07	PH-VS-SQL	30	Good
5/6/2021 17:57:12	PH-VS-SQL	31	Good
5/6/2021 17:57:13	PH-VS-SQL	31	Good
5/6/2021 17:57:13	PH-VS-SQL	213092	Good
5/6/2021 17:57:14	PH-VS-SQL	1317	Good
5/6/2021 17:57:14	PH-VS-SQL	272238	Good
5/6/2021 17:57:19	PH-VS-SQL	31	Good
5/6/2021 17:57:23	PH-VS-SQL	1317	Good
5/6/2021 17:57:29	PH-VS-SQL	30	Good
5/6/2021 17:57:32	PH-VS-SQL	31	Good
5/6/2021 17:57:33	PH-VS-SQL	31	Good
5/6/2021 17:57:33	PH-VS-SQL	1317	Good
5/6/2021 17:57:43	PH-VS-SQL	213092	Good
5/6/2021 17:57:44	PH-VS-SQL	1317	Good
5/6/2021 17:57:44	PH-VS-SQL	272238	Good
5/6/2021 17:57:49	PH-VS-SQL	30	Good
5/6/2021 17:57:50	PH-VS-SQL	31	Good
5/6/2021 17:57:51	PH-VS-SQL	31	Good
5/6/2021 17:57:52	PH-VS-SQL	31	Good
5/6/2021 17:57:53	PH-VS-SQL	1317	Good
5/6/2021 17:58:02	PH-VS-SQL	30	Good
5/6/2021 17:58:03	PH-VS-SQL	1317	Good
5/6/2021 17:58:05	PH-VS-SQL	31	Good
5/6/2021 17:58:11	PH-VS-SQL	31	Good
5/6/2021 17:58:13	PH-VS-SQL	30	Good
5/6/2021 17:58:14	PH-VS-SQL	1317	Good
5/6/2021 17:58:14	PH-VS-SQL	272238	Good
5/6/2021 17:58:23	PH-VS-SQL	1317	Good
5/6/2021 17:58:29	PH-VS-SQL	31	Good
5/6/2021 17:58:30	PH-VS-SQL	30	Good
5/6/2021 17:58:32	PH-VS-SQL	30	Good
5/6/2021 17:58:33	PH-VS-SQL	1317	Good
5/6/2021 17:58:41	PH-VS-SQL	31	Good
5/6/2021 17:58:43	PH-VS-SQL	213091	Good
5/6/2021 17:58:44	PH-VS-SQL	1317	Good

(b) (3) (A)

5/6/2021 17:58:44	PH-VS-SQL	272238	Good
5/6/2021 17:58:47	PH-VS-SQL	30	Good
5/6/2021 17:58:50	PH-VS-SQL	31	Good
5/6/2021 17:58:51	PH-VS-SQL	31	Good
5/6/2021 17:58:53	PH-VS-SQL	1317	Good
5/6/2021 17:58:59	PH-VS-SQL	30	Good
5/6/2021 17:59:03	PH-VS-SQL	1317	Good
5/6/2021 17:59:10	PH-VS-SQL	31	Good
5/6/2021 17:59:11	PH-VS-SQL	31	Good
5/6/2021 17:59:13	PH-VS-SQL	1317	Good
5/6/2021 17:59:22	PH-VS-SQL	30	Good
5/6/2021 17:59:23	PH-VS-SQL	1317	Good
5/6/2021 17:59:24	PH-VS-SQL	31	Good
5/6/2021 17:59:29	PH-VS-SQL	31	Good
5/6/2021 17:59:30	PH-VS-SQL	30	Good
5/6/2021 17:59:32	PH-VS-SQL	31	Good
5/6/2021 17:59:33	PH-VS-SQL	213091	Good
5/6/2021 17:59:33	PH-VS-SQL	1317	Good
5/6/2021 17:59:37	PH-VS-SQL	30	Good
5/6/2021 17:59:44	PH-VS-SQL	1317	Good
5/6/2021 17:59:49	PH-VS-SQL	31	Good
5/6/2021 17:59:50	PH-VS-SQL	30	Good
5/6/2021 17:59:53	PH-VS-SQL	1317	Good
5/6/2021 18:00:04	PH-VS-SQL	1317	Good
5/6/2021 18:00:04	PH-VS-SQL	272238	Good
5/6/2021 18:00:09	PH-VS-SQL	31	Good
5/6/2021 18:00:10	PH-VS-SQL	31	Good
5/6/2021 18:00:12	PH-VS-SQL	31	Good
5/6/2021 18:00:14	PH-VS-SQL	1317	Good
5/6/2021 18:00:16	PH-VS-SQL	30	Good
5/6/2021 18:00:23	PH-VS-SQL	1317	Good
5/6/2021 18:00:28	PH-VS-SQL	31	Good
5/6/2021 18:00:29	PH-VS-SQL	31	Good
5/6/2021 18:00:32	PH-VS-SQL	30	Good
5/6/2021 18:00:35	PH-VS-SQL	1317	Good
5/6/2021 18:00:35	PH-VS-SQL	272238	Good
5/6/2021 18:00:37	PH-VS-SQL	31	Good
5/6/2021 18:00:45	PH-VS-SQL	1317	Good
5/6/2021 18:00:48	PH-VS-SQL	31	Good
5/6/2021 18:00:49	PH-VS-SQL	31	Good
5/6/2021 18:00:55	PH-VS-SQL	213091	Good
5/6/2021 18:00:55	PH-VS-SQL	1317	Good
5/6/2021 18:00:55	PH-VS-SQL	272238	Good
5/6/2021 18:00:59	PH-VS-SQL	31	Good
5/6/2021 18:01:05	PH-VS-SQL	1317	Good
5/6/2021 18:01:08	PH-VS-SQL	30	Good
5/6/2021 18:01:09	PH-VS-SQL	31	Good

(b) (3) (A)

5/6/2021 18:01:16	PH-VS-SQL	213091	Good
5/6/2021 18:01:16	PH-VS-SQL	1317	Good
5/6/2021 18:01:23	PH-VS-SQL	31	Good
5/6/2021 18:01:26	PH-VS-SQL	31	Good
5/6/2021 18:01:26	PH-VS-SQL	1317	Good
5/6/2021 18:01:28	PH-VS-SQL	31	Good
5/6/2021 18:01:30	PH-VS-SQL	31	Good
5/6/2021 18:01:36	PH-VS-SQL	1317	Good
5/6/2021 18:01:36	PH-VS-SQL	272238	Good
5/6/2021 18:01:45	PH-VS-SQL	31	Good
5/6/2021 18:01:47	PH-VS-SQL	31	Good
5/6/2021 18:01:48	PH-VS-SQL	31	Good
5/6/2021 18:01:56	PH-VS-SQL	1317	Good
5/6/2021 18:01:56	PH-VS-SQL	272238	Good
5/6/2021 18:02:04	PH-VS-SQL	31	Good
5/6/2021 18:02:05	PH-VS-SQL	31	Good
5/6/2021 18:02:07	PH-VS-SQL	31	Good
5/6/2021 18:02:08	PH-VS-SQL	31	Good
5/6/2021 18:02:16	PH-VS-SQL	1317	Good
5/6/2021 18:02:16	PH-VS-SQL	272238	Good
5/6/2021 18:02:25	PH-VS-SQL	30	Good
5/6/2021 18:02:26	PH-VS-SQL	31	Good
5/6/2021 18:02:27	PH-VS-SQL	31	Good
5/6/2021 18:02:36	PH-VS-SQL	1317	Good
5/6/2021 18:02:39	PH-VS-SQL	31	Good
5/6/2021 18:02:46	PH-VS-SQL	26	Good
5/6/2021 18:02:46	PH-VS-SQL	1317	Good
5/6/2021 18:02:47	PH-VS-SQL	25	Good
5/6/2021 18:02:50	PH-VS-SQL	24	Good
5/6/2021 18:02:56	PH-VS-SQL	1317	Good
5/6/2021 18:03:00	PH-VS-SQL	34	Good
5/6/2021 18:03:04	PH-VS-SQL	31	Good
5/6/2021 18:03:06	PH-VS-SQL	31	Good
5/6/2021 18:03:06	PH-VS-SQL	213091	Good
5/6/2021 18:03:06	PH-VS-SQL	1318	Good
5/6/2021 18:03:15	PH-VS-SQL	29	Good
5/6/2021 18:03:16	PH-VS-SQL	1318	Good
5/6/2021 18:03:24	PH-VS-SQL	32	Good
5/6/2021 18:03:26	PH-VS-SQL	32	Good
5/6/2021 18:03:28	PH-VS-SQL	32	Good
5/6/2021 18:03:34	PH-VS-SQL	29	Good
5/6/2021 18:03:36	PH-VS-SQL	1319	Good
5/6/2021 18:03:37	PH-VS-SQL	6	Good
5/6/2021 18:03:43	PH-VS-SQL	18	Good
5/6/2021 18:03:44	PH-VS-SQL	31	Good
5/6/2021 18:03:45	PH-VS-SQL	31	Good
5/6/2021 18:03:46	PH-VS-SQL	24	Good

(b) (3) (A)

5/6/2021 18:03:56	PH-VS-SQL	1320	Good
5/6/2021 18:03:56	PH-VS-SQL	30	Good
5/6/2021 18:04:02	PH-VS-SQL	55	Good
5/6/2021 18:04:03	PH-VS-SQL	30	Good
5/6/2021 18:04:04	PH-VS-SQL	30	Good
5/6/2021 18:04:06	PH-VS-SQL	213091	Good
5/6/2021 18:04:06	PH-VS-SQL	1321	Good
5/6/2021 18:04:07	PH-VS-SQL	56	Good
5/6/2021 18:04:11	PH-VS-SQL	31	Good
5/6/2021 18:04:14	PH-VS-SQL	50	Good
5/6/2021 18:04:16	PH-VS-SQL	272238	Good
5/6/2021 18:04:20	PH-VS-SQL	30	Good
5/6/2021 18:04:23	PH-VS-SQL	30	Good
5/6/2021 18:04:24	PH-VS-SQL	30	Good
5/6/2021 18:04:26	PH-VS-SQL	1322	Good
5/6/2021 18:04:26	PH-VS-SQL	272238	Good
5/6/2021 18:04:29	PH-VS-SQL	31	Good
5/6/2021 18:04:36	PH-VS-SQL	1323	Good
5/6/2021 18:04:36	PH-VS-SQL	272238	Good
5/6/2021 18:04:43	PH-VS-SQL	30	Good
5/6/2021 18:04:44	PH-VS-SQL	30	Good
5/6/2021 18:04:45	PH-VS-SQL	3	Good
5/6/2021 18:04:46	PH-VS-SQL	1324	Good
5/6/2021 18:04:47	PH-VS-SQL	272238	Good
5/6/2021 18:04:49	PH-VS-SQL	12	Good
5/6/2021 18:04:54	PH-VS-SQL	31	Good
5/6/2021 18:04:56	PH-VS-SQL	272238	Good
5/6/2021 18:05:02	PH-VS-SQL	30	Good
5/6/2021 18:05:03	PH-VS-SQL	30	Good
5/6/2021 18:05:06	PH-VS-SQL	1325	Good
5/6/2021 18:05:06	PH-VS-SQL	272238	Good
5/6/2021 18:05:10	PH-VS-SQL	30	Good
5/6/2021 18:05:16	PH-VS-SQL	1325	Good
5/6/2021 18:05:16	PH-VS-SQL	272238	Good
5/6/2021 18:05:22	PH-VS-SQL	30	Good
5/6/2021 18:05:23	PH-VS-SQL	30	Good
5/6/2021 18:05:26	PH-VS-SQL	213091	Good
5/6/2021 18:05:26	PH-VS-SQL	1326	Good
5/6/2021 18:05:26	PH-VS-SQL	272238	Good
5/6/2021 18:05:29	PH-VS-SQL	30	Good
5/6/2021 18:05:36	PH-VS-SQL	1326	Good
5/6/2021 18:05:36	PH-VS-SQL	272238	Good
5/6/2021 18:05:36	PH-VS-SQL	30	Good
5/6/2021 18:05:42	PH-VS-SQL	30	Good
5/6/2021 18:05:43	PH-VS-SQL	30	Good
5/6/2021 18:05:46	PH-VS-SQL	213091	Good
5/6/2021 18:05:46	PH-VS-SQL	1327	Good

(b) (3) (A)

5/6/2021 18:05:46	PH-VS-SQL	272238	Good
5/6/2021 18:05:48	PH-VS-SQL	30	Good
5/6/2021 18:05:49	PH-VS-SQL	30	Good
5/6/2021 18:05:56	PH-VS-SQL	1327	Good
5/6/2021 18:05:56	PH-VS-SQL	272238	Good
5/6/2021 18:06:01	PH-VS-SQL	30	Good
5/6/2021 18:06:02	PH-VS-SQL	30	Good
5/6/2021 18:06:06	PH-VS-SQL	1329	Good
5/6/2021 18:06:06	PH-VS-SQL	272238	Good
5/6/2021 18:06:07	PH-VS-SQL	30	Good
5/6/2021 18:06:14	PH-VS-SQL	29	Good
5/6/2021 18:06:16	PH-VS-SQL	213091	Good
5/6/2021 18:06:16	PH-VS-SQL	1329	Good
5/6/2021 18:06:16	PH-VS-SQL	272238	Good
5/6/2021 18:06:21	PH-VS-SQL	30	Good
5/6/2021 18:06:22	PH-VS-SQL	30	Good
5/6/2021 18:06:26	PH-VS-SQL	1330	Good
5/6/2021 18:06:26	PH-VS-SQL	272238	Good
5/6/2021 18:06:26	PH-VS-SQL	30	Good
5/6/2021 18:06:35	PH-VS-SQL	30	Good
5/6/2021 18:06:36	PH-VS-SQL	272238	Good
5/6/2021 18:06:40	PH-VS-SQL	30	Good
5/6/2021 18:06:41	PH-VS-SQL	30	Good
5/6/2021 18:06:46	PH-VS-SQL	1331	Good
5/6/2021 18:06:46	PH-VS-SQL	272238	Good
5/6/2021 18:06:52	PH-VS-SQL	29	Good
5/6/2021 18:06:53	PH-VS-SQL	30	Good
5/6/2021 18:06:56	PH-VS-SQL	1331	Good
5/6/2021 18:06:56	PH-VS-SQL	272238	Good
5/6/2021 18:07:00	PH-VS-SQL	30	Good
5/6/2021 18:07:01	PH-VS-SQL	30	Good
5/6/2021 18:07:03	PH-VS-SQL	48	Good
5/6/2021 18:07:06	PH-VS-SQL	1332	Good
5/6/2021 18:07:07	PH-VS-SQL	29	Good
5/6/2021 18:07:17	PH-VS-SQL	272237	Good
5/6/2021 18:07:20	PH-VS-SQL	16	Good
5/6/2021 18:07:20	PH-VS-SQL	32	Good
5/6/2021 18:07:21	PH-VS-SQL	33	Good
5/6/2021 18:07:23	PH-VS-SQL	12	Good
5/6/2021 18:07:26	PH-VS-SQL	1333	Good
5/6/2021 18:07:26	PH-VS-SQL	272237	Good
5/6/2021 18:07:26	PH-VS-SQL	37	Good
5/6/2021 18:07:30	PH-VS-SQL	0	Good
5/6/2021 18:07:36	PH-VS-SQL	1333	Good
5/6/2021 18:07:36	PH-VS-SQL	272237	Good
5/6/2021 18:07:36	PH-VS-SQL	26	Good
5/6/2021 18:07:39	PH-VS-SQL	28	Good

(b) (3) (A)

5/6/2021 18:07:40	PH-VS-SQL	29	Good
5/6/2021 18:07:45	PH-VS-SQL	32	Good
5/6/2021 18:07:46	PH-VS-SQL	1333	Good
5/6/2021 18:07:46	PH-VS-SQL	272237	Good
5/6/2021 18:07:53	PH-VS-SQL	29	Good
5/6/2021 18:07:56	PH-VS-SQL	1334	Good
5/6/2021 18:07:56	PH-VS-SQL	272237	Good
5/6/2021 18:07:59	PH-VS-SQL	30	Good
5/6/2021 18:08:00	PH-VS-SQL	30	Good
5/6/2021 18:08:06	PH-VS-SQL	1333	Good
5/6/2021 18:08:06	PH-VS-SQL	29	Good
5/6/2021 18:08:06	PH-VS-SQL	272237	Good
5/6/2021 18:08:11	PH-VS-SQL	9	Good
5/6/2021 18:08:16	PH-VS-SQL	1334	Good
5/6/2021 18:08:16	PH-VS-SQL	31	Good
5/6/2021 18:08:18	PH-VS-SQL	0	Good
5/6/2021 18:08:19	PH-VS-SQL	30	Good
5/6/2021 18:08:20	PH-VS-SQL	30	Good
5/6/2021 18:08:25	PH-VS-SQL	29	Good
5/6/2021 18:08:26	PH-VS-SQL	213091	Good
5/6/2021 18:08:26	PH-VS-SQL	1333	Good
5/6/2021 18:08:33	PH-VS-SQL	30	Good
5/6/2021 18:08:36	PH-VS-SQL	1333	Good
5/6/2021 18:08:38	PH-VS-SQL	30	Good
5/6/2021 18:08:39	PH-VS-SQL	30	Good
5/6/2021 18:08:40	PH-VS-SQL	31	Good
5/6/2021 18:08:43	PH-VS-SQL	5	Good
5/6/2021 18:08:46	PH-VS-SQL	1334	Good
5/6/2021 18:08:54	PH-VS-SQL	29	Good
5/6/2021 18:08:56	PH-VS-SQL	1333	Good
5/6/2021 18:08:56	PH-VS-SQL	37	Good
5/6/2021 18:08:58	PH-VS-SQL	30	Good
5/6/2021 18:08:59	PH-VS-SQL	44	Good
5/6/2021 18:09:00	PH-VS-SQL	30	Good
5/6/2021 18:09:03	PH-VS-SQL	30	Good
5/6/2021 18:09:06	PH-VS-SQL	1334	Good
5/6/2021 18:09:10	PH-VS-SQL	29	Good
5/6/2021 18:09:16	PH-VS-SQL	85	Good
5/6/2021 18:09:16	PH-VS-SQL	1334	Good
5/6/2021 18:09:17	PH-VS-SQL	272237	Good
5/6/2021 18:09:17	PH-VS-SQL	30	Good
5/6/2021 18:09:18	PH-VS-SQL	30	Good
5/6/2021 18:09:19	PH-VS-SQL	90	Good
5/6/2021 18:09:19	PH-VS-SQL	30	Good
5/6/2021 18:09:21	PH-VS-SQL	99	Good
5/6/2021 18:09:26	PH-VS-SQL	1334	Good
5/6/2021 18:09:29	PH-VS-SQL	29	Good

(b) (3) (A)

5/6/2021 18:09:36	PH-VS-SQL	1333	Good
5/6/2021 18:09:36	PH-VS-SQL	272237	Good
5/6/2021 18:09:37	PH-VS-SQL	30	Good
5/6/2021 18:09:38	PH-VS-SQL	30	Good
5/6/2021 18:09:40	PH-VS-SQL	30	Good
5/6/2021 18:09:46	PH-VS-SQL	1333	Good
5/6/2021 18:09:50	PH-VS-SQL	30	Good
5/6/2021 18:09:56	PH-VS-SQL	1333	Good
5/6/2021 18:09:56	PH-VS-SQL	272237	Good
5/6/2021 18:09:57	PH-VS-SQL	30	Good
5/6/2021 18:09:58	PH-VS-SQL	30	Good
5/6/2021 18:10:00	PH-VS-SQL	30	Good
5/6/2021 18:10:06	PH-VS-SQL	1333	Good
5/6/2021 18:10:09	PH-VS-SQL	5	Good
5/6/2021 18:10:12	PH-VS-SQL	29	Good
5/6/2021 18:10:16	PH-VS-SQL	18	Good
5/6/2021 18:10:16	PH-VS-SQL	213091	Good
5/6/2021 18:10:16	PH-VS-SQL	1333	Good
5/6/2021 18:10:16	PH-VS-SQL	30	Good
5/6/2021 18:10:16	PH-VS-SQL	272237	Good
5/6/2021 18:10:17	PH-VS-SQL	30	Good
5/6/2021 18:10:19	PH-VS-SQL	23	Good
5/6/2021 18:10:26	PH-VS-SQL	1333	Good
5/6/2021 18:10:26	PH-VS-SQL	30	Good
5/6/2021 18:10:32	PH-VS-SQL	31	Good
5/6/2021 18:10:35	PH-VS-SQL	52	Good
5/6/2021 18:10:36	PH-VS-SQL	1334	Good
5/6/2021 18:10:36	PH-VS-SQL	272237	Good
5/6/2021 18:10:36	PH-VS-SQL	30	Good
5/6/2021 18:10:38	PH-VS-SQL	59	Good
5/6/2021 18:10:38	PH-VS-SQL	31	Good
5/6/2021 18:10:45	PH-VS-SQL	30	Good
5/6/2021 18:10:46	PH-VS-SQL	1334	Good
5/6/2021 18:10:55	PH-VS-SQL	92	Good
5/6/2021 18:10:56	PH-VS-SQL	272237	Good
5/6/2021 18:10:56	PH-VS-SQL	33	Good
5/6/2021 18:10:57	PH-VS-SQL	37	Good
5/6/2021 18:10:58	PH-VS-SQL	98	Good
5/6/2021 18:11:01	PH-VS-SQL	100	Good
5/6/2021 18:11:06	PH-VS-SQL	1334	Good
5/6/2021 18:11:07	PH-VS-SQL	110	Good
5/6/2021 18:11:15	PH-VS-SQL	44	Good
5/6/2021 18:11:16	PH-VS-SQL	1334	Good
5/6/2021 18:11:16	PH-VS-SQL	35	Good
5/6/2021 18:11:17	PH-VS-SQL	31	Good
5/6/2021 18:11:26	PH-VS-SQL	1333	Good
5/6/2021 18:11:26	PH-VS-SQL	101	Good

(b) (3) (A)

5/6/2021 18:11:35	PH-VS-SQL	41	Good
5/6/2021 18:11:36	PH-VS-SQL	213091	Good
5/6/2021 18:11:36	PH-VS-SQL	1333	Good
5/6/2021 18:11:36	PH-VS-SQL	44	Good
5/6/2021 18:11:45	PH-VS-SQL	91	Good
5/6/2021 18:11:46	PH-VS-SQL	1334	Good
5/6/2021 18:11:55	PH-VS-SQL	52	Good
5/6/2021 18:11:56	PH-VS-SQL	1334	Good
5/6/2021 18:11:56	PH-VS-SQL	60	Good
5/6/2021 18:12:04	PH-VS-SQL	85	Good
5/6/2021 18:12:06	PH-VS-SQL	213092	Good
5/6/2021 18:12:06	PH-VS-SQL	1333	Good
5/6/2021 18:12:13	PH-VS-SQL	54	Good
5/6/2021 18:12:14	PH-VS-SQL	57	Good
5/6/2021 18:12:15	PH-VS-SQL	63	Good
5/6/2021 18:12:16	PH-VS-SQL	1334	Good
5/6/2021 18:12:18	PH-VS-SQL	94	Good
5/6/2021 18:12:21	PH-VS-SQL	80	Good
5/6/2021 18:12:24	PH-VS-SQL	98	Good
5/6/2021 18:12:26	PH-VS-SQL	1333	Good
5/6/2021 18:12:31	PH-VS-SQL	87	Good
5/6/2021 18:12:31	PH-VS-SQL	59	Good
5/6/2021 18:12:33	PH-VS-SQL	6	Good
5/6/2021 18:12:34	PH-VS-SQL	7	Good
5/6/2021 18:12:35	PH-VS-SQL	79	Good
5/6/2021 18:12:35	PH-VS-SQL	51	Good
5/6/2021 18:12:35	PH-VS-SQL	12	Good
5/6/2021 18:12:36	PH-VS-SQL	213092	Good
5/6/2021 18:12:36	PH-VS-SQL	1333	Good
5/6/2021 18:12:42	PH-VS-SQL	82	Good
5/6/2021 18:12:46	PH-VS-SQL	1333	Good
5/6/2021 18:12:52	PH-VS-SQL	6	Good
5/6/2021 18:12:53	PH-VS-SQL	44	Good
5/6/2021 18:12:53	PH-VS-SQL	10	Good
5/6/2021 18:12:53	PH-VS-SQL	8	Good
5/6/2021 18:12:54	PH-VS-SQL	14	Good
5/6/2021 18:12:56	PH-VS-SQL	212623	Good
5/6/2021 18:12:56	PH-VS-SQL	1333	Good
5/6/2021 18:12:57	PH-VS-SQL	36	Good
5/6/2021 18:12:57	PH-VS-SQL	1	Good
5/6/2021 18:13:00	PH-VS-SQL	0	Good
5/6/2021 18:13:02	PH-VS-SQL	82	Good
5/6/2021 18:13:06	PH-VS-SQL	1333	Good
5/6/2021 18:13:06	PH-VS-SQL	272237	Good
5/6/2021 18:13:11	PH-VS-SQL	9	Good
5/6/2021 18:13:12	PH-VS-SQL	5	Good
5/6/2021 18:13:13	PH-VS-SQL	13	Good

(b) (3) (A)

5/6/2021 18:13:14	PH-VS-SQL	19	Good
5/6/2021 18:13:15	PH-VS-SQL	1	Good
5/6/2021 18:13:16	PH-VS-SQL	1333	Good
5/6/2021 18:13:21	PH-VS-SQL	76	Good
5/6/2021 18:13:26	PH-VS-SQL	212619	Good
5/6/2021 18:13:26	PH-VS-SQL	1333	Good
5/6/2021 18:13:26	PH-VS-SQL	272237	Good
5/6/2021 18:13:31	PH-VS-SQL	11	Good
5/6/2021 18:13:33	PH-VS-SQL	19	Good
5/6/2021 18:13:34	PH-VS-SQL	27	Good
5/6/2021 18:13:36	PH-VS-SQL	1334	Good
5/6/2021 18:13:41	PH-VS-SQL	74	Good
5/6/2021 18:13:46	PH-VS-SQL	1333	Good
5/6/2021 18:13:50	PH-VS-SQL	13	Good
5/6/2021 18:13:52	PH-VS-SQL	17	Good
5/6/2021 18:13:53	PH-VS-SQL	24	Good
5/6/2021 18:13:56	PH-VS-SQL	212621	Good
5/6/2021 18:13:56	PH-VS-SQL	1334	Good
5/6/2021 18:14:00	PH-VS-SQL	72	Good
5/6/2021 18:14:06	PH-VS-SQL	1333	Good
5/6/2021 18:14:10	PH-VS-SQL	16	Good
5/6/2021 18:14:12	PH-VS-SQL	23	Good
5/6/2021 18:14:13	PH-VS-SQL	30	Good
5/6/2021 18:14:16	PH-VS-SQL	1334	Good
5/6/2021 18:14:19	PH-VS-SQL	70	Good
5/6/2021 18:14:26	PH-VS-SQL	212617	Good
5/6/2021 18:14:29	PH-VS-SQL	18	Good
5/6/2021 18:14:32	PH-VS-SQL	28	Good
5/6/2021 18:14:33	PH-VS-SQL	36	Good
5/6/2021 18:14:36	PH-VS-SQL	1333	Good
5/6/2021 18:14:39	PH-VS-SQL	68	Good
5/6/2021 18:14:46	PH-VS-SQL	212615	Good
5/6/2021 18:14:46	PH-VS-SQL	1333	Good
5/6/2021 18:14:48	PH-VS-SQL	20	Good
5/6/2021 18:14:51	PH-VS-SQL	27	Good
5/6/2021 18:14:52	PH-VS-SQL	34	Good
5/6/2021 18:14:56	PH-VS-SQL	1334	Good
5/6/2021 18:14:58	PH-VS-SQL	66	Good
5/6/2021 18:15:06	PH-VS-SQL	1333	Good
5/6/2021 18:15:08	PH-VS-SQL	22	Good
5/6/2021 18:15:11	PH-VS-SQL	31	Good
5/6/2021 18:15:12	PH-VS-SQL	38	Good
5/6/2021 18:15:16	PH-VS-SQL	212616	Good
5/6/2021 18:15:16	PH-VS-SQL	1333	Good
5/6/2021 18:15:18	PH-VS-SQL	64	Good
5/6/2021 18:15:26	PH-VS-SQL	1334	Good
5/6/2021 18:15:27	PH-VS-SQL	24	Good

(b) (3) (A)

5/6/2021 18:15:31	PH-VS-SQL	36	Good
5/6/2021 18:15:32	PH-VS-SQL	42	Good
5/6/2021 18:15:36	PH-VS-SQL	1333	Good
5/6/2021 18:15:36	PH-VS-SQL	272237	Good
5/6/2021 18:15:37	PH-VS-SQL	62	Good
5/6/2021 18:15:46	PH-VS-SQL	212616	Good
5/6/2021 18:15:46	PH-VS-SQL	1333	Good
5/6/2021 18:15:47	PH-VS-SQL	25	Good
5/6/2021 18:15:50	PH-VS-SQL	34	Good
5/6/2021 18:15:51	PH-VS-SQL	39	Good
5/6/2021 18:15:56	PH-VS-SQL	1334	Good
5/6/2021 18:15:56	PH-VS-SQL	272237	Good
5/6/2021 18:15:57	PH-VS-SQL	60	Good
5/6/2021 18:16:06	PH-VS-SQL	212616	Good
5/6/2021 18:16:06	PH-VS-SQL	1334	Good
5/6/2021 18:16:06	PH-VS-SQL	27	Good
5/6/2021 18:16:10	PH-VS-SQL	38	Good
5/6/2021 18:16:11	PH-VS-SQL	42	Good
5/6/2021 18:16:16	PH-VS-SQL	59	Good
5/6/2021 18:16:17	PH-VS-SQL	1333	Good
5/6/2021 18:16:17	PH-VS-SQL	272237	Good
5/6/2021 18:16:26	PH-VS-SQL	1333	Good
5/6/2021 18:16:26	PH-VS-SQL	28	Good
5/6/2021 18:16:29	PH-VS-SQL	36	Good
5/6/2021 18:16:30	PH-VS-SQL	40	Good
5/6/2021 18:16:35	PH-VS-SQL	58	Good
5/6/2021 18:16:36	PH-VS-SQL	212616	Good
5/6/2021 18:16:45	PH-VS-SQL	29	Good
5/6/2021 18:16:46	PH-VS-SQL	1333	Good
5/6/2021 18:16:49	PH-VS-SQL	39	Good
5/6/2021 18:16:50	PH-VS-SQL	43	Good
5/6/2021 18:16:55	PH-VS-SQL	57	Good
5/6/2021 18:16:56	PH-VS-SQL	1334	Good
5/6/2021 18:16:56	PH-VS-SQL	272237	Good
5/6/2021 18:17:04	PH-VS-SQL	31	Good
5/6/2021 18:17:06	PH-VS-SQL	212616	Good
5/6/2021 18:17:06	PH-VS-SQL	1333	Good
5/6/2021 18:17:09	PH-VS-SQL	41	Good
5/6/2021 18:17:10	PH-VS-SQL	45	Good
5/6/2021 18:17:14	PH-VS-SQL	55	Good
5/6/2021 18:17:16	PH-VS-SQL	1333	Good
5/6/2021 18:17:17	PH-VS-SQL	272237	Good
5/6/2021 18:17:24	PH-VS-SQL	32	Good
5/6/2021 18:17:26	PH-VS-SQL	212616	Good
5/6/2021 18:17:26	PH-VS-SQL	1334	Good
5/6/2021 18:17:28	PH-VS-SQL	40	Good
5/6/2021 18:17:29	PH-VS-SQL	43	Good

(b) (3) (A)

5/6/2021 18:17:34	PH-VS-SQL	55	Good
5/6/2021 18:17:36	PH-VS-SQL	1334	Good
5/6/2021 18:17:36	PH-VS-SQL	272237	Good
5/6/2021 18:17:44	PH-VS-SQL	32	Good
5/6/2021 18:17:47	PH-VS-SQL	1334	Good
5/6/2021 18:17:47	PH-VS-SQL	272237	Good
5/6/2021 18:17:48	PH-VS-SQL	42	Good
5/6/2021 18:17:49	PH-VS-SQL	45	Good
5/6/2021 18:17:53	PH-VS-SQL	54	Good
5/6/2021 18:17:56	PH-VS-SQL	212616	Good
5/6/2021 18:17:56	PH-VS-SQL	1333	Good
5/6/2021 18:18:03	PH-VS-SQL	33	Good
5/6/2021 18:18:06	PH-VS-SQL	1334	Good
5/6/2021 18:18:08	PH-VS-SQL	43	Good
5/6/2021 18:18:09	PH-VS-SQL	46	Good
5/6/2021 18:18:13	PH-VS-SQL	53	Good
5/6/2021 18:18:16	PH-VS-SQL	1333	Good
5/6/2021 18:18:22	PH-VS-SQL	34	Good
5/6/2021 18:18:27	PH-VS-SQL	1334	Good
5/6/2021 18:18:27	PH-VS-SQL	42	Good
5/6/2021 18:18:28	PH-VS-SQL	44	Good
5/6/2021 18:18:32	PH-VS-SQL	52	Good
5/6/2021 18:18:37	PH-VS-SQL	1334	Good
5/6/2021 18:18:42	PH-VS-SQL	34	Good
5/6/2021 18:18:47	PH-VS-SQL	1333	Good
5/6/2021 18:18:47	PH-VS-SQL	43	Good
5/6/2021 18:18:48	PH-VS-SQL	46	Good
5/6/2021 18:18:52	PH-VS-SQL	51	Good
5/6/2021 18:18:57	PH-VS-SQL	1334	Good
5/6/2021 18:19:02	PH-VS-SQL	35	Good
5/6/2021 18:19:06	PH-VS-SQL	42	Good
5/6/2021 18:19:07	PH-VS-SQL	1334	Good
5/6/2021 18:19:07	PH-VS-SQL	44	Good
5/6/2021 18:19:12	PH-VS-SQL	51	Good
5/6/2021 18:19:17	PH-VS-SQL	212616	Good
5/6/2021 18:19:17	PH-VS-SQL	1334	Good
5/6/2021 18:19:21	PH-VS-SQL	36	Good
5/6/2021 18:19:26	PH-VS-SQL	43	Good
5/6/2021 18:19:27	PH-VS-SQL	1333	Good
5/6/2021 18:19:27	PH-VS-SQL	45	Good
5/6/2021 18:19:30	PH-VS-SQL	50	Good
5/6/2021 18:19:37	PH-VS-SQL	212616	Good
5/6/2021 18:19:37	PH-VS-SQL	1333	Good
5/6/2021 18:19:40	PH-VS-SQL	36	Good
5/6/2021 18:19:46	PH-VS-SQL	44	Good
5/6/2021 18:19:47	PH-VS-SQL	212616	Good
5/6/2021 18:19:47	PH-VS-SQL	1333	Good

(b) (3) (A)

5/6/2021 18:19:47	PH-VS-SQL	46	Good
5/6/2021 18:19:49	PH-VS-SQL	50	Good
5/6/2021 18:19:57	PH-VS-SQL	212616	Good
5/6/2021 18:19:57	PH-VS-SQL	1333	Good
5/6/2021 18:20:00	PH-VS-SQL	37	Good
5/6/2021 18:20:05	PH-VS-SQL	43	Good
5/6/2021 18:20:06	PH-VS-SQL	45	Good
5/6/2021 18:20:07	PH-VS-SQL	212616	Good
5/6/2021 18:20:07	PH-VS-SQL	1333	Good
5/6/2021 18:20:10	PH-VS-SQL	49	Good
5/6/2021 18:20:17	PH-VS-SQL	212616	Good
5/6/2021 18:20:19	PH-VS-SQL	37	Good
5/6/2021 18:20:25	PH-VS-SQL	44	Good
5/6/2021 18:20:26	PH-VS-SQL	46	Good
5/6/2021 18:20:27	PH-VS-SQL	1334	Good
5/6/2021 18:20:28	PH-VS-SQL	49	Good
5/6/2021 18:20:37	PH-VS-SQL	212616	Good
5/6/2021 18:20:39	PH-VS-SQL	38	Good
5/6/2021 18:20:45	PH-VS-SQL	45	Good
5/6/2021 18:20:46	PH-VS-SQL	46	Good
5/6/2021 18:20:49	PH-VS-SQL	49	Good
5/6/2021 18:20:57	PH-VS-SQL	212616	Good
5/6/2021 18:20:57	PH-VS-SQL	1333	Good
5/6/2021 18:20:58	PH-VS-SQL	38	Good
5/6/2021 18:21:04	PH-VS-SQL	44	Good
5/6/2021 18:21:05	PH-VS-SQL	45	Good
5/6/2021 18:21:07	PH-VS-SQL	1333	Good
5/6/2021 18:21:09	PH-VS-SQL	48	Good
5/6/2021 18:21:17	PH-VS-SQL	212616	Good
5/6/2021 18:21:17	PH-VS-SQL	1333	Good
5/6/2021 18:21:18	PH-VS-SQL	39	Good
5/6/2021 18:21:24	PH-VS-SQL	45	Good
5/6/2021 18:21:25	PH-VS-SQL	46	Good
5/6/2021 18:21:27	PH-VS-SQL	1333	Good
5/6/2021 18:21:28	PH-VS-SQL	48	Good
5/6/2021 18:21:37	PH-VS-SQL	212616	Good
5/6/2021 18:21:37	PH-VS-SQL	1334	Good
5/6/2021 18:21:38	PH-VS-SQL	39	Good
5/6/2021 18:21:44	PH-VS-SQL	45	Good
5/6/2021 18:21:45	PH-VS-SQL	46	Good
5/6/2021 18:21:47	PH-VS-SQL	1333	Good
5/6/2021 18:21:47	PH-VS-SQL	272237	Good
5/6/2021 18:21:48	PH-VS-SQL	47	Good
5/6/2021 18:21:57	PH-VS-SQL	1334	Good
5/6/2021 18:21:58	PH-VS-SQL	39	Good
5/6/2021 18:22:03	PH-VS-SQL	44	Good
5/6/2021 18:22:04	PH-VS-SQL	46	Good

(b) (3) (A)

5/6/2021 18:22:07	PH-VS-SQL	212616	Good
5/6/2021 18:22:07	PH-VS-SQL	1333	Good
5/6/2021 18:22:07	PH-VS-SQL	47	Good
5/6/2021 18:22:17	PH-VS-SQL	1333	Good
5/6/2021 18:22:17	PH-VS-SQL	40	Good
5/6/2021 18:22:23	PH-VS-SQL	45	Good
5/6/2021 18:22:24	PH-VS-SQL	46	Good
5/6/2021 18:22:27	PH-VS-SQL	1333	Good
5/6/2021 18:22:27	PH-VS-SQL	47	Good
5/6/2021 18:22:37	PH-VS-SQL	212616	Good
5/6/2021 18:22:37	PH-VS-SQL	1333	Good
5/6/2021 18:22:37	PH-VS-SQL	40	Good
5/6/2021 18:22:42	PH-VS-SQL	44	Good
5/6/2021 18:22:43	PH-VS-SQL	45	Good
5/6/2021 18:22:46	PH-VS-SQL	47	Good
5/6/2021 18:22:47	PH-VS-SQL	1333	Good
5/6/2021 18:22:57	PH-VS-SQL	40	Good
5/6/2021 18:23:02	PH-VS-SQL	44	Good
5/6/2021 18:23:03	PH-VS-SQL	46	Good
5/6/2021 18:23:05	PH-VS-SQL	46	Good
5/6/2021 18:23:07	PH-VS-SQL	1333	Good
5/6/2021 18:23:16	PH-VS-SQL	40	Good
5/6/2021 18:23:17	PH-VS-SQL	1333	Good
5/6/2021 18:23:22	PH-VS-SQL	44	Good
5/6/2021 18:23:23	PH-VS-SQL	44	Good
5/6/2021 18:23:27	PH-VS-SQL	1333	Good
5/6/2021 18:23:32	PH-VS-SQL	35	Good
5/6/2021 18:23:37	PH-VS-SQL	1333	Good
5/6/2021 18:23:41	PH-VS-SQL	49	Good
5/6/2021 18:23:42	PH-VS-SQL	49	Good
5/6/2021 18:23:47	PH-VS-SQL	212616	Good
5/6/2021 18:23:47	PH-VS-SQL	1334	Good
5/6/2021 18:23:51	PH-VS-SQL	38	Good
5/6/2021 18:23:57	PH-VS-SQL	1335	Good
5/6/2021 18:24:01	PH-VS-SQL	47	Good
5/6/2021 18:24:02	PH-VS-SQL	47	Good
5/6/2021 18:24:07	PH-VS-SQL	212616	Good
5/6/2021 18:24:07	PH-VS-SQL	1336	Good
5/6/2021 18:24:10	PH-VS-SQL	40	Good
5/6/2021 18:24:17	PH-VS-SQL	1336	Good
5/6/2021 18:24:21	PH-VS-SQL	45	Good
5/6/2021 18:24:22	PH-VS-SQL	45	Good
5/6/2021 18:24:27	PH-VS-SQL	212616	Good
5/6/2021 18:24:27	PH-VS-SQL	1337	Good
5/6/2021 18:24:30	PH-VS-SQL	41	Good
5/6/2021 18:24:37	PH-VS-SQL	212616	Good
5/6/2021 18:24:37	PH-VS-SQL	1338	Good

(b) (3) (A)

5/6/2021 18:24:40	PH-VS-SQL	45	Good
5/6/2021 18:24:41	PH-VS-SQL	44	Good
5/6/2021 18:24:42	PH-VS-SQL	44	Good
5/6/2021 18:24:47	PH-VS-SQL	212616	Good
5/6/2021 18:24:47	PH-VS-SQL	1339	Good
5/6/2021 18:24:50	PH-VS-SQL	41	Good
5/6/2021 18:24:57	PH-VS-SQL	212616	Good
5/6/2021 18:24:57	PH-VS-SQL	1340	Good
5/6/2021 18:25:00	PH-VS-SQL	44	Good
5/6/2021 18:25:01	PH-VS-SQL	44	Good
5/6/2021 18:25:02	PH-VS-SQL	44	Good
5/6/2021 18:25:07	PH-VS-SQL	212616	Good
5/6/2021 18:25:07	PH-VS-SQL	1340	Good
5/6/2021 18:25:08	PH-VS-SQL	42	Good
5/6/2021 18:25:17	PH-VS-SQL	212616	Good
5/6/2021 18:25:17	PH-VS-SQL	1341	Good
5/6/2021 18:25:19	PH-VS-SQL	43	Good
5/6/2021 18:25:20	PH-VS-SQL	43	Good
5/6/2021 18:25:27	PH-VS-SQL	1342	Good
5/6/2021 18:25:29	PH-VS-SQL	42	Good
5/6/2021 18:25:37	PH-VS-SQL	212616	Good
5/6/2021 18:25:37	PH-VS-SQL	1342	Good
5/6/2021 18:25:38	PH-VS-SQL	43	Good
5/6/2021 18:25:39	PH-VS-SQL	43	Good
5/6/2021 18:25:40	PH-VS-SQL	43	Good
5/6/2021 18:25:47	PH-VS-SQL	212616	Good
5/6/2021 18:25:47	PH-VS-SQL	1343	Good
5/6/2021 18:25:48	PH-VS-SQL	42	Good
5/6/2021 18:25:57	PH-VS-SQL	212616	Good
5/6/2021 18:25:57	PH-VS-SQL	1344	Good
5/6/2021 18:25:59	PH-VS-SQL	43	Good
5/6/2021 18:26:00	PH-VS-SQL	43	Good
5/6/2021 18:26:07	PH-VS-SQL	212616	Good
5/6/2021 18:26:07	PH-VS-SQL	1345	Good
5/6/2021 18:26:10	PH-VS-SQL	42	Good
5/6/2021 18:26:17	PH-VS-SQL	212616	Good
5/6/2021 18:26:17	PH-VS-SQL	1346	Good
5/6/2021 18:26:18	PH-VS-SQL	43	Good
5/6/2021 18:26:19	PH-VS-SQL	43	Good
5/6/2021 18:26:21	PH-VS-SQL	43	Good
5/6/2021 18:26:25	PH-VS-SQL	42	Good
5/6/2021 18:26:27	PH-VS-SQL	212616	Good
5/6/2021 18:26:27	PH-VS-SQL	1346	Good
5/6/2021 18:26:37	PH-VS-SQL	212616	Good
5/6/2021 18:26:37	PH-VS-SQL	1347	Good
5/6/2021 18:26:38	PH-VS-SQL	43	Good
5/6/2021 18:26:39	PH-VS-SQL	43	Good

(b) (3) (A)

5/6/2021 18:26:47	PH-VS-SQL	212616	Good
5/6/2021 18:26:47	PH-VS-SQL	1347	Good
5/6/2021 18:26:48	PH-VS-SQL	42	Good
5/6/2021 18:26:52	PH-VS-SQL	43	Good
5/6/2021 18:26:57	PH-VS-SQL	212616	Good
5/6/2021 18:26:57	PH-VS-SQL	1349	Good
5/6/2021 18:26:58	PH-VS-SQL	43	Good
5/6/2021 18:26:59	PH-VS-SQL	43	Good
5/6/2021 18:27:02	PH-VS-SQL	43	Good
5/6/2021 18:27:07	PH-VS-SQL	212616	Good
5/6/2021 18:27:07	PH-VS-SQL	1349	Good
5/6/2021 18:27:11	PH-VS-SQL	42	Good
5/6/2021 18:27:17	PH-VS-SQL	212616	Good
5/6/2021 18:27:17	PH-VS-SQL	1350	Good
5/6/2021 18:27:17	PH-VS-SQL	43	Good
5/6/2021 18:27:18	PH-VS-SQL	43	Good
5/6/2021 18:27:24	PH-VS-SQL	43	Good
5/6/2021 18:27:27	PH-VS-SQL	212616	Good
5/6/2021 18:27:27	PH-VS-SQL	1350	Good
5/6/2021 18:27:27	PH-VS-SQL	42	Good
5/6/2021 18:27:37	PH-VS-SQL	212616	Good
5/6/2021 18:27:37	PH-VS-SQL	1352	Good
5/6/2021 18:27:37	PH-VS-SQL	42	Good
5/6/2021 18:27:38	PH-VS-SQL	43	Good
5/6/2021 18:27:39	PH-VS-SQL	42	Good
5/6/2021 18:27:47	PH-VS-SQL	212616	Good
5/6/2021 18:27:47	PH-VS-SQL	1352	Good
5/6/2021 18:27:51	PH-VS-SQL	43	Good
5/6/2021 18:27:57	PH-VS-SQL	212616	Good
5/6/2021 18:27:57	PH-VS-SQL	1353	Good
5/6/2021 18:27:57	PH-VS-SQL	42	Good
5/6/2021 18:27:59	PH-VS-SQL	43	Good
5/6/2021 18:28:02	PH-VS-SQL	42	Good
5/6/2021 18:28:07	PH-VS-SQL	212616	Good
5/6/2021 18:28:07	PH-VS-SQL	1354	Good
5/6/2021 18:28:07	PH-VS-SQL	272237	Good
5/6/2021 18:28:08	PH-VS-SQL	43	Good
5/6/2021 18:28:16	PH-VS-SQL	43	Good
5/6/2021 18:28:17	PH-VS-SQL	212616	Good
5/6/2021 18:28:17	PH-VS-SQL	1355	Good
5/6/2021 18:28:17	PH-VS-SQL	43	Good
5/6/2021 18:28:19	PH-VS-SQL	42	Good
5/6/2021 18:28:27	PH-VS-SQL	212616	Good
5/6/2021 18:28:27	PH-VS-SQL	1356	Good
5/6/2021 18:28:30	PH-VS-SQL	43	Good
5/6/2021 18:28:36	PH-VS-SQL	43	Good
5/6/2021 18:28:37	PH-VS-SQL	212616	Good

(b) (3) (A)

5/6/2021 18:28:37	PH-VS-SQL	1356	Good
5/6/2021 18:28:37	PH-VS-SQL	42	Good
5/6/2021 18:28:44	PH-VS-SQL	42	Good
5/6/2021 18:28:47	PH-VS-SQL	1357	Good
5/6/2021 18:28:49	PH-VS-SQL	43	Good
5/6/2021 18:28:55	PH-VS-SQL	42	Good
5/6/2021 18:28:56	PH-VS-SQL	43	Good
5/6/2021 18:28:57	PH-VS-SQL	212616	Good
5/6/2021 18:28:57	PH-VS-SQL	1357	Good
5/6/2021 18:28:57	PH-VS-SQL	43	Good
5/6/2021 18:29:03	PH-VS-SQL	42	Good
5/6/2021 18:29:07	PH-VS-SQL	212616	Good
5/6/2021 18:29:07	PH-VS-SQL	1358	Good
5/6/2021 18:29:07	PH-VS-SQL	272237	Good
5/6/2021 18:29:15	PH-VS-SQL	42	Good
5/6/2021 18:29:16	PH-VS-SQL	42	Good
5/6/2021 18:29:17	PH-VS-SQL	212616	Good
5/6/2021 18:29:17	PH-VS-SQL	1359	Good
5/6/2021 18:29:17	PH-VS-SQL	43	Good
5/6/2021 18:29:22	PH-VS-SQL	42	Good
5/6/2021 18:29:27	PH-VS-SQL	212616	Good
5/6/2021 18:29:27	PH-VS-SQL	1360	Good
5/6/2021 18:29:27	PH-VS-SQL	272237	Good
5/6/2021 18:29:35	PH-VS-SQL	42	Good
5/6/2021 18:29:36	PH-VS-SQL	42	Good
5/6/2021 18:29:37	PH-VS-SQL	212616	Good
5/6/2021 18:29:37	PH-VS-SQL	1360	Good
5/6/2021 18:29:42	PH-VS-SQL	43	Good
5/6/2021 18:29:47	PH-VS-SQL	212616	Good
5/6/2021 18:29:47	PH-VS-SQL	1361	Good
5/6/2021 18:29:54	PH-VS-SQL	43	Good
5/6/2021 18:29:55	PH-VS-SQL	42	Good
5/6/2021 18:29:57	PH-VS-SQL	212616	Good
5/6/2021 18:29:57	PH-VS-SQL	1362	Good
5/6/2021 18:29:57	PH-VS-SQL	272237	Good
5/6/2021 18:29:58	PH-VS-SQL	43	Good
5/6/2021 18:29:59	PH-VS-SQL	42	Good
5/6/2021 18:30:00	PH-VS-SQL	1	Good
5/6/2021 18:30:00	PH-VS-SQL	0	Good
5/6/2021 18:30:00	PH-VS-SQL	43	Good
5/6/2021 18:30:00	PH-VS-SQL	212616	Good
5/6/2021 18:30:00	PH-VS-SQL	272237	Good
5/6/2021 18:30:00	PH-VS-SQL	1363	Good

VII. REFERENCES AND CRITERIA

The following primary references and criteria documents have been utilized in the overall facility inspection and evaluation:

ASME B31.3	Process Piping, 2016 Edition
ASTM A53	Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc-Coated, Welded and Seamless
NFPA 30	Flammable and Combustible Liquids Code
NFPA 750	Standard on Water Mist Fire Protection Systems
MIL-HDBK-1022	Petroleum Fuel Facilities (superseded by UFC 3-460-01 - Design: Petroleum Fuel Facilities)